

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
QUALITY INVESTMENT PROPERTIES IRVING, LLC

AUTHORIZING THE OPERATION OF
QTS Irving
Other Computer Related Services

LOCATED AT
Dallas County, Texas
Latitude 32° 53' 50" Longitude 96° 58' 59"
Regulated Entity Number: RN102166386

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: Q4771 Issuance Date: _____

For the Commission

Table of Contents

| Section | Page |
|---|------|
| General Terms and Conditions | 1 |
| Special Terms and Conditions: | 1 |
| Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting..... | 1 |
| New Source Review Authorization Requirements | 6 |
| Compliance Requirements..... | 7 |
| Protection of Stratospheric Ozone | 8 |
| Temporary Fuel Shortages (30 TAC § 112.15) | 9 |
| Permit Location | 9 |
| Permit Shield (30 TAC § 122.148) | 9 |
| Attachments | 10 |
| Applicable Requirements Summary..... | 11 |
| Permit Shield..... | 44 |
| New Source Review Authorization References | 48 |
| Appendix A..... | 57 |
| Acronym List | 58 |

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive

ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer’s eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity

requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to

condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

D. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:

- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
- (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
- (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).

5. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
- B. Title 40 CFR § 60.8 (relating to Performance Tests)

- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
6. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
 7. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

New Source Review Authorization Requirements

8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated January 20, 2026 in the application for project 38315), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air

contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
12. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Dallas-Fort Worth Eight-Hour Nonattainment area, 30 TAC § 117.9030
 - B. The permit holder shall comply with the Initial Control Plan unit identification requirements in 30 TAC § 117.450(a) and (a)(1)-(7).
 - C. The permit holder shall comply with the requirements of 30 TAC § 117.452 for Final Control Plan Procedures for Reasonably Available Control Technology (RACT) and 30 TAC § 117.456 for Revision of Final Control Plan.
 - D. The permit holder shall comply with the requirements of 30 TAC § 117.454 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.456 for Revision of Final Control Plan.
 - E. The permit holder shall comply with the requirement in 30 TAC § 117.450(b) for identification of exempt units in the Initial Control Plan.
13. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)

- (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
- (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

14. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

15. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:

- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-

conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Temporary Fuel Shortages (30 TAC § 112.15)

16. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
 - A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
 - B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
 - C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
 - D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

Permit Location

17. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

18. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary **12**

Applicable Requirements Summary **20**

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|---------------------------------------|------------------|---|----------------------|-------------------------------------|---------------------------|
| EGEN3 | SRIC ENGINES | N/A | R7-EGEN1/2b | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| EGEN3 | SRIC ENGINES | N/A | 63III-EGEN1/2b | 40 CFR Part 60, Subpart III | No changing attributes. |
| EGEN3 | SRIC ENGINES | N/A | 63ZZZZ- EGEN1/2b | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-EGENDC1/2A | SRIC ENGINES | EGEN1, EGEN10, EGEN11, EGEN4, EGEN7, EGEN8 | R7-EGEN1/2a | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-EGENDC1/2A | SRIC ENGINES | EGEN1, EGEN10, EGEN11, EGEN4, EGEN7, EGEN8 | 63III-EGEN1/2a | 40 CFR Part 60, Subpart III | No changing attributes. |
| GRP-EGENDC1/2A | SRIC ENGINES | EGEN1, EGEN10, EGEN11, EGEN4, EGEN7, EGEN8 | 63ZZZZ- EGEN1/2a | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP- EGENDC1/2C | SRIC ENGINES | EGEN12, EGEN6 | R7-EGEN1/2c | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP- EGENDC1/2C | SRIC ENGINES | EGEN12, EGEN6 | 63III-EGEN1/2c | 40 CFR Part 60, Subpart III | No changing attributes. |
| GRP- EGENDC1/2C | SRIC ENGINES | EGEN12, EGEN6 | 63ZZZZ- EGEN1/2c | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP- EGENDC1/2D | SRIC ENGINES | EGEN13, EGEN14, EGEN15, EGEN16, EGEN17, EGEN18, EGEN19, EGEN2, EGEN5, EGEN9 | R7-EGEN1/2d | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP- EGENDC1/2D | SRIC ENGINES | EGEN13, EGEN14, EGEN15, EGEN16, EGEN17, EGEN18, EGEN19, EGEN2, | 63III-EGEN1/2d | 40 CFR Part 60, Subpart III | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|---------------------|-------------------------------------|-------------------------|
| | | EGEN5, EGEN9 | | | |
| GRP- EGENDC1/2D | SRIC ENGINES | EGEN13, EGEN14, EGEN15, EGEN16, EGEN17, EGEN18, EGEN19, EGEN2, EGEN5, EGEN9 | 63ZZZZ- EGEN1/2d | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-EGENDC3/4 | SRIC ENGINES | EGEN20, EGEN21, EGEN22, EGEN23, EGEN24, EGEN25, EGEN26, EGEN27, EGEN28, EGEN29, EGEN30, EGEN31, EGEN32, EGEN33, EGEN34, EGEN35, EGEN36, EGEN37, EGEN38, EGEN39, EGEN40, EGEN41, EGEN42, EGEN43, EGEN44, EGEN45, EGEN46, EGEN47, EGEN48, EGEN49, EGEN50, EGEN51, EGEN52, EGEN53, EGEN54, EGEN55, EGEN56, EGEN57, EGEN58, EGEN59, EGEN60, EGEN61, EGEN62, EGEN63, EGEN64, EGEN65, EGEN66, EGEN67, EGEN68, EGEN69, EGEN70, EGEN71, EGEN72, EGEN73 | R7-EGEN3/4 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|----------------|---------------------------------|-------------------------|
| GRP-EGENDC3/4 | SRIC ENGINES | EGEN20, EGEN21, EGEN22, EGEN23, EGEN24, EGEN25, EGEN26, EGEN27, EGEN28, EGEN29, EGEN30, EGEN31, EGEN32, EGEN33, EGEN34, EGEN35, EGEN36, EGEN37, EGEN38, EGEN39, EGEN40, EGEN41, EGEN42, EGEN43, EGEN44, EGEN45, EGEN46, EGEN47, EGEN48, EGEN49, EGEN50, EGEN51, EGEN52, EGEN53, EGEN54, EGEN55, EGEN56, EGEN57, EGEN58, EGEN59, EGEN60, EGEN61, EGEN62, EGEN63, EGEN64, EGEN65, EGEN66, EGEN67, EGEN68, EGEN69, EGEN70, EGEN71, EGEN72, EGEN73 | 63IIII-EGEN3/4 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-EGENDC3/4 | SRIC ENGINES | EGEN20, EGEN21, EGEN22, EGEN23, EGEN24, EGEN25, EGEN26, EGEN27, EGEN28, EGEN29, EGEN30, EGEN31, EGEN32, EGEN33, EGEN34, EGEN35, | 63ZZZZ-EGEN3/4 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|---------------|-------------------------------------|-------------------------|
| | | EGEN36, EGEN37, EGEN38, EGEN39, EGEN40, EGEN41, EGEN42, EGEN43, EGEN44, EGEN45, EGEN46, EGEN47, EGEN48, EGEN49, EGEN50, EGEN51, EGEN52, EGEN53, EGEN54, EGEN55, EGEN56, EGEN57, EGEN58, EGEN59, EGEN60, EGEN61, EGEN62, EGEN63, EGEN64, EGEN65, EGEN66, EGEN67, EGEN68, EGEN69, EGEN70, EGEN71, EGEN72, EGEN73 | | | |
| GRP-EGENDC5/6 | SRIC ENGINES | EGEN100, EGEN101, EGEN102, EGEN103, EGEN104, EGEN105, EGEN106, EGEN107, EGEN108, EGEN109, EGEN110, EGEN111, EGEN112, EGEN113, EGEN114, EGEN115, | R7-EGEN5/6 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|----------------|------------------------------|-------------------------|
| | | EGEN116, EGEN117, EGEN118, EGEN119, EGEN120, EGEN74, EGEN75, EGEN76, EGEN77, EGEN78, EGEN79, EGEN80, EGEN81, EGEN82, EGEN83, EGEN84, EGEN85, EGEN86, EGEN87, EGEN88, EGEN89, EGEN90, EGEN91, EGEN92, EGEN93, EGEN94, EGEN95, EGEN96, EGEN97, EGEN98, EGEN99 | | | |
| GRP-EGENDC5/6 | SRIC ENGINES | EGEN100, EGEN101, EGEN102, EGEN103, EGEN104, EGEN105, EGEN106, EGEN107, EGEN108, EGEN109, EGEN110, EGEN111, EGEN112, EGEN113, EGEN114, EGEN115, EGEN116, | 63IIII-EGEN5/6 | 40 CFR Part 60, Subpart IIII | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|----------------|---------------------------------|-------------------------|
| | | EGEN117, EGEN118, EGEN119, EGEN120, EGEN74, EGEN75, EGEN76, EGEN77, EGEN78, EGEN79, EGEN80, EGEN81, EGEN82, EGEN83, EGEN84, EGEN85, EGEN86, EGEN87, EGEN88, EGEN89, EGEN90, EGEN91, EGEN92, EGEN93, EGEN94, EGEN95, EGEN96, EGEN97, EGEN98, EGEN99 | | | |
| GRP-EGENDC5/6 | SRIC ENGINES | EGEN100, EGEN101, EGEN102, EGEN103, EGEN104, EGEN105, EGEN106, EGEN107, EGEN108, EGEN109, EGEN110, EGEN111, EGEN112, EGEN113, EGEN114, EGEN115, EGEN116, EGEN117, | 63ZZZZ-EGEN5/6 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|-------------------------------|--------------|--|---------------|-------------------------------------|-------------------------|
| | | EGEN118, EGEN119, EGEN120, EGEN74, EGEN75, EGEN76, EGEN77, EGEN78, EGEN79, EGEN80, EGEN81, EGEN82, EGEN83, EGEN84, EGEN85, EGEN86, EGEN87, EGEN88, EGEN89, EGEN90, EGEN91, EGEN92, EGEN93, EGEN94, EGEN95, EGEN96, EGEN97, EGEN98, EGEN99 | | | |
| GRP-FIREPUMP1 | SRIC ENGINES | FP1 | R7-FP1 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-FIREPUMP1 | SRIC ENGINES | FP1 | 63IIII-FP1 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-FIREPUMP1 | SRIC ENGINES | FP1 | 63ZZZZ-FP1 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-FIREPUMP2 | SRIC ENGINES | FP2 | R7-FP2 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-FIREPUMP2 | SRIC ENGINES | FP2 | 63IIII-FP2 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-FIREPUMP2 | SRIC ENGINES | FP2 | 63ZZZZ-FP2 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-FIREPUMP3 | SRIC ENGINES | FP4 | R7-FP4 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-FIREPUMP3 | SRIC ENGINES | FP4 | 63IIII-FP4 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-FIREPUMP3 | SRIC ENGINES | FP4 | 63ZZZZ-FP4 | 40 CFR Part 63, Subpart | No changing attributes. |

Unit Summary

| Unit/Group/ Process ID No. | Unit Type | Group/Inclusive Units | SOP Index No. | Regulation | Requirement Driver |
|---------------------------------------|------------------|----------------------------------|----------------------|-------------------------------------|---------------------------|
| | | | | ZZZZ | |
| GRP-FIREPUMP4 | SRIC ENGINES | FP5, FP6 | R7-FP5/6 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-FIREPUMP4 | SRIC ENGINES | FP5, FP6 | 63IIII-FP5/6 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-FIREPUMP4 | SRIC ENGINES | FP5, FP6 | 63ZZZZ-FP5/6 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-HSEGENDC3 | SRIC ENGINES | DC3HSE | R7-HSEDC3 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-HSEGENDC3 | SRIC ENGINES | DC3HSE | 63IIII-HSEDC3 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-HSEGENDC3 | SRIC ENGINES | DC3HSE | 63ZZZZ-HSEDC3 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-HSEGENDC4 | SRIC ENGINES | DC4HSE | R7-HSEDC4 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-HSEGENDC4 | SRIC ENGINES | DC4HSE | 63IIII-HSEDC4 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-HSEGENDC4 | SRIC ENGINES | DC4HSE | 63ZZZZ-HSEDC4 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-HSEGENDC5 | SRIC ENGINES | DC5HSE | R7-HSEDC5 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-HSEGENDC5 | SRIC ENGINES | DC5HSE | 63IIII-HSEDC5 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-HSEGENDC5 | SRIC ENGINES | DC5HSE | 63ZZZZ-HSEDC5 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |
| GRP-HSEGENDC6 | SRIC ENGINES | DC6HSE | R7-HSEDC6 | 30 TAC Chapter 117, Subchapter B | No changing attributes. |
| GRP-HSEGENDC6 | SRIC ENGINES | DC6HSE | 63IIII-HSEDC6 | 40 CFR Part 60, Subpart IIII | No changing attributes. |
| GRP-HSEGENDC6 | SRIC ENGINES | DC6HSE | 63ZZZZ-HSEDC6 | 40 CFR Part 63, Subpart ZZZZ | No changing attributes. |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|-----------------|-----------------|---------------------------------------|--|--|---|---|---|
| EGEN3 | EU | R7-EGEN1/2b | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| EGEN3 | EU | 63IIII-EGEN1/2b | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| EGEN3 | EU | 63IIII- | PM | 40 CFR Part 60, | § 60.4205(d)(3) | Owners and operators of | § 60.4211(d)(1) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|-----------------|-------------|---------------------------------------|---|--|--|---|---|
| | | EGEN1/2b | | Subpart IIII | § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | | [G]§ 60.4214(d) |
| EGEN3 | EU | 63ZZZZ-EGEN1/2b | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-EGENDC1/2 A | EU | R7-EGEN1/2a | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|-----------------|-----------------|---------------------------------------|--|---|---|---|---|
| | | | | | | § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-EGENDC1/2 A | EU | 63IIII-EGEN1/2a | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC1/2 A | EU | 63IIII-EGEN1/2a | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC1/2 A | EU | 63ZZZZ-EGEN1/2a | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|-----------------|-----------------|---------------------------------------|--|--|---|---|---|
| | | | | | | part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |
| GRP-EGENDC1/2C | EU | R7-EGEN1/2c | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-EGENDC1/2C | EU | 63IIII-EGEN1/2c | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|-----------------|-------------|---------------------------------------|---|--|---|---|---|
| | | | | | | speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | | | |
| GRP-EGENDC1/2 C | EU | 63IIII-EGEN1/2c | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC1/2 C | EU | 63ZZZZ-EGEN1/2c | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-EGENDC1/2 D | EU | R7-EGEN1/2d | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|----------------|-----------------|---------------------------------------|--|---|---|---|---|
| | | | | | | diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-EGENDC1/2D | EU | 63III-EGEN1/2d | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC1/2D | EU | 63III-EGEN1/2d | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP- | EU | 63ZZZ- | 112(B) | 40 CFR Part 63, | § 63.6590(c) | Stationary RICE subject to | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|----------------|-----------------|---------------------------------------|---|--|-------------------------------------|---|---|
| EGENDC1/2D | | EGEN1/2d | HAPS | Subpart ZZZZ | | Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |
| GRP-EGENDC3/4 | EU | R7-EGEN3/4 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-EGENDC3/4 | EU | 63IIII-EGEN3/4 | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 | Owners and operators of emergency stationary CI | § 60.4211(d)(1) § 60.4213(a) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|----------------|-------------|---------------------------------------|---|---|---|---|---|
| | | | | | § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NOx emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4213(b) § 60.4213(c) § 60.4213(e) | | |
| GRP-EGENDC3/4 | EU | 63IIII-EGEN3/4 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC3/4 | EU | 63ZZZZ-EGEN3/4 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|----------------|-----------------|---------------------------------------|--|--|---|---|---|
| | | | | | | engines under this part. | | | |
| GRP-EGENDC5/6 | EU | R7-EGEN5/6 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-EGENDC5/6 | EU | 63IIII-EGEN5/6 | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|----------------|-------------|---------------------------------------|---|--|---|---|---|
| GRP-EGENDC5/6 | EU | 63IIII-EGEN5/6 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-EGENDC5/6 | EU | 63ZZZZ-EGEN5/6 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-FIREPUMP1 | EU | R7-FP1 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|--------------------------|---------------------------------------|---|--|-------------------------------------|---|---|
| | | | | | | engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-FIREPUMP1 | EU | 63IIII-FP1 | NMHC and NO _x | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr, as listed in Table 4 to this subpart. | None | None | None |
| GRP-FIREPUMP1 | EU | 63IIII-FP1 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as listed in Table 4 to this subpart. | None | None | None |
| GRP-FIREPUMP1 | EU | 63ZZZZ-FP1 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|--------------------------|---------------------------------------|--|--|-------------------------------------|---|---|
| | | | | | | through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |
| GRP-FIREPUMP2 | EU | R7-FP2 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-FIREPUMP2 | EU | 63IIII-FP2 | NMHC and NO _x | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal | None | None | [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-------------|---------------------------------------|---|---|-------------------------------------|---|---|
| | | | | | [G]§ 60.4211(f) | to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart. | | | |
| GRP-FIREPUMP2 | EU | 63IIII-FP2 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as listed in Table 4 to this subpart. | None | None | [G]§ 60.4214(d) |
| GRP-FIREPUMP2 | EU | 63ZZZZ-FP2 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|--------------------------|---------------------------------------|---|--|-------------------------------------|---|---|
| | | | | | | engines under this part. | | | |
| GRP-FIREPUMP3 | EU | R7-FP4 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-FIREPUMP3 | EU | 63IIII-FP4 | NMHC and NO _x | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr, as listed in Table 4 to this subpart. | None | None | None |
| GRP-FIREPUMP3 | EU | 63IIII-FP4 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 | Owners and operators of emergency stationary fire pump CI ICE with a | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-------------|---------------------------------------|--|--|-------------------------------------|---|---|
| | | | | | § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as listed in Table 4 to this subpart. | | | |
| GRP-FIREPUMP3 | EU | 63ZZZZ-FP4 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-FIREPUMP4 | EU | R7-FP5/6 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|--------------------------|---------------------------------------|---|--|-------------------------------------|---|---|
| | | | | | | emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-FIREPUMP4 | EU | 63IIII-FP5/6 | NMHC and NO _x | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr, as listed in Table 4 to this subpart. | None | None | None |
| GRP-FIREPUMP4 | EU | 63IIII-FP5/6 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 30 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as listed in Table 4 to this subpart. | None | None | None |
| GRP-FIREPUMP4 | EU | 63ZZZZ-FP5/6 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-----------|---------------------------------------|---|--|-------------------------------------|---|---|
| | | | | | | Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |
| GRP-HSEGENDC3 | EU | R7-HSEDC3 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-HSEGENDC3 | EU | 63IIII-HSEDC3 | CO | 40 CFR Part 60, Subpart IIII | § 60.4205(b) § 1042.101 § 60.4202(f)(1) | Owners and operators of emergency stationary CI ICE, that are not fire pump | None | None | [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|------------------------|---------------------------------------|--|--|-------------------------------------|---|---|
| | | | | | § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | engines, with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(e)-(f), 40 CFR 1042.101, and 40 CFR 1042-Appendix I. | | | |
| GRP-HSEGENDC3 | EU | 63III-HSEDC3 | HC and NO _x | 40 CFR Part 60, Subpart IIII | § 60.4205(b) § 1042.101 § 60.4202(f)(1) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 600 KW and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder and is a 2013 model year and later must comply with an HC+NO _x emission limit of 6.2 g/KW-hr, as stated in 40 CFR 60.4202(f)(1) and 40 CFR 1042.101. | None | None | [G]§ 60.4214(d) |
| GRP-HSEGENDC3 | EU | 63III-HSEDC3 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(b) § 1042.101 § 60.4202(f)(1) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 600 KW and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder and is a 2013 model year and later must comply with | None | None | [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-------------|---------------------------------------|---|--|-------------------------------------|---|---|
| | | | | | | a PM emission limit of 0.14 g/KW-hr, as stated in 40 CFR 60.4202(f)(1) and 40 CFR 1042.101. | | | |
| GRP-HSEGENDC3 | EU | 63ZZZZ-HSEDC3 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-HSEGENDC4 | EU | R7-HSEDC4 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-----------------|---------------------------------------|--|---|---|---|---|
| | | | | | | installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-HSEGENDC4 | EU | 63IIII-HSEDC4 | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-HSEGENDC4 | EU | 63IIII-HSEDC4 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-HSEGENDC4 | EU | 63ZZZZ-HSEDC4 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-----------------|---------------------------------------|--|--|---|---|---|
| | | | | | | engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |
| GRP-HSEGENDC5 | EU | R7-HSEDC5 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |
| GRP-HSEGENDC5 | EU | 63IIII-HSEDC5 | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-------------|---------------------------------------|---|--|---|---|---|
| | | | | | | maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | | | |
| GRP-HSEGENDC 5 | EU | 63IIII-HSEDC5 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-HSEGENDC 5 | EU | 63ZZZZ-HSEDC5 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | None | None | None |
| GRP-HSEGENDC 6 | EU | R7-HSEDC6 | Exempt | 30 TAC Chapter 117, Subchapter B | [G]§ 117.403(a)(9) § 117.403(a) [G]§ 117.410(f) | Units exempt from this division, except as specified in §§ 117.440(i), 117.445(f)(4) and (9), 117.450 and 117.454, include new, modified, reconstructed or relocated diesel engines placed into service on or after June 1, | None | § 117.440(i) § 117.445(f) § 117.445(f)(4) [G]§ 117.445(f)(9) | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-----------------|---------------------------------------|--|---|---|---|---|
| | | | | | | 2007 that operate less than 100 hr/yr except in emergency situations and that meet the emission standard for non-road engines listed in 40 CFR § 89.112(a), Table 1 in effect at the time of installation, modification, reconstruction or relocation per § 117.403(a)(9)(A)-(B) | | | |
| GRP-HSEGENDC6 | EU | 63IIII-HSEDC6 | NO _x | 40 CFR Part 60, Subpart IIII | [G]§ 60.4205(d)(2) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder and was installed on or after 01/01/2012 must comply with the following NO _x emission limits: 14.4 g/KW-hr when maximum engine speed is less than 130 rpm, 44.0 x N-0.23 when maximum engine speed is at least 130 but less than 2000 rpm, and 7.7 g/KW-hr when maximum engine speed is 2000 rpm or more. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(e) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-HSEGENDC6 | EU | 63IIII-HSEDC6 | PM | 40 CFR Part 60, Subpart IIII | § 60.4205(d)(3) § 60.4206 § 60.4207(d) § 60.4211(d) [G]§ 60.4211(f) | Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must comply with a PM emission limit of 0.40 g/KW-hr. | § 60.4211(d)(1) § 60.4213(a) § 60.4213(b) § 60.4213(c) § 60.4213(f) | [G]§ 60.4211(d)(2) | [G]§ 60.4211(d)(2) [G]§ 60.4214(d) |
| GRP-HSEGENDC6 | EU | 63ZZZZ-HSEDC6 | 112(B) HAPS | 40 CFR Part 63, Subpart ZZZZ | § 63.6590(c) | Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source | None | None | None |

Applicable Requirements Summary

| Unit Group Process ID No. | Unit Group Process Type | SOP Index No. | Pollutant | State Rule or Federal Regulation Name | Emission Limitation, Standard or Equipment Specification Citation | Textual Description (See Special Term and Condition 1.B.) | Monitoring And Testing Requirements | Recordkeeping Requirements (30 TAC § 122.144) | Reporting Requirements (30 TAC § 122.145) |
|---------------------------|-------------------------|---------------|-----------|---------------------------------------|---|--|-------------------------------------|--|--|
| | | | | | | that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part. | | | |

Permit Shield

Permit Shield 45

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

| Unit / Group / Process ID No. | Group / Inclusive Units | Regulation | Basis of Determination |
|-------------------------------|---|--|--|
| EGEN3 | N/A | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-EGENDC1/2A | EGEN1, EGEN10, EGEN11, EGEN4, EGEN7, EGEN8 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-EGENDC1/2C | EGEN12, EGEN6 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-EGENDC1/2D | EGEN13, EGEN14, EGEN15, EGEN16, EGEN17, EGEN18, EGEN19, EGEN2, EGEN5, EGEN9 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-EGENDC3/4 | EGEN20, EGEN21, EGEN22, EGEN23, EGEN24, EGEN25, EGEN26, EGEN27, EGEN28, EGEN29, EGEN30, EGEN31, EGEN32, EGEN33, EGEN34, EGEN35, EGEN36, EGEN37, EGEN38, EGEN39, EGEN40, EGEN41, EGEN42, EGEN43, EGEN44, EGEN45, EGEN46, EGEN47, EGEN48, EGEN49, EGEN50, EGEN51, EGEN52, EGEN53, EGEN54, EGEN55, EGEN56, EGEN57, EGEN58, EGEN59, EGEN60, EGEN61, | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

| Unit / Group / Process ID No. | Group / Inclusive Units | Regulation | Basis of Determination |
|-------------------------------|---|--|--|
| | EGEN62, EGEN63, EGEN64, EGEN65, EGEN66, EGEN67, EGEN68, EGEN69, EGEN70, EGEN71, EGEN72, EGEN73 | | |
| GRP-EGENDC5/6 | EGEN100, EGEN101, EGEN102, EGEN103, EGEN104, EGEN105, EGEN106, EGEN107, EGEN108, EGEN109, EGEN110, EGEN111, EGEN112, EGEN113, EGEN114, EGEN115, EGEN116, EGEN117, EGEN118, EGEN119, EGEN120, EGEN74, EGEN75, EGEN76, EGEN77, EGEN78, EGEN79, EGEN80, EGEN81, EGEN82, EGEN83, EGEN84, EGEN85, EGEN86, EGEN87, EGEN88, EGEN89, EGEN90, EGEN91, EGEN92, EGEN93, EGEN94, EGEN95, EGEN96, EGEN97, EGEN98, EGEN99 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-FIREPUMP1 | FP1 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998) |
| GRP-FIREPUMP2 | FP2 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-FIREPUMP3 | FP4 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road |

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

| Unit / Group / Process ID No. | Group / Inclusive Units | Regulation | Basis of Determination |
|-------------------------------|-------------------------|---|--|
| | | | engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-FIREPUMP4 | FP5, FP6 | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-HSEGENDC3 | DC3HSE | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-HSEGENDC4 | DC4HSE | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-HSEGENDC5 | DC5HSE | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |
| GRP-HSEGENDC6 | DC6HSE | 30 TAC Chapter 117, Nitric Acid Man.-Ozone NA | Will operate less than 100 hr/yr for non-emergency purposes and meets the non-road engine standards in 40 CFR 89.112(a), Table 1 (October 23, 1998). |

New Source Review Authorization References

New Source Review Authorization References 49

New Source Review Authorization References by Emission Unit 50

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Permits By Rule (30 TAC Chapter 106) for the Application Area | |
|--|------------------------------|
| Number: 106.371 | Version No./Date: 09/04/2000 |
| Number: 106.372 | Version No./Date: 09/04/2000 |
| Number: 106.472 | Version No./Date: 09/04/2000 |
| Number: 106.511 | Version No./Date: 09/04/2000 |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| DC3HSE | DC3 HOUSE GENERATOR | 106.511/09/04/2000 [163702] |
| DC4HSE | DC4 HOUSE GENERATOR | 106.511/09/04/2000 [163702] |
| DC5HSE | DC5 HOUSE GENERATOR | 106.511/09/04/2000 [163702] |
| DC6HSE | DC6 HOUSE GENERATOR | 106.511/09/04/2000 [163702] |
| EGEN1 | EMERGENCY GENERATOR 1 | 106.511/09/04/2000 [163702] |
| EGEN10 | EMERGENCY GENERATOR 10 | 106.511/09/04/2000 [163702] |
| EGEN100 | EMERGENCY GENERATOR 100 | 106.511/09/04/2000 [163702] |
| EGEN101 | EMERGENCY GENERATOR 101 | 106.511/09/04/2000 [163702] |
| EGEN102 | EMERGENCY GENERATOR 102 | 106.511/09/04/2000 [163702] |
| EGEN103 | EMERGENCY GENERATOR 103 | 106.511/09/04/2000 [163702] |
| EGEN104 | EMERGENCY GENERATOR 104 | 106.511/09/04/2000 [163702] |
| EGEN105 | EMERGENCY GENERATOR 105 | 106.511/09/04/2000 [163702] |
| EGEN106 | EMERGENCY GENERATOR 106 | 106.511/09/04/2000 [163702] |
| EGEN107 | EMERGENCY GENERATOR 107 | 106.511/09/04/2000 [163702] |
| EGEN108 | EMERGENCY GENERATOR 108 | 106.511/09/04/2000 [163702] |
| EGEN109 | EMERGENCY GENERATOR 109 | 106.511/09/04/2000 [163702] |
| EGEN11 | EMERGENCY GENERATOR 11 | 106.511/09/04/2000 [163702] |
| EGEN110 | EMERGENCY GENERATOR 110 | 106.511/09/04/2000 [163702] |
| EGEN111 | EMERGENCY GENERATOR 111 | 106.511/09/04/2000 [163702] |
| EGEN112 | EMERGENCY GENERATOR 112 | 106.511/09/04/2000 [163702] |
| EGEN113 | EMERGENCY GENERATOR 113 | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| EGEN114 | EMERGENCY GENERATOR 114 | 106.511/09/04/2000 [163702] |
| EGEN115 | EMERGENCY GENERATOR 115 | 106.511/09/04/2000 [163702] |
| EGEN116 | EMERGENCY GENERATOR 116 | 106.511/09/04/2000 [163702] |
| EGEN117 | EMERGENCY GENERATOR 117 | 106.511/09/04/2000 [163702] |
| EGEN118 | EMERGENCY GENERATOR 118 | 106.511/09/04/2000 [163702] |
| EGEN119 | EMERGENCY GENERATOR 119 | 106.511/09/04/2000 [163702] |
| EGEN12 | EMERGENCY GENERATOR 12 | 106.511/09/04/2000 [163702] |
| EGEN120 | EMERGENCY GENERATOR 120 | 106.511/09/04/2000 [163702] |
| EGEN13 | EMERGENCY GENERATOR 13 | 106.511/09/04/2000 [163702] |
| EGEN14 | EMERGENCY GENERATOR 14 | 106.511/09/04/2000 [163702] |
| EGEN15 | EMERGENCY GENERATOR 15 | 106.511/09/04/2000 [163702] |
| EGEN16 | EMERGENCY GENERATOR 16 | 106.511/09/04/2000 [163702] |
| EGEN17 | EMERGENCY GENERATOR 17 | 106.511/09/04/2000 [163702] |
| EGEN18 | EMERGENCY GENERATOR 18 | 106.511/09/04/2000 [163702] |
| EGEN19 | EMERGENCY GENERATOR 19 | 106.511/09/04/2000 [163702] |
| EGEN2 | EMERGENCY GENERATOR 2 | 106.511/09/04/2000 [163702] |
| EGEN20 | EMERGENCY GENERATOR 20 | 106.511/09/04/2000 [163702] |
| EGEN21 | EMERGENCY GENERATOR 21 | 106.511/09/04/2000 [163702] |
| EGEN22 | EMERGENCY GENERATOR 22 | 106.511/09/04/2000 [163702] |
| EGEN23 | EMERGENCY GENERATOR 23 | 106.511/09/04/2000 [163702] |
| EGEN24 | EMERGENCY GENERATOR 24 | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| EGEN25 | EMERGENCY GENERATOR 25 | 106.511/09/04/2000 [163702] |
| EGEN26 | EMERGENCY GENERATOR 26 | 106.511/09/04/2000 [163702] |
| EGEN27 | EMERGENCY GENERATOR 27 | 106.511/09/04/2000 [163702] |
| EGEN28 | EMERGENCY GENERATOR 28 | 106.511/09/04/2000 [163702] |
| EGEN29 | EMERGENCY GENERATOR 29 | 106.511/09/04/2000 [163702] |
| EGEN3 | EMERGENCY GENERATOR 3 | 106.511/09/04/2000 [163702] |
| EGEN30 | EMERGENCY GENERATOR 30 | 106.511/09/04/2000 [163702] |
| EGEN31 | EMERGENCY GENERATOR 31 | 106.511/09/04/2000 [163702] |
| EGEN32 | EMERGENCY GENERATOR 32 | 106.511/09/04/2000 [163702] |
| EGEN33 | EMERGENCY GENERATOR 33 | 106.511/09/04/2000 [163702] |
| EGEN34 | EMERGENCY GENERATOR 34 | 106.511/09/04/2000 [163702] |
| EGEN35 | EMERGENCY GENERATOR 35 | 106.511/09/04/2000 [163702] |
| EGEN36 | EMERGENCY GENERATOR 36 | 106.511/09/04/2000 [163702] |
| EGEN37 | EMERGENCY GENERATOR 37 | 106.511/09/04/2000 [163702] |
| EGEN38 | EMERGENCY GENERATOR 38 | 106.511/09/04/2000 [163702] |
| EGEN39 | EMERGENCY GENERATOR 39 | 106.511/09/04/2000 [163702] |
| EGEN4 | EMERGENCY GENERATOR 4 | 106.511/09/04/2000 [163702] |
| EGEN40 | EMERGENCY GENERATOR 40 | 106.511/09/04/2000 [163702] |
| EGEN41 | EMERGENCY GENERATOR 41 | 106.511/09/04/2000 [163702] |
| EGEN42 | EMERGENCY GENERATOR 42 | 106.511/09/04/2000 [163702] |
| EGEN43 | EMERGENCY GENERATOR 43 | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| EGEN44 | EMERGENCY GENERATOR 44 | 106.511/09/04/2000 [163702] |
| EGEN45 | EMERGENCY GENERATOR 45 | 106.511/09/04/2000 [163702] |
| EGEN46 | EMERGENCY GENERATOR 46 | 106.511/09/04/2000 [163702] |
| EGEN47 | EMERGENCY GENERATOR 47 | 106.511/09/04/2000 [163702] |
| EGEN48 | EMERGENCY GENERATOR 48 | 106.511/09/04/2000 [163702] |
| EGEN49 | EMERGENCY GENERATOR 49 | 106.511/09/04/2000 [163702] |
| EGEN5 | EMERGENCY GENERATOR 5 | 106.511/09/04/2000 [163702] |
| EGEN50 | EMERGENCY GENERATOR 50 | 106.511/09/04/2000 [163702] |
| EGEN51 | EMERGENCY GENERATOR 51 | 106.511/09/04/2000 [163702] |
| EGEN52 | EMERGENCY GENERATOR 52 | 106.511/09/04/2000 [163702] |
| EGEN53 | EMERGENCY GENERATOR 53 | 106.511/09/04/2000 [163702] |
| EGEN54 | EMERGENCY GENERATOR 54 | 106.511/09/04/2000 [163702] |
| EGEN55 | EMERGENCY GENERATOR 55 | 106.511/09/04/2000 [163702] |
| EGEN56 | EMERGENCY GENERATOR 56 | 106.511/09/04/2000 [163702] |
| EGEN57 | EMERGENCY GENERATOR 57 | 106.511/09/04/2000 [163702] |
| EGEN58 | EMERGENCY GENERATOR 58 | 106.511/09/04/2000 [163702] |
| EGEN59 | EMERGENCY GENERATOR 59 | 106.511/09/04/2000 [163702] |
| EGEN6 | EMERGENCY GENERATOR 6 | 106.511/09/04/2000 [163702] |
| EGEN60 | EMERGENCY GENERATOR 60 | 106.511/09/04/2000 [163702] |
| EGEN61 | EMERGENCY GENERATOR 61 | 106.511/09/04/2000 [163702] |
| EGEN62 | EMERGENCY GENERATOR 62 | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| EGEN63 | EMERGENCY GENERATOR 63 | 106.511/09/04/2000 [163702] |
| EGEN64 | EMERGENCY GENERATOR 64 | 106.511/09/04/2000 [163702] |
| EGEN65 | EMERGENCY GENERATOR 65 | 106.511/09/04/2000 [163702] |
| EGEN66 | EMERGENCY GENERATOR 66 | 106.511/09/04/2000 [163702] |
| EGEN67 | EMERGENCY GENERATOR 67 | 106.511/09/04/2000 [163702] |
| EGEN68 | EMERGENCY GENERATOR 68 | 106.511/09/04/2000 [163702] |
| EGEN69 | EMERGENCY GENERATOR 69 | 106.511/09/04/2000 [163702] |
| EGEN7 | EMERGENCY GENERATOR 7 | 106.511/09/04/2000 [163702] |
| EGEN70 | EMERGENCY GENERATOR 70 | 106.511/09/04/2000 [163702] |
| EGEN71 | EMERGENCY GENERATOR 71 | 106.511/09/04/2000 [163702] |
| EGEN72 | EMERGENCY GENERATOR 72 | 106.511/09/04/2000 [163702] |
| EGEN73 | EMERGENCY GENERATOR 73 | 106.511/09/04/2000 [163702] |
| EGEN74 | EMERGENCY GENERATOR 74 | 106.511/09/04/2000 [163702] |
| EGEN75 | EMERGENCY GENERATOR 75 | 106.511/09/04/2000 [163702] |
| EGEN76 | EMERGENCY GENERATOR 76 | 106.511/09/04/2000 [163702] |
| EGEN77 | EMERGENCY GENERATOR 77 | 106.511/09/04/2000 [163702] |
| EGEN78 | EMERGENCY GENERATOR 78 | 106.511/09/04/2000 [163702] |
| EGEN79 | EMERGENCY GENERATOR 79 | 106.511/09/04/2000 [163702] |
| EGEN8 | EMERGENCY GENERATOR 8 | 106.511/09/04/2000 [163702] |
| EGEN80 | EMERGENCY GENERATOR 80 | 106.511/09/04/2000 [163702] |
| EGEN81 | EMERGENCY GENERATOR 81 | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| EGEN82 | EMERGENCY GENERATOR 82 | 106.511/09/04/2000 [163702] |
| EGEN83 | EMERGENCY GENERATOR 83 | 106.511/09/04/2000 [163702] |
| EGEN84 | EMERGENCY GENERATOR 84 | 106.511/09/04/2000 [163702] |
| EGEN85 | EMERGENCY GENERATOR 85 | 106.511/09/04/2000 [163702] |
| EGEN86 | EMERGENCY GENERATOR 86 | 106.511/09/04/2000 [163702] |
| EGEN87 | EMERGENCY GENERATOR 87 | 106.511/09/04/2000 [163702] |
| EGEN88 | EMERGENCY GENERATOR 88 | 106.511/09/04/2000 [163702] |
| EGEN89 | EMERGENCY GENERATOR 89 | 106.511/09/04/2000 [163702] |
| EGEN9 | EMERGENCY GENERATOR 9 | 106.511/09/04/2000 [163702] |
| EGEN90 | EMERGENCY GENERATOR 90 | 106.511/09/04/2000 [163702] |
| EGEN91 | EMERGENCY GENERATOR 91 | 106.511/09/04/2000 [163702] |
| EGEN92 | EMERGENCY GENERATOR 92 | 106.511/09/04/2000 [163702] |
| EGEN93 | EMERGENCY GENERATOR 93 | 106.511/09/04/2000 [163702] |
| EGEN94 | EMERGENCY GENERATOR 94 | 106.511/09/04/2000 [163702] |
| EGEN95 | EMERGENCY GENERATOR 95 | 106.511/09/04/2000 [163702] |
| EGEN96 | EMERGENCY GENERATOR 96 | 106.511/09/04/2000 [163702] |
| EGEN97 | EMERGENCY GENERATOR 97 | 106.511/09/04/2000 [163702] |
| EGEN98 | EMERGENCY GENERATOR 98 | 106.511/09/04/2000 [163702] |
| EGEN99 | EMERGENCY GENERATOR 99 | 106.511/09/04/2000 [163702] |
| FP1 | DC1 FIRE PUMP | 106.511/09/04/2000 [163702] |
| FP2 | DC2 FIRE PUMP | 106.511/09/04/2000 [163702] |

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

| Unit/Group/Process ID No. | Emission Unit Name/Description | New Source Review Authorization** |
|---------------------------|--------------------------------|-----------------------------------|
| FP4 | DC4 FIRE PUMP | 106.511/09/04/2000 [163702] |
| FP5 | DC5 FIRE PUMP | 106.511/09/04/2000 [163702] |
| FP6 | DC6 FIRE PUMP | 106.511/09/04/2000 [163702] |

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 58

Acronym List

The following abbreviations or acronyms may be used in this permit:

| | |
|------------------|---|
| ACFM | actual cubic feet per minute |
| AMOC | alternate means of control |
| ARP | Acid Rain Program |
| ASTM | American Society of Testing and Materials |
| B/PA | Beaumont/Port Arthur (nonattainment area) |
| CAM | Compliance Assurance Monitoring |
| CD | control device |
| CEMS | continuous emissions monitoring system |
| CFR | Code of Federal Regulations |
| COMS | continuous opacity monitoring system |
| CVS | closed vent system |
| D/FW | Dallas/Fort Worth (nonattainment area) |
| EP | emission point |
| EPA | U.S. Environmental Protection Agency |
| EU | emission unit |
| FCAA Amendments | Federal Clean Air Act Amendments |
| FOP | federal operating permit |
| gr/100 scf | grains per 100 standard cubic feet |
| HAP | hazardous air pollutant |
| H/G/B | Houston/Galveston/Brazoria (nonattainment area) |
| H ₂ S | hydrogen sulfide |
| ID No. | identification number |
| lb/hr | pound(s) per hour |
| MACT | Maximum Achievable Control Technology (40 CFR Part 63) |
| MMBtu/hr | Million British thermal units per hour |
| NA | nonattainment |
| N/A | not applicable |
| NADB | National Allowance Data Base |
| NESHAP | National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61) |
| NO _x | nitrogen oxides |
| NSPS | New Source Performance Standard (40 CFR Part 60) |
| NSR | New Source Review |
| ORIS | Office of Regulatory Information Systems |
| Pb | lead |
| PBR | Permit By Rule |
| PEMS | predictive emissions monitoring system |
| PM | particulate matter |
| ppmv | parts per million by volume |
| PRO | process unit |
| PSD | prevention of significant deterioration |
| psia | pounds per square inch absolute |
| RO | Responsible Official |
| SIP | state implementation plan |
| SO ₂ | sulfur dioxide |
| TCEQ | Texas Commission on Environmental Quality |
| TSP | total suspended particulate |
| TVP | true vapor pressure |
| U.S.C. | United States Code |
| VOC | volatile organic compound |