

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
US Department of the Air Force

AUTHORIZING THE OPERATION OF
Joint Base San Antonio Lackland
National Security

LOCATED AT
Bexar County, Texas
Latitude 29° 24' 5" Longitude 98° 37' 12"
Regulated Entity Number: RN100542729

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1393 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	8
New Source Review Authorization Requirements	9
Compliance Requirements.....	9
Protection of Stratospheric Ozone	11
Alternative Requirements	11
Permit Location	12
Permit Shield (30 TAC § 122.148)	12
Attachments	13
Applicable Requirements Summary.....	14
Additional Monitoring Requirements	147
Permit Shield.....	152
New Source Review Authorization References	157
Schedules	183
Alternative Requirement.....	186
Appendix A.....	189
Acronym List	190

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
 - F. Emission units subject to 40 CFR Part 63, Subpart CCCCCC as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1380 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic

monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under

30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which

condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The

observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

- G. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.211 (relating to Exception for Prescribed Burn)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: "Storage of Volatile Organic Compounds," the permit holder shall comply with the requirements of 30 TAC § 115.112(c)(1).
- 5. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
 - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:
 - (i) Title 30 TAC § 115.222(3) (relating to Control Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (ii) Title 30 TAC § 115.222(6) (relating to Control Requirements)
 - (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)
- 6. The permit holder shall comply with the following requirements of 30 TAC Chapter 117:
 - A. For the manufacturing, distribution, sales, and installation of natural gas-fired water heaters, boilers, and process heaters subject to Subchapter E, Division 3 (30 TAC § 117.3200):
 - (i) Title 30 TAC § 117.3205 (relating to Emission Specifications)
 - (ii) Title 30 TAC § 117.3210 (relating to Certification Requirements)
 - (iii) Title 30 TAC § 117.3215 (relating to Notification and Labeling Requirements)
- 7. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)

- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
8. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
9. For each gasoline dispensing facility, with a throughput of less than 10,000 gallons per month as specified in 40 CFR Part 63, Subpart CCCCC, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1380 incorporated by reference):
- A. Title 40 CFR § 63.11111(e), for records of monthly throughput
 - B. Title 40 CFR § 63.11111(i), for compliance due to increase of throughput
 - C. Title 40 CFR § 63.11111(j), for dispensing from fixed tank into portable tank for on-site delivery
 - D. Title 40 CFR § 63.11113(c), for compliance due to increase of throughput
 - E. Title 40 CFR § 63.11115(a), for operation of the source
 - F. Title 40 CFR § 63.11116(a) and (a)(1) - (4), for work practices
 - G. Title 40 CFR § 63.11116(b), for records availability
 - H. Title 40 CFR § 63.11116(d), for portable gasoline containers
10. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

11. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit

holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

12. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated December 8, 2025 in the application for project 39290), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
13. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
14. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

15. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
16. The permit holder shall adhere to the provisions in the Compliance Schedule attachment of this permit and submit certified progress reports consistent with the schedule established under 30 TAC § 122.132(d)(4)(C) and including the information specified in 30 TAC § 122.142(d)(2).

Those emission units listed in the Compliance Schedule attachment shall adhere with the requirements in the Compliance Schedule attachment until operating fully in compliance with the applicable requirements.

17. Use of Emission Credits to comply with applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
- B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

18. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4

- (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

19. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. Any on site servicing, maintenance, and repair of fleet vehicle air conditioning using ozone-depleting refrigerants shall be conducted in accordance with 40 CFR Part 82, Subpart B. Permit holders shall ensure that repairs or refrigerant removal are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart B.
 - C. The permit holder shall comply with 40 CFR Part 82, Subpart D related to the procurement requirements of Class I or Class II (ozone-depleting) substances or products containing those substances as specified in 40 CFR § 82.80 - § 82.86 and the applicable Part 82 Appendices.
 - D. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.
 - E. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

Alternative Requirements

20. The permit holder shall comply with the approved alternative means of control (AMOC); alternative monitoring, recordkeeping, or reporting requirements; or requirements determined to be equivalent to an otherwise applicable requirement contained in the Alternative Requirements attachment of this permit. Units complying with an approved alternative requirement have reference to the approval in the Applicable Requirements summary listing for the unit. The permit holder shall maintain the original documentation, from the TCEQ Executive Director, demonstrating the method or limitation utilized. Documentation shall be maintained and made available in accordance with 30 TAC § 122.144.

Permit Location

21. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

22. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Schedules

Alternative Requirement

Applicable Requirements Summary

Unit Summary 15

Applicable Requirements Summary 35

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
AR08943AST	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
CE08171AST	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
FDSP600065	STORAGE TANKS/VESSELS	N/A	MACTCCCCC	40 CFR Part 63, Subpart CCCCC	No changing attributes.
FLD00894JETA	LOADING/UNLOADING OPERATIONS	N/A	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
FLD02890DSL	LOADING/UNLOADING OPERATIONS	N/A	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
FLD651227	LOADING/UNLOADING OPERATIONS	N/A	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
FLD827	LOADING/UNLOADING OPERATIONS	N/A	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
GRP-6	SOLVENT DEGREASING MACHINES	DEGR601094, DEGR674212, DEGR704054, DEGR876	R5411	30 TAC Chapter 115, Degreasing Processes	No changing attributes.
GRP-NEW1-25K	STORAGE TANKS/VESSELS	AST1443	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPATANKD2	STORAGE TANKS/VESSELS	AF20071AST, CE01711AST, CE01781AST, CE10521AST, CE20001AAST, CE20002AST,	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		CE20004AST, CE50751AST, CE65781AST, CE65822AST, CE65861AST, CE65882AST, CE65921AST, CE65961AST, LB16231AST, LR50233AST, MW45591AST			
GRPATANKG2	STORAGE TANKS/VESSELS	LR50231AST, LR50232AST	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPATANKG2	STORAGE TANKS/VESSELS	LR50231AST, LR50232AST	GACTCCCCC	40 CFR Part 63, Subpart CCCCC	No changing attributes.
GRPATANKJ2	STORAGE TANKS/VESSELS	LR111011AST, LR111021AST	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPECOMLAK	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	ECOM6586A, ECOM6586AA, ECOM6586AB, ECOM6586AC, ECOM6586AD, ECOM6586AE, ECOM6586AF, ECOM6586B, ECOM6586C, ECOM6586D, ECOM6586E, ECOM6586F, ECOM6586G, ECOM6586H, ECOM6586I, ECOM6586J,	R1111GRPECOM	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOM6586K, ECOM6586L, ECOM6586M, ECOM6586N, ECOM6586O, ECOM6586P, ECOM6586Q, ECOM6586R, ECOM6586S, ECOM6586T, ECOM6586U, ECOM6586V, ECOM6586W, ECOM6586X, ECOM6586Y, ECOM6586Z, ECOMK1531, ECOMK1610, ECOMK1612, ECOMK1614A, ECOMK1614B, ECOMK1621A, ECOMK1621B, ECOMK1623, ECOMK1650A, ECOMK1650B, ECOMK1674, ECOMK1676A, ECOMK1676B, ECOMK171A, ECOMK171B, ECOMK171C, ECOMK171D, ECOMK178, ECOMK210,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOMK3030A, ECOMK3030B, ECOML10050, ECOML10055, ECOML10060, ECOML10070A, ECOML10070B, ECOML10075A, ECOML10075B, ECOML10175, ECOML10203, ECOML10207, ECOML10215A, ECOML10215B, ECOML10251, ECOML10255, ECOML10261, ECOML10263, ECOML10265, ECOML1030, ECOML10330, ECOML10338, ECOML10390, ECOML10416A, ECOML10416B, ECOML10504A, ECOML10504B, ECOML10504C, ECOML10504D, ECOML10504E, ECOML10541, ECOML10634, ECOML10658A, ECOML10658B, ECOML10808,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML10810, ECOML10904A, ECOML10904B, ECOML10908, ECOML1160, ECOML1161, ECOML1178, ECOML1207, ECOML1212A, ECOML1212B, ECOML1212C, ECOML1215A, ECOML1215B, ECOML1215C, ECOML1215D, ECOML1215E, ECOML1217, ECOML1219, ECOML1249, ECOML1250, ECOML1285, ECOML1288, ECOML1415A, ECOML1415B, ECOML1415C, ECOML1423, ECOML1528, ECOML16000A, ECOML16000B, ECOML2000A, ECOML2000B, ECOML2028A, ECOML2028B, ECOML2041, ECOML2049,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML2067, ECOML2081, ECOML2088, ECOML2167, ECOML2169, ECOML2300, ECOML2418, ECOML2443, ECOML2484, ECOML2490A, ECOML2490B, ECOML2506, ECOML2901, ECOML3220, ECOML3352A, ECOML3352B, ECOML3352C, ECOML3352D, ECOML3425A, ECOML3425B, ECOML3550, ECOML3750A, ECOML3750B, ECOML3885, ECOML4430A, ECOML4430B, ECOML4430C, ECOML4430D, ECOML4550, ECOML4559A, ECOML4559B, ECOML4559C, ECOML4559D, ECOML4559E, ECOML4559F,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML4610, ECOML5004, ECOML5045, ECOML5100, ECOML5160, ECOML5200, ECOML5275, ECOML5277A, ECOML5277B, ECOML5311, ECOML5432, ECOML5497, ECOML5506, ECOML5570A, ECOML5570B, ECOML5595A, ECOML5595B, ECOML5616, ECOML5725, ECOML5747, ECOML6114, ECOML6300, ECOML6330A, ECOML6330B, ECOML6418A, ECOML6418B, ECOML6420, ECOML6476, ECOML6482, ECOML6576, ECOML6578A, ECOML6578B, ECOML6578C, ECOML6578D, ECOML6578E,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML6578F, ECOML6578G, ECOML6578H, ECOML6578I, ECOML6578J, ECOML6578K, ECOML6578L, ECOML6578M, ECOML6578O, ECOML6582A, ECOML6582B, ECOML6582C, ECOML6588A, ECOML6588B, ECOML6588C, ECOML6588D, ECOML6588E, ECOML6588F, ECOML6588G, ECOML6588H, ECOML6588I, ECOML6588J, ECOML6588K, ECOML6588L, ECOML6588M, ECOML6588N, ECOML6588O, ECOML6588P, ECOML6592A, ECOML6592B, ECOML6592C, ECOML6592D, ECOML6596A, ECOML6596B, ECOML6596C,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML6596D, ECOML6596E, ECOML6596F, ECOML6596G, ECOML6596H, ECOML6596I, ECOML6596J, ECOML6596K, ECOML6596L, ECOML6596M, ECOML6596N, ECOML6596O, ECOML6596P, ECOML6612, ECOML6629, ECOML7025, ECOML7037, ECOML7065A, ECOML7065B, ECOML7080, ECOML7214, ECOML7241, ECOML7243, ECOML7246, ECOML7342, ECOML7346A, ECOML7346B, ECOML7353, ECOML7355, ECOML7356, ECOML7357, ECOML7358, ECOML7360, ECOML7362, ECOML7364,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML7366, ECOML7368, ECOML7429A, ECOML7429B, ECOML7435, ECOML7445, ECOML7450, ECOML7460A, ECOML7460B, ECOML7475, ECOML7481, ECOML7485, ECOML7487, ECOML7538, ECOML7602A, ECOML7602B, ECOML814, ECOML817, ECOML8206, ECOML8210, ECOML825, ECOML826, ECOML828, ECOML829A, ECOML829B, ECOML830, ECOML832A, ECOML832B, ECOML8420A, ECOML8420B, ECOML874, ECOML896, ECOML898, ECOML9020, ECOML9028,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOML907, ECOML908, ECOML9085A, ECOML9085B, ECOML909, ECOML910A, ECOML910B, ECOML9110A, ECOML9110B, ECOML9122A, ECOML9122B, ECOML921, ECOML9210A, ECOML9210B, ECOML9225A, ECOML9225B, ECOML9310A, ECOML9310B, ECOML9410A, ECOML9410B, ECOML950A, ECOML950B, ECOML954, ECOMM124A, ECOMM124B, ECOMM124C, ECOMM127, ECOMM145, ECOMM147A, ECOMM147B, ECOMM147C, ECOMM150A, ECOMM150B, ECOMM199A, ECOMM199B,			

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ECOMM230A, ECOMM230B, ECOMM242, ECOMM315, ECOMM321, ECOMM331			
ICOM159032	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM159032	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM159033	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM159033	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM162741	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM162741	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM162743	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM162743	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600078	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600107	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600110	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600130	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM600130	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM600217	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600220	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600226	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM600226	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600267	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600292	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600376	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600377	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600406	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600407	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM600407	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM600408	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601059	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601061	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM601061	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM601062	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601063	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601065	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601067	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601068	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM601068	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601077	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM601077	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601079	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM601926	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM624	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649879	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649879	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649880	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649880	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649881	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM649881	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649883	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649883	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649884	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649888	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649888	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649889	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649889	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649890	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649890	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649891	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649891	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649893	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649893	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649894	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649894	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649895	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM649895	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649896	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649896	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649897	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649898	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM649898	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM649899	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM658360	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM690	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM690	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM695896	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM695896	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM703671	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM703671	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM703673	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM703673	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM703681	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704087	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704087	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704092	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704092	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704095	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704095	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704096	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704097	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704097	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704099	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704099	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704110	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704112	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704113	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704115	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM704116	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704122	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704122	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704227	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704227	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM704230	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM704230	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM706503	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM706503	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM706504	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM706504	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM706505	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM706505	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM712	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM717028	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM717028	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM723510	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ICOM723510	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM735974	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM735974	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM790	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM798	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM798	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM813278	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM813278	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM814	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM815748	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM815748	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM904	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ICOM929	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
ICOM929	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SURF600396	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Subchapter E, Division 5	No changing attributes.
SURF600396	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
SURF601064	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Subchapter E, Division 5	No changing attributes.
SURF601064	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.
SURF656672	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Subchapter E, Division 5	No changing attributes.
SURF656672	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.
SURF714	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Subchapter E, Division 5	No changing attributes.
SURF714	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.
SURF892	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Subchapter E, Division 5	No changing attributes.
SURF892	SURFACE COATING OPERATIONS	N/A	R5115	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
AR08943AST	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
CE08171AST	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
FDSP600065	EU	MACTCC CCCC	112(B) HAPS	40 CFR Part 63, Subpart CCCCCC	§ 63.11117(b)(3) § 63.11111(c) § 63.11111(i) § 63.11115(a) § 63.11117(a) § 63.11117(b) § 63.11124(a) § 63.11124(a)(3)	Submerged fill pipes not meeting the specifications of paragraphs (b)(1) or (b)(2) of this section are allowed if the owner or operator can demonstrate that the liquid level in the tank is always above the entire opening of the fill pipe. Documentation providing such demonstration must be made available for inspection by the Administrator's delegated representative during the course of a site visit.	§ 63.11117(b)(3)	§ 63.11111(e) § 63.11117(b)(3) § 63.11117(d) [G]§ 63.11125(d)	§ 63.11126(b)
FLD00894JETA	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						division, except as specified.			
FLD02890D SL	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
FLD651227	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
FLD827	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
GRP-6	EU	R5411	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.412(a)(1) § 115.411(a)(1) § 115.411(a)(2) [G]§ 115.412(a)(1)(A) § 115.412(a)(1)(C) [G]§ 115.412(a)(1)(F)	No person shall own or operate a system utilizing a VOC for the cold solvent cleaning of objects without the controls listed in §115.412(a)(1)(A)-(F), except as exempted in §115.411.	[G]§ 115.415(1) § 115.415(4) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEW1-25K	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPATANK D2	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPATANK G2	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
GRPATANK G2	EU	GACTCC CCCC	112(B) HAPS	40 CFR Part 63, Subpart CCCCCC	§ 63.11117(b)(1) § 63.11111(c) § 63.11111(i) § 63.11115(a) § 63.11117(a) § 63.11117(b) § 63.11124(a)	For facilities with a monthly throughput of 10,000 gallons or more but less than 100,000 gallons of gasoline, submerged fill pipes installed on gasoline storage tanks on or before	None	§ 63.11111(e) § 63.11117(d) [G]§ 63.11125(d)	§ 63.11126(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.11124(a)(3)	11/09/2006 must be no more than 12 inches from the bottom of the tank.			
GRPATANK J2	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
GRPECOMLAK	EP	R1111GRPECOM	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
ICOM15903 2	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM15903 2	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM15903 2	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM15903 2	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM15903 2	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM15903 3	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a CO emission limit of 11.4 g/KW-hr, as listed in Table 1 to this subpart.	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM159033	EU	60III	Hydrocarbons	40 CFR Part 60, Subpart III	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with an HC emission limit of 1.3 g/KW-hr, as listed in Table 1 to this subpart.	None	None	[G]§ 60.4214(d)
ICOM159033	EU	60III	NO _x	40 CFR Part 60, Subpart III	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a NO _x emission limit of 9.2 g/KW-hr, as listed in Table 1 to this subpart.	None	None	[G]§ 60.4214(d)
ICOM159033	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a PM emission limit of 0.54 g/KW-hr, as listed in Table 1 to this	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						subpart.			
ICOM159033	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM162741	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM162741	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM16274 1	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM16274 1	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM16274 1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM16274 3	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)- Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1039-Appendix I, and Table 2 to this subpart.			
ICOM162743	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM162743	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM162743	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM600078	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600107	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6640(f)(4)(i)				
ICOM600110	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600130	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM600130	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM600130	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM600130	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM600130	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM600217	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600220	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1)	For each existing emergency stationary CI RICE and black start	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table	§ 63.6625(i) § 63.6655(e) § 63.6655(f)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6660(a) § 63.6660(b) § 63.6660(c)	
ICOM600226	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM600226	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM60022 6	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM60022 6	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM600226	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM600267	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600292	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	Table 2d.4.a-c.			
ICOM600376	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600377	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM600406	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1)	For each existing emergency stationary CI RICE and black start	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table	§ 63.6625(i) § 63.6655(e) § 63.6655(f)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6660(a) § 63.6660(b) § 63.6660(c)	
ICOM600407	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM600407	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
ICOM600407	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM600407	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition engines or 40 CFR part 60 subpart JJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM600408	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4	For each existing emergency stationary CI	§ 63.6625(i) § 63.6640(a)	§ 63.6625(i) § 63.6655(e)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	
ICOM601059	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM601061	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM601061	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601061	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601061	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM60106 1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM60106 2	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	Table 2d.4.a-c.			
ICOM601063	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM601065	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM601067	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1)	For each existing emergency stationary CI RICE and black start	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table	§ 63.6625(i) § 63.6655(e) § 63.6655(f)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6660(a) § 63.6660(b) § 63.6660(c)	
ICOM601068	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601068	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM601068	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601068	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM601068	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM601077	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601077	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f)	than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM601077	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM601077	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM601077	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM601079	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM60192	EU	63ZZZZ	112(B)	40 CFR Part 63,	§ 63.6603(a)-Table	For each existing	§ 63.6625(i)	§ 63.6625(i)	§ 63.6640(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
6			HAPS	Subpart ZZZZ	2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6650(f)
ICOM624	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM64987 9	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
ICOM649879	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM649879	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM649879	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM649880	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM649880	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	model year and later must comply with an NMHC+NOx emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
ICOM649880	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM649880	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						engines under this part.			
ICOM64988 1	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM64988 1	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM64988 1	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.			
ICOM64988 1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM64988 3	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649883	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649883	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649883	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM64988 3	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM64988 4	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	requirements as specified in Table 2d.4.a-c.			
ICOM649888	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649888	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1039-Appendix I.			
ICOM649888	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649888	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM649888	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1)	For each existing emergency stationary CI RICE and black start	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table	§ 63.6625(i) § 63.6655(e) § 63.6655(f)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6660(a) § 63.6660(b) § 63.6660(c)	
ICOM649889	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649889	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649889	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649889	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM649889	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM649890	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649890	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f)	than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649890	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649890	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM649890	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM649891	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM64989 1	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM64989 1	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM64989 1	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM64989 1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM64989 3	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649893	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649893	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649893	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1)	Emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM64989 3	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM64989 4	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649894	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649894	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649894	EU	60IIII	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM649894	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						engines under this part.			
ICOM649895	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649895	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649895	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649895	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM649895	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM649896	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649896	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649896	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I	Owners and operators of emergency stationary CI	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM64989 6	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM64989 6	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM649897	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM649898	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM649898	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649898	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM649898	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM649898	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM649899	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)				
ICOM658360	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM690	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM690	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2)	Owners and operators of emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM690	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM690	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM690	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM69589 6	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						2 to this subpart.			
ICOM695896	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM695896	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM695896	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM70367 1	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM70367 1	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM70367 1	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM70367 1	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM70367	EU	63ZZZZ	112(B)	40 CFR Part 63,	§ 63.6590(c)	Stationary RICE subject to	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
1			HAPS	Subpart ZZZZ		Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM703673	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM703673	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM703673	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM703673	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM703673	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM703681	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM704087	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I	Owners and operators of emergency stationary CI	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704087	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704087	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704087	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM704087	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM704092	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM704092	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM704092	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-	Owners and operators of emergency stationary CI ICE, that are not fire pump	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.			
ICOM70409 2	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM70409 5	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704095	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704095	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704095	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1)	Emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM704095	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM704096	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6640(a)-Table 6.9.a.ii	§ 63.6660(b) § 63.6660(c)	
ICOM704097	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704097	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704097	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704097	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM70409	EU	63ZZZ	112(B)	40 CFR Part 63,	§ 63.6590(c)	Stationary RICE subject to	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
7			HAPS	Subpart ZZZZ		Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM704099	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM704099	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
ICOM704099	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM704099	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						applicable. No further requirements apply for such engines under this part.			
ICOM704110	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM704112	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM704113	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	Table 2d.4.a-c.			
ICOM704115	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM704116	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM704122	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2)	Owners and operators of emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704122	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704122	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704122	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM704122	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements apply for such engines under this part.			
ICOM704227	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704227	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704227	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM704227	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM704227	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM704230	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704230	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1039-Appendix I.			
ICOM704230	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM704230	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM704230	EU	63ZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM706503	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706503	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM706503	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706503	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2),	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and 40 CFR 1039.105(b)(1)-(3).			
ICOM706503	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM706504	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706504	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM706504	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706504	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM706504	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM706505	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CFR 1039-Appendix I.			
ICOM706505	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706505	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM706505	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM706505	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM712	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)				
ICOM717028	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM717028	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM717028	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2)	Owners and operators of emergency stationary CI ICE, that are not fire pump	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM717028	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM717028	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM723510	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM723510	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM723510	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM723510	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM723510	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM735974	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM735974	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f)	cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
ICOM735974	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM735974	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements apply for such engines under this part.			
ICOM790	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM798	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	None
ICOM798	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	displacement of less than 10 liters per cylinder and is a 2008 model year and later, must comply with an NMHC+NOx emission limit of 4.7 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM798	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	None
ICOM798	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM798	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM813278	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	None
ICOM813278	EU	60IIII	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I	Owners and operators of emergency stationary CI	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later, must comply with an NMHC+NOx emission limit of 4.7 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM813278	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	None
ICOM813278	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
ICOM813278	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
ICOM814	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6640(f)(4) § 63.6640(f)(4)(i)				
ICOM815748	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM815748	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
ICOM815748	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	or equal to 75 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
ICOM81574 8	EU	60III	PM (Opacity)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ICOM81574 8	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ICOM904	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
ICOM929	EU	60IIII	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ICOM929	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
ICOM929	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
ICOM929	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
SURF600396	PRO	R5115	VOC	30 TAC Chapter 115, Subchapter E, Division 5	§ 115.453(a)(2) § 115.453(a) § 115.453(a)(1) [G]§ 115.453(c) § 115.453(d)(1) § 115.453(d)(1)(A) § 115.453(d)(1)(B) § 115.453(d)(1)(C) § 115.453(d)(1)(D) § 115.453(d)(1)(E) § 115.453(d)(2) § 115.453(d)(2)(A) § 115.453(d)(2)(B) § 115.453(d)(2)(C) § 115.453(d)(2)(D) § 115.453(d)(2)(E) § 115.453(d)(2)(F) § 115.453(d)(2)(G)	The coating VOC limits for motor vehicle materials specified in the Table in paragraph (a)(2) applied to the metal and plastic parts in paragraph (1)(C)-(F) of this subsection, as delivered to the application system, must be met using low-VOC coatings (minus water and exempt solvent).	§ 115.455(a) [G]§ 115.455(a)(1) § 115.455(a)(5) § 115.455(b)	§ 115.458(b)(1) § 115.458(b)(2) § 115.458(b)(6) § 115.458(b)(7)	None
SURF600396	PRO	R5115	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.427(5) [G]§ 115.422(6) § 115.426	The coating of vehicles at in-house (fleet) vehicle refinishing operations and the coating of vehicles by private individuals are exempt from §115.421(11)(B) and §115.422(1) and (2) of this title. This exemption is not applicable if the coating of a vehicle by a private	§ 115.426(4)	§ 115.426 § 115.426(4)	[G]§ 115.422(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						individual occurs at a commercial operation.			
SURF601064	PRO	R5115	VOC	30 TAC Chapter 115, Subchapter E, Division 5	§ 115.453(a)(1)(C)-Table 1 § 115.453(a) § 115.453(a)(1) § 115.453(a)(1)(C) [G]§ 115.453(c) § 115.453(d)(1) § 115.453(d)(1)(A) § 115.453(d)(1)(B) § 115.453(d)(1)(C) § 115.453(d)(1)(D) § 115.453(d)(1)(E) § 115.453(d)(2) § 115.453(d)(2)(A) § 115.453(d)(2)(B) § 115.453(d)(2)(C) § 115.453(d)(2)(D) § 115.453(d)(2)(E) § 115.453(d)(2)(F) § 115.453(d)(2)(G)	The VOC content of air-dried coating applied to miscellaneous metal parts and products shall not exceed the pounds of VOC per gallon of coating listed in Table 1.	§ 115.455(a) [G]§ 115.455(a)(1) § 115.455(a)(5) § 115.455(b)	§ 115.458(b)(1) § 115.458(b)(2) § 115.458(b)(6) § 115.458(b)(7)	None
SURF601064	PRO	R5115	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.421(10)(B) § 115.421 § 115.421(10) [G]§ 115.422(5)(A) [G]§ 115.422(5)(B) [G]§ 115.422(5)(D) § 115.422(5)(E) § 115.426 § 115.427(6)	The VOC content of specialty coatings as listed in subparagraph (B) of this paragraph shall not exceed the specified limits grams of VOC/liter of coating, less water and exempt solvent in Figure: 30 TAC §115.421(10)(B).	§ 115.424(a) § 115.424(b) [G]§ 115.425(1) § 115.425(5)(A) § 115.425(5)(B) § 115.425(5)(C) § 115.425(6) [G]§ 115.426(1)	§ 115.426 [G]§ 115.426(1) [G]§ 115.426(5)(A) § 115.426(5)(B) [G]§ 115.426(5)(C)	None
SURF656672	PRO	R5115	VOC	30 TAC Chapter 115, Subchapter E, Division 5	§ 115.453(a)(1)(C)-Table 1 § 115.453(a) § 115.453(a)(1) § 115.453(a)(1)(C) [G]§ 115.453(c) § 115.453(d)(1)	The VOC content of air-dried coating applied to miscellaneous metal parts and products shall not exceed the pounds of VOC per gallon of coating listed in Table 1.	§ 115.455(a) [G]§ 115.455(a)(1) § 115.455(a)(5) § 115.455(b)	§ 115.458(b)(1) § 115.458(b)(2) § 115.458(b)(6) § 115.458(b)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.453(d)(1)(A) § 115.453(d)(1)(B) § 115.453(d)(1)(C) § 115.453(d)(1)(D) § 115.453(d)(1)(E) § 115.453(d)(2) § 115.453(d)(2)(A) § 115.453(d)(2)(B) § 115.453(d)(2)(C) § 115.453(d)(2)(D) § 115.453(d)(2)(E) § 115.453(d)(2)(F) § 115.453(d)(2)(G)				
SURF65667 2	PRO	R5115	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.421(10)(B) § 115.421 § 115.421(10) [G]§ 115.422(5)(A) [G]§ 115.422(5)(B) [G]§ 115.422(5)(D) § 115.422(5)(E) § 115.426 § 115.427(6)	The VOC content of specialty coatings as listed in subparagraph (B) of this paragraph shall not exceed the specified limits grams of VOC/liter of coating, less water and exempt solvent in Figure: 30 TAC §115.421(10)(B).	§ 115.424(a) § 115.424(b) [G]§ 115.425(1) § 115.425(5)(A) § 115.425(5)(B) § 115.425(5)(C) § 115.425(6) [G]§ 115.426(1)	§ 115.426 [G]§ 115.426(1) [G]§ 115.426(5)(A) § 115.426(5)(B) [G]§ 115.426(5)(C)	None
SURF714	PRO	R5115	VOC	30 TAC Chapter 115, Subchapter E, Division 5	§ 115.453(a)(1)(C)- Table 1 § 115.453(a) § 115.453(a)(1) § 115.453(a)(1)(C) [G]§ 115.453(c) § 115.453(d)(1) § 115.453(d)(1)(A) § 115.453(d)(1)(B) § 115.453(d)(1)(C) § 115.453(d)(1)(D) § 115.453(d)(1)(E) § 115.453(d)(2) § 115.453(d)(2)(A) § 115.453(d)(2)(B) § 115.453(d)(2)(C)	The VOC content of air-dried coating applied to miscellaneous metal parts and products shall not exceed the pounds of VOC per gallon of coating listed in Table 1.	§ 115.455(a) [G]§ 115.455(a)(1) § 115.455(a)(5) § 115.455(b)	§ 115.458(b)(1) § 115.458(b)(2) § 115.458(b)(6) § 115.458(b)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.453(d)(2)(D) § 115.453(d)(2)(E) § 115.453(d)(2)(F) § 115.453(d)(2)(G)				
SURF714	PRO	R5115	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.421(8)(A) § 115.421 § 115.421(8)(B) § 115.421(8)(C) § 115.426	VOC emissions from the coating of miscellaneous metal parts and products shall not exceed 3.0 lbs/gal (0.36 kg/L) of coating (minus water and exempt solvent) delivered for all other coating applications, including high-bake coatings.	§ 115.424(a) § 115.424(b) [G]§ 115.425(1) § 115.425(6) [G]§ 115.426(1)	§ 115.426 [G]§ 115.426(1)	None
SURF892	PRO	R5115	VOC	30 TAC Chapter 115, Subchapter E, Division 5	§ 115.453(a)(1)(C)-Table 1 § 115.453(a) § 115.453(a)(1) § 115.453(a)(1)(C) [G]§ 115.453(c) § 115.453(d)(1) § 115.453(d)(1)(A) § 115.453(d)(1)(B) § 115.453(d)(1)(C) § 115.453(d)(1)(D) § 115.453(d)(1)(E) § 115.453(d)(2) § 115.453(d)(2)(A) § 115.453(d)(2)(B) § 115.453(d)(2)(C) § 115.453(d)(2)(D) § 115.453(d)(2)(E) § 115.453(d)(2)(F) § 115.453(d)(2)(G)	The VOC content of air-dried coating applied to miscellaneous metal parts and products shall not exceed the pounds of VOC per gallon of coating listed in Table 1.	§ 115.455(a) [G]§ 115.455(a)(1) § 115.455(a)(5) § 115.455(b)	§ 115.458(b)(1) § 115.458(b)(2) § 115.458(b)(6) § 115.458(b)(7)	None
SURF892	PRO	R5115	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.421(10)(B) § 115.421 § 115.421(10) [G]§ 115.422(5)(A)	The VOC content of specialty coatings as listed in subparagraph (B) of this paragraph shall not exceed	§ 115.424(a) § 115.424(b) [G]§ 115.425(1) § 115.425(5)(A)	§ 115.426 [G]§ 115.426(1) [G]§ 115.426(5)(A) § 115.426(5)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.422(5)(B) [G]§ 115.422(5)(D) § 115.422(5)(E) § 115.426 § 115.427(6)	the specified limits grams of VOC/liter of coating, less water and exempt solvent in Figure: 30 TAC §115.421(10)(B).	§ 115.425(5)(B) § 115.425(5)(C) § 115.425(6) [G]§ 115.426(1)	[G]§ 115.426(5)(C)	

Additional Monitoring Requirements

Periodic Monitoring Summary 148

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-6	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5411
Pollutant: VOC	Main Standard: § 115.412(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of 30 TAC § 115.412(1)(A)-(F).	
Periodic Monitoring Text: Inspect equipment and record data monthly to ensure compliance with any applicable requirements in § 115.412(a)(1)(A)-(F). Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of § 115.412(a)(1)(A)-(F) shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPATANKG2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Unable to produce tank construction specifications.	
<p>Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPATANKG2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Repairs not completed prior to refilling the storage vessel.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPECOMLAK	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111GRPECOM
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Permit Shield

Permit Shield 153

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
AR08943AST	N/A	40 CFR Part 60, Subpart K	40 CFR 60 Subpart K applies to tanks greater than or equal to 40,000 gals. This tank is under 40,000 gal.
AR08943AST	N/A	40 CFR Part 60, Subpart Ka	Tank is not used to store petroleum liquids. Therefore, Subpart Ka is not applicable.
AR08943AST	N/A	40 CFR Part 60, Subpart Kb	Subpart Kb applies to tanks greater than or equal to 75 cubic meters (19,800 gallons). Tank is less than 19,800 gal.
FDSP600065	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Motor vehicle fuel dispensing facilities are exempt.
FDSP601907	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Motor vehicle fuel dispensing facilities, as defined in §101.1 of this title, are exempt from the requirements of this division.
FLD00211DSL	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Motor vehicle fuel dispensing facilities, as defined in §101.1 of this title, are exempt from the requirements of this division.
GRPATANKD1	CE09541AST, CE09801AST, CE11602AST, CE160001AST, CE90641AST, CS04741AST, CS14081AST, CS14181AST, LB15311AST, LB16101AST, LB16741AST, MW76021AST, TW109081AT	30 TAC Chapter 115, Storage of VOCs	Storage tanks located in Bexar County which store a material having a vapor pressure less than 1.5 psia are exempt from 30 TAC 115 Storage of Volatile Organic Compounds per 30 TAC 115.111(c)(1). Tanks store diesel (diesel generator tanks) with VP<1.5
GRPATANKD1	CE11602AST, CS04742AST, LB15311AST, LB16741AST	40 CFR Part 60, Subpart K	40 CFR 60 Subpart K applies to tanks >= 40,000 gals which were constructed/modified between 6/11/73-5/19/78. These tanks were constructed after 5/19/78 and are <40,000 gals. Therefore Subpart K is not applicable.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPATANKD1	CE09541AST, CE09801AST, CE11602AST, CE160001AST, CE90641AST, CS04741AST, CS14081AST, CS14181AST, LB15311AST, LB16101AST, LB16741AST, MW76021AST, TW109081AT	40 CFR Part 60, Subpart K	40 CFR 60 Subpart K applies to tanks which commenced construction or modification after June 11, 1973, and prior to May 19, 1978. These tanks were constructed after May 19, 1978.
GRPATANKD1	CE09541AST, CE09801AST, CE11602AST, CE160001AST, CE90641AST, CS04741AST, CS14081AST, CS14181AST, LB15311AST, LB16101AST, LB16741AST, MW76021AST, TW109081AT	40 CFR Part 60, Subpart Ka	Tank is not used to store petroleum liquids. Therefore, Subpart Ka is not applicable.
GRPATANKD1	CE09541AST, CE09801AST, CE11602AST, CE160001AST, CE90641AST, CS04741AST, CS14081AST, CS14181AST, LB15311AST, LB16101AST, LB16741AST, MW76021AST, TW109081AT	40 CFR Part 60, Subpart Kb	This subpart does not apply to storage vessels storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa) (40 CFR 110b(b)). Tanks in this group are storing diesel fuel with a vapor pressure less than 3.5 kPa.
GRPATANKD2	AF20071AST, CE01711AST, CE01781AST, CE10521AST, CE20001AAS, CE20002AST, CE20004AST, CE50751AST, CE65781AST, CE65822AST, CE65861AST, CE65882AST, CE65921AST, CE65961AST, LB16231AST, LR50233AST, MW45591AST	40 CFR Part 60, Subpart K	Subpart K applies to vessels storing petroleum liquids with a capacity greater than or equal to 40,000. Tanks in this group are less than 40,000 gal.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPATANKD2	AF20071AST, CE01711AST, CE01781AST, CE10521AST, CE20001AAST, CE20002AST, CE20004AST, CE50751AST, CE65781AST, CE65822AST, CE65861AST, CE65882AST, CE65921AST, CE65961AST, LB16231AST, LR50233AST, MW45591AST	40 CFR Part 60, Subpart Ka	Subpart Ka applies to vessels storing petroleum liquids with a capacity greater than or equal to 40,000. Tanks in this group are less than 40,000 gal.
GRPATANKD2	AF20071AST, CE01711AST, CE01781AST, CE10521AST, CE20001AAST, CE20002AST, CE20004AST, CE50751AST, CE65781AST, CE65822AST, CE65861AST, CE65882AST, CE65921AST, CE65961AST, LB16231AST, LR50233AST, MW45591AST	40 CFR Part 60, Subpart Kb	Subpart Kb applies to tanks greater than or equal to 19,800 gallons. Tanks in this group are under 19,800 gallons.
GRPATANKG2	LR50231AST, LR50232AST	40 CFR Part 60, Subpart K	40 CFR 60 Subpart K applies to tanks greater than or equal to 40,000 gals which were constructed/modified between 6/11/73-5/19/78. These tanks were constructed after 5/19/78 and are greater than 40,000 gals. Therefore Subpart K is not applicable.
GRPATANKG2	LR50231AST, LR50232AST	40 CFR Part 60, Subpart Ka	40 CFR 60 Subpart Ka applies to tanks greater than or equal to 40,000 gals which were constructed/modified between 5/18/78-7/23/84. These tanks were constructed after 7/23/84 and are greater than 40,000 gals. Therefore Subpart Ka is not applicable.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPATANKG2	LR50231AST, LR50232AST	40 CFR Part 60, Subpart Kb	40 CFR 60 Subpart Kb applies to tanks greater than or equal to 40 cubic meters (10,567 gallons). These tanks are less than 10,567gals and are located at gasoline service station. Therefore Subpart Kb is not applicable.
GRPATANKJ2	LR111011AST, LR111021AST	40 CFR Part 60, Subpart K	40 CFR 60 Subpart K applies to tanks greater than or equal to 40,000 gals which were constructed/modified between 6/11/73-5/19/78. This tank was constructed after 5/19/78.
GRPATANKJ2	LR111011AST, LR111021AST	40 CFR Part 60, Subpart Ka	40 CFR 60 Subpart Ka applies to tanks greater than or equal to 40,000 gals which were constructed/modified between 5/18/78-7/24/84. These tanks were constructed after 7/23/84. Therefore Subpart Ka is not applicable.

New Source Review Authorization References

New Source Review Authorization References 158

New Source Review Authorization References by Emission Unit 160

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 7	Version No./Date: 05/05/1976
Number: 7	Version No./Date: 01/08/1980
Number: 7	Version No./Date: 01/29/1980
Number: 7	Version No./Date: 09/23/1982
Number: 7	Version No./Date: 03/15/1985
Number: 7	Version No./Date: 09/12/1989
Number: 7	Version No./Date: 05/04/1994
Number: 7	Version No./Date: 06/07/1996
Number: 14	Version No./Date: 11/05/1986
Number: 14	Version No./Date: 05/04/1994
Number: 14	Version No./Date: 10/04/1995
Number: 51	Version No./Date: 05/05/1976
Number: 51	Version No./Date: 08/30/1988
Number: 52	Version No./Date: 11/25/1985
Number: 63	Version No./Date: 05/05/1976
Number: 75	Version No./Date: 08/11/1989
Number: 75	Version No./Date: 09/12/1989
Number: 86	Version No./Date: 09/12/1989
Number: 86	Version No./Date: 05/04/1994
Number: 102	Version No./Date: 05/04/1994
Number: 103	Version No./Date: 06/07/1996
Number: 106.183	Version No./Date: 06/18/1997
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.231	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 03/14/1997
Number: 106.371	Version No./Date: 09/04/2000

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.392	Version No./Date: 03/14/1997
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.436	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 03/14/1997
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 03/14/1997
Number: 106.511	Version No./Date: 09/04/2000
Number: 107	Version No./Date: 07/20/1992

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
AF20071AST	BLDG. L02007, DIESEL GENERATOR TANK, 3,000 GALLONS	106.478/09/04/2000
AR08943AST	BLDG. KFA00894, VAULTED JET-A TANK, 6,000 GALLONS	106.478/09/04/2000
AST1443	BLDG 5023, VAULTED DIESEL TANK - 10,000 GAL	106.478/09/04/2000
CE01711AST	BLDG. K00171, DIESEL GENERATOR TANK, 1,100 GALLONS	106.478/09/04/2000
CE01781AST	BLDG. K00178, DIESEL GENERATOR TANK, 3,000 GALLONS	106.478/09/04/2000
CE08171AST	BLDG. 319, 12,000 GAL DIESEL AST	106.478/09/04/2000
CE09541AST	BLDG. KFA00954, DIESEL GENERATOR TANK, 683 GALLONS	106.478/09/04/2000
CE09801AST	BLDG. L00980, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000
CE10521AST	BLDG. L01052, DIESEL GENERATOR TANK, 2,000 GALLONS	106.478/09/04/2000
CE11602AST	BLDG 1160, VAULTED DIESEL TANK - 1,000 GAL	86/09/12/1989
CE11602AST	BLDG. L01160, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000
CE160001AST	BLDG. LAK16000, DIESEL GENERATOR TANK, 660 GALLONS	106.478/09/04/2000
CE20001AAST	BLDG. L02000, DIESEL GENERATOR TANK, 2,000 GALLONS	106.478/09/04/2000
CE20002AST	BLDG. L02000, DIESEL GENERATOR TANK, 3,500 GALLONS	106.478/09/04/2000
CE20004AST	BLDG. L02000, DIESEL GENERATOR TANK, 4,000 GALLONS	106.478/09/04/2000
CE50751AST	BLDG. L05075, DIESEL GENERATOR TANK, 1,700 GALLONS	106.478/09/04/2000
CE65781AST	BLDG. L06578, DIESEL GENERATOR TANK, 1,700 GALLONS	106.478/09/04/2000
CE65822AST	BLDG. L06582, DIESEL GENERATOR TANK, 2,260 GALLONS	106.478/09/04/2000
CE65861AST	BLDG. L06586, DIESEL GENERATOR TANK, 1,911 GALLONS	106.478/09/04/2000
CE65882AST	BLDG. L06588, DIESEL GENERATOR TANK, 1,600 GALLONS	106.478/09/04/2000
CE65921AST	BLDG. L06592, DIESEL GENERATOR TANK, 2,400 GALLONS	106.478/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
CE65961AST	BLDG. L06596, DIESEL GENERATOR TANK, 1,700 GALLONS	106.478/09/04/2000
CE90641AST	BLDG. L09064, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000
CS04741AST	BLDG. L00474, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000
CS04742AST	BLDG 474, VAULTED DIESEL TANK - 1,000 GAL	86/05/04/1994
CS14081AST	BLDG. L01408, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000
CS14181AST	BLDG. KFA01418, DIESEL GENERATOR TANK, 750 GALLONS	106.478/09/04/2000
DEGR601094	BLDG KFA00874, PNEUDRAULICS SHOP, 80 GAL IMMERSION	106.454/11/01/2001
DEGR674212	BLDG L05275, 80 GAL IMMERSION COLD SOLVENT DEGRSR	106.454/11/01/2001
DEGR704054	BLDG L00826, WHEEL AND TIRE SHOP, 80 GAL IMMERSION	106.454/11/01/2001
DEGR876	BLDG K00894, AF RESERVE AGE- AGITATING PART WASHER	107/07/20/1992
ECOM6586A	LACKLAND BOILER, BUILDING L06586, BOILER #01	106.183/09/04/2000
ECOM6586AA	LACKLAND BOILER, BUILDING L06586, BOILER #27	106.183/09/04/2000
ECOM6586AB	LACKLAND BOILER, BUILDING L06586, BOILER #28	106.183/09/04/2000
ECOM6586AC	LACKLAND BOILER, BUILDING L06586, BOILER #29	106.183/09/04/2000
ECOM6586AD	LACKLAND BOILER, BUILDING L06586, BOILER #30	106.183/09/04/2000
ECOM6586AE	LACKLAND BOILER, BUILDING L06586, BOILER #31	106.183/09/04/2000
ECOM6586AF	LACKLAND BOILER, BUILDING L06586, BOILER #32	106.183/09/04/2000
ECOM6586B	LACKLAND BOILER, BUILDING L06586, BOILER #02	106.183/09/04/2000
ECOM6586C	LACKLAND BOILER, BUILDING L06586, BOILER #03	106.183/09/04/2000
ECOM6586D	LACKLAND BOILER, BUILDING L06586, BOILER #04	106.183/09/04/2000
ECOM6586E	LACKLAND BOILER, BUILDING L06586, BOILER #05	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOM6586F	LACKLAND BOILER, BUILDING L06586, BOILER #06	106.183/09/04/2000
ECOM6586G	LACKLAND BOILER, BUILDING L06586, BOILER #07	106.183/09/04/2000
ECOM6586H	LACKLAND BOILER, BUILDING L06586, BOILER #08	106.183/09/04/2000
ECOM6586I	LACKLAND BOILER, BUILDING L06586, BOILER #09	106.183/09/04/2000
ECOM6586J	LACKLAND BOILER, BUILDING L06586, BOILER #10	106.183/09/04/2000
ECOM6586K	LACKLAND BOILER, BUILDING L06586, BOILER #11	106.183/09/04/2000
ECOM6586L	LACKLAND BOILER, BUILDING L06586, BOILER #12	106.183/09/04/2000
ECOM6586M	LACKLAND BOILER, BUILDING L06586, BOILER #13	106.183/09/04/2000
ECOM6586N	LACKLAND BOILER, BUILDING L06586, BOILER #14	106.183/09/04/2000
ECOM6586O	LACKLAND BOILER, BUILDING L06586, BOILER #15	106.183/09/04/2000
ECOM6586P	LACKLAND BOILER, BUILDING L06586, BOILER #16	106.183/09/04/2000
ECOM6586Q	LACKLAND BOILER, BUILDING L06586, BOILER #17	106.183/09/04/2000
ECOM6586R	LACKLAND BOILER, BUILDING L06586, BOILER #18	106.183/09/04/2000
ECOM6586S	LACKLAND BOILER, BUILDING L06586, BOILER #19	106.183/09/04/2000
ECOM6586T	LACKLAND BOILER, BUILDING L06586, BOILER #20	106.183/09/04/2000
ECOM6586U	LACKLAND BOILER, BUILDING L06586, BOILER #21	106.183/09/04/2000
ECOM6586V	LACKLAND BOILER, BUILDING L06586, BOILER #22	106.183/09/04/2000
ECOM6586W	LACKLAND BOILER, BUILDING L06586, BOILER #23	106.183/09/04/2000
ECOM6586X	LACKLAND BOILER, BUILDING L06586, BOILER #24	106.183/09/04/2000
ECOM6586Y	LACKLAND BOILER, BUILDING L06586, BOILER #25	106.183/09/04/2000
ECOM6586Z	LACKLAND BOILER, BUILDING L06586, BOILER #26	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOMK1531	KELLY ANNEX BOILER, BUILDING K01531	106.183/09/04/2000
ECOMK1610	KELLY ANNEX BOILER, BUILDING K01610	106.183/09/04/2000
ECOMK1612	KELLY ANNEX BOILER, BUILDING K01612	106.183/09/04/2000
ECOMK1614A	KELLY ANNEX BOILER, BUILDING K01614, BOILER #1	7/05/04/1994
ECOMK1614B	KELLY ANNEX BOILER, BUILDING K01614, BOILER #2	7/05/04/1994
ECOMK1621A	KELLY ANNEX BOILER, BUILDING K01621, BOILER #1	106.183/09/04/2000
ECOMK1621B	KELLY ANNEX BOILER, BUILDING K01621, BOILER #2	7/03/15/1985
ECOMK1623	KELLY ANNEX BOILER, BUILDING K01623	106.183/09/04/2000
ECOMK1650A	KELLY ANNEX BOILER, BUILDING K01650, BOILER #1	7/09/23/1982
ECOMK1650B	KELLY ANNEX BOILER, BUILDING K01650, BOILER #2	106.183/09/04/2000
ECOMK1674	KELLY ANNEX BOILER, BUILDING K01674	106.183/09/04/2000
ECOMK1676A	KELLY ANNEX BOILER, BUILDING K01676, BOILER #1	7/09/23/1982
ECOMK1676B	KELLY ANNEX BOILER, BUILDING K01676, BOILER #2	7/09/23/1982
ECOMK171A	KELLY ANNEX BOILER, BUILDING K00171, BOILER #1	106.183/09/04/2000
ECOMK171B	KELLY ANNEX BOILER, BUILDING K00171, BOILER #2	106.183/09/04/2000
ECOMK171C	KELLY ANNEX BOILER, BUILDING K00171, BOILER #3	7/09/12/1989
ECOMK171D	KELLY ANNEX BOILER, BUILDING K00171, BOILER #4	7/09/12/1989
ECOMK178	KELLY ANNEX BOILER, BUILDING K00178	106.183/09/04/2000
ECOMK210	KELLY ANNEX BOILER, BUILDING K00210	106.183/09/04/2000
ECOMK3030A	KELLY ANNEX BOILER, BUILDING K03030, BOILER #1	7/01/29/1980
ECOMK3030B	KELLY ANNEX BOILER, BUILDING K03030, BOILER #2	7/01/29/1980

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
EComL10050	LACKLAND BOILER, BUILDING L10050	106.183/09/04/2000
EComL10055	LACKLAND BOILER, BUILDING L10055	106.183/09/04/2000
EComL10060	LACKLAND BOILER, BUILDING L10060	7/09/12/1989
EComL10070A	LACKLAND BOILER, BUILDING L10070, BOILER #1	106.183/09/04/2000
EComL10070B	LACKLAND BOILER, BUILDING L10070, BOILER #2	106.183/09/04/2000
EComL10075A	LACKLAND BOILER, BUILDING L10075, BOILER #1	106.183/09/04/2000
EComL10075B	LACKLAND BOILER, BUILDING L10075, BOILER #2	106.183/09/04/2000
EComL10175	LACKLAND BOILER, BUILDING L10175	106.183/09/04/2000
EComL10203	LACKLAND BOILER, BUILDING L10203	106.183/09/04/2000
EComL10207	LACKLAND BOILER, BUILDING L10207	7/05/04/1994
EComL10215A	LACKLAND BOILER, BUILDING L10215, BOILER #1	7/09/12/1989
EComL10215B	LACKLAND BOILER, BUILDING L10215, BOILER #2	106.183/09/04/2000
EComL10251	LACKLAND BOILER, BUILDING L10251	106.183/09/04/2000
EComL10255	LACKLAND BOILER, BUILDING L10255	106.183/09/04/2000
EComL10261	LACKLAND BOILER, BUILDING L10261	106.183/09/04/2000
EComL10263	LACKLAND BOILER, BUILDING L10263	106.183/09/04/2000
EComL10265	LACKLAND BOILER, BUILDING L10265	106.183/09/04/2000
EComL1030	LACKLAND BOILER, BUILDING L01030	7/05/04/1994
EComL10330	LACKLAND BOILER, BUILDING L10330	7/06/07/1996
EComL10338	LACKLAND BOILER, BUILDING L10338	7/09/23/1982
EComL10390	LACKLAND BOILER, BUILDING L10390	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML10416A	LACKLAND BOILER, BUILDING L10416, BOILER #1	106.183/09/04/2000
ECOML10416B	LACKLAND BOILER, BUILDING L10416, BOILER #2	106.183/09/04/2000
ECOML10504A	LACKLAND BOILER, BUILDING L10504, BOILER #1	106.183/09/04/2000
ECOML10504B	LACKLAND BOILER, BUILDING L10504, BOILER #2	106.183/09/04/2000
ECOML10504C	LACKLAND BOILER, BUILDING L10504, BOILER #3	106.183/09/04/2000
ECOML10504D	LACKLAND BOILER, BUILDING L10504, BOILER #4	106.183/09/04/2000
ECOML10504E	LACKLAND BOILER, BUILDING L10504, BOILER #5	106.183/09/04/2000
ECOML10541	LACKLAND BOILER, BUILDING L10541	106.183/09/04/2000
ECOML10634	LACKLAND BOILER, BUILDING L10634	106.183/09/04/2000
ECOML10658A	LACKLAND BOILER, BUILDING L10658, BOILER #1	7/03/15/1985
ECOML10658B	LACKLAND BOILER, BUILDING L10658, BOILER #2	106.183/09/04/2000
ECOML10808	LACKLAND BOILER, BUILDING L10808	106.183/06/18/1997
ECOML10810	LACKLAND BOILER, BUILDING L10810	106.183/09/04/2000
ECOML10904A	LACKLAND BOILER, BUILDING L10904, BOILER #1	106.183/09/04/2000
ECOML10904B	LACKLAND BOILER, BUILDING L10904, BOILER #2	106.183/09/04/2000
ECOML10908	LACKLAND BOILER, BUILDING L10908	106.183/09/04/2000
ECOML1160	LACKLAND BOILER, BUILDING L01160	7/09/23/1982
ECOML1161	LACKLAND BOILER, BUILDING L01161	106.183/06/18/1997
ECOML1178	LACKLAND BOILER, BUILDING L01178	106.183/09/04/2000
ECOML1207	LACKLAND BOILER, BUILDING L01207	106.183/06/18/1997
ECOML1212A	LACKLAND BOILER, BUILDING L01212, BOILER #1	106.183/06/18/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML1212B	LACKLAND BOILER, BUILDING L01212, BOILER #2	106.183/06/18/1997
ECOML1212C	LACKLAND BOILER, BUILDING L01212, BOILER #3	106.183/06/18/1997
ECOML1215A	LACKLAND BOILER, BUILDING L01215, BOILER #1	106.183/09/04/2000
ECOML1215B	LACKLAND BOILER, BUILDING L01215, BOILER #2	106.183/09/04/2000
ECOML1215C	LACKLAND BOILER, BUILDING L01215, BOILER #3	106.183/09/04/2000
ECOML1215D	LACKLAND BOILER, BUILDING L01215, BOILER #4	106.183/09/04/2000
ECOML1215E	LACKLAND BOILER, BUILDING L01215, BOILER #5	106.183/09/04/2000
ECOML1217	LACKLAND BOILER, BUILDING L01217	106.183/09/04/2000
ECOML1219	LACKLAND BOILER, BUILDING L01219	106.183/09/04/2000
ECOML1249	LACKLAND BOILER, BUILDING L01249	7/09/12/1989
ECOML1250	LACKLAND BOILER, BUILDING L01250	7/05/04/1994
ECOML1285	LACKLAND BOILER, BUILDING L01285	106.183/09/04/2000
ECOML1288	LACKLAND BOILER, BUILDING L01288	106.183/09/04/2000
ECOML1415A	LACKLAND BOILER, BUILDING L01415, BOILER #1	106.183/09/04/2000
ECOML1415B	LACKLAND BOILER, BUILDING L01415, BOILER #2	106.183/09/04/2000
ECOML1415C	LACKLAND BOILER, BUILDING L01415, BOILER #3	106.183/09/04/2000
ECOML1423	LACKLAND BOILER, BUILDING L01423	106.183/09/04/2000
ECOML1528	LACKLAND BOILER, BUILDING L01528	106.183/09/04/2000
ECOML16000A	LACKLAND BOILER, BUILDING L16000, BOILER #1	106.183/09/04/2000
ECOML16000B	LACKLAND BOILER, BUILDING L16000, BOILER #2	106.183/09/04/2000
ECOML2000A	LACKLAND BOILER, BUILDING L02000, BOILER #1	7/06/07/1996

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML2000B	LACKLAND BOILER, BUILDING L02000, BOILER #2	106.183/06/18/1997
ECOML2028A	LACKLAND BOILER, BUILDING L02028, BOILER #1	7/05/04/1994
ECOML2028B	LACKLAND BOILER, BUILDING L02028, BOILER #2	7/05/04/1994
ECOML2041	LACKLAND BOILER, BUILDING L02041	106.183/06/18/1997
ECOML2049	LACKLAND BOILER, BUILDING L02049	106.183/06/18/1997
ECOML2067	LACKLAND BOILER, BUILDING L02067	106.183/09/04/2000
ECOML2081	LACKLAND BOILER, BUILDING L02081	7/05/04/1994
ECOML2088	LACKLAND BOILER, BUILDING L02088	7/01/29/1980
ECOML2167	LACKLAND BOILER, BUILDING L02167	106.183/09/04/2000
ECOML2169	LACKLAND BOILER, BUILDING L02169	7/06/07/1996
ECOML2300	LACKLAND BOILER, BUILDING L02300	106.183/09/04/2000
ECOML2418	LACKLAND BOILER, BUILDING L02418	7/06/07/1996
ECOML2443	LACKLAND BOILER, BUILDING L02443	106.183/09/04/2000
ECOML2484	LACKLAND BOILER, BUILDING L02484	106.183/09/04/2000
ECOML2490A	LACKLAND BOILER, BUILDING L02490, BOILER #1	106.183/09/04/2000
ECOML2490B	LACKLAND BOILER, BUILDING L02490, BOILER #2	106.183/09/04/2000
ECOML2506	LACKLAND BOILER, BUILDING L02506	7/05/05/1976
ECOML2901	LACKLAND BOILER, BUILDING L02901	7/09/12/1989
ECOML3220	LACKLAND BOILER, BUILDING L03220	7/05/04/1994
ECOML3352A	LACKLAND BOILER, BUILDING L03352, BOILER #1	106.183/09/04/2000
ECOML3352B	LACKLAND BOILER, BUILDING L03352, BOILER #2	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML3352C	LACKLAND BOILER, BUILDING L03352, BOILER #3	106.183/09/04/2000
ECOML3352D	LACKLAND BOILER, BUILDING L03352, BOILER #4	106.183/09/04/2000
ECOML3425A	LACKLAND BOILER, BUILDING L03425, BOILER #1	106.183/06/18/1997
ECOML3425B	LACKLAND BOILER, BUILDING L03425, BOILER #2	106.183/06/18/1997
ECOML3550	LACKLAND BOILER, BUILDING L03350	106.183/09/04/2000
ECOML3750A	LACKLAND BOILER, BUILDING L03750, BOILER #1	106.183/09/04/2000
ECOML3750B	LACKLAND BOILER, BUILDING L03750, BOILER #2	106.183/09/04/2000
ECOML3885	LACKLAND BOILER, BUILDING L03885	7/03/15/1985
ECOML4430A	LACKLAND BOILER, BUILDING L04430, BOILER #1	106.183/09/04/2000
ECOML4430B	LACKLAND BOILER, BUILDING L04430, BOILER #2	106.183/09/04/2000
ECOML4430C	LACKLAND BOILER, BUILDING L04430, BOILER #3	106.183/09/04/2000
ECOML4430D	LACKLAND BOILER, BUILDING L04430, BOILER #4	106.183/09/04/2000
ECOML4550	LACKLAND BOILER, BUILDING L04450	106.183/09/04/2000
ECOML4559A	LACKLAND BOILER, BUILDING L04459, BOILER #1	106.183/09/04/2000
ECOML4559B	LACKLAND BOILER, BUILDING L04459, BOILER #2	106.183/09/04/2000
ECOML4559C	LACKLAND BOILER, BUILDING L04459, BOILER #3	106.183/09/04/2000
ECOML4559D	LACKLAND BOILER, BUILDING L04459, BOILER #4	106.183/09/04/2000
ECOML4559E	LACKLAND BOILER, BUILDING L04459, BOILER #5	106.183/09/04/2000
ECOML4559F	LACKLAND BOILER, BUILDING L04459, BOILER #6	106.183/09/04/2000
ECOML4610	LACKLAND BOILER, BUILDING L04610	7/09/12/1989
ECOML5004	LACKLAND BOILER, BUILDING L05004	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML5045	LACKLAND BOILER, BUILDING L05045	106.183/09/04/2000
ECOML5100	LACKLAND BOILER, BUILDING L05100	7/09/12/1989
ECOML5160	LACKLAND BOILER, BUILDING L05160	7/09/12/1989
ECOML5200	LACKLAND BOILER, BUILDING L05200	7/03/15/1985
ECOML5275	LACKLAND BOILER, BUILDING L05275	106.183/09/04/2000
ECOML5277A	LACKLAND BOILER, BUILDING L05277, BOILER #1	7/03/15/1985
ECOML5277B	LACKLAND BOILER, BUILDING L05277, BOILER #2	7/05/04/1994
ECOML5311	LACKLAND BOILER, BUILDING L05311	106.183/09/04/2000
ECOML5432	LACKLAND BOILER, BUILDING L05432	7/09/12/1989
ECOML5497	LACKLAND BOILER, BUILDING L05497	106.183/09/04/2000
ECOML5506	LACKLAND BOILER, BUILDING L05506	7/09/12/1989
ECOML5570A	LACKLAND BOILER, BUILDING L05570, BOILER #1	7/09/12/1989
ECOML5570B	LACKLAND BOILER, BUILDING L05570, BOILER #2	7/09/12/1989
ECOML5595A	LACKLAND BOILER, BUILDING L05595, BOILER #1	106.183/06/18/1997
ECOML5595B	LACKLAND BOILER, BUILDING L05595, BOILER #2	7/09/12/1989
ECOML5616	LACKLAND BOILER, BUILDING L05616	106.183/06/18/1997
ECOML5725	LACKLAND BOILER, BUILDING L05725	7/09/23/1982
ECOML5747	LACKLAND BOILER, BUILDING L05747	7/09/23/1982
ECOML6114	LACKLAND BOILER, BUILDING L06114	7/09/12/1989
ECOML6300	LACKLAND BOILER, BUILDING L06300	106.183/09/04/2000
ECOML6330A	LACKLAND BOILER, BUILDING L06330, BOILER #1	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML6330B	LACKLAND BOILER, BUILDING L06330, BOILER #2	106.183/09/04/2000
ECOML6418A	LACKLAND BOILER, BUILDING L06418, BOILER #1	106.183/09/04/2000
ECOML6418B	LACKLAND BOILER, BUILDING L06418, BOILER #2	106.183/09/04/2000
ECOML6420	LACKLAND BOILER, BUILDING L06420	7/09/12/1989
ECOML6476	LACKLAND BOILER, BUILDING L06476	7/09/12/1989
ECOML6482	LACKLAND BOILER, BUILDING L06482	7/09/12/1989
ECOML6576	LACKLAND BOILER, BUILDING L06576	106.183/09/04/2000
ECOML6578A	LACKLAND BOILER, BUILDING L06578, BOILER #01	106.183/09/04/2000
ECOML6578B	LACKLAND BOILER, BUILDING L06578, BOILER #02	106.183/09/04/2000
ECOML6578C	LACKLAND BOILER, BUILDING L06578, BOILER #03	106.183/09/04/2000
ECOML6578D	LACKLAND BOILER, BUILDING L06578, BOILER #04	106.183/09/04/2000
ECOML6578E	LACKLAND BOILER, BUILDING L06578, BOILER #05	106.183/09/04/2000
ECOML6578F	LACKLAND BOILER, BUILDING L06578, BOILER #06	106.183/09/04/2000
ECOML6578G	LACKLAND BOILER, BUILDING L06578, BOILER #07	106.183/09/04/2000
ECOML6578H	LACKLAND BOILER, BUILDING L06578, BOILER #08	106.183/09/04/2000
ECOML6578I	LACKLAND BOILER, BUILDING L06578, BOILER #09	106.183/09/04/2000
ECOML6578J	LACKLAND BOILER, BUILDING L06578, BOILER #10	106.183/09/04/2000
ECOML6578K	LACKLAND BOILER, BUILDING L06578, BOILER #11	106.183/09/04/2000
ECOML6578L	LACKLAND BOILER, BUILDING L06578, BOILER #12	106.183/09/04/2000
ECOML6578M	LACKLAND BOILER, BUILDING L06578, BOILER #13	106.183/09/04/2000
ECOML6578O	LACKLAND BOILER, BUILDING L06578, BOILER #14	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML6582A	LACKLAND BOILER, BUILDING L06582, BOILER #1	106.183/09/04/2000
ECOML6582B	LACKLAND BOILER, BUILDING L06582, BOILER #2	106.183/09/04/2000
ECOML6582C	LACKLAND BOILER, BUILDING L06582, BOILER #3	106.183/09/04/2000
ECOML6588A	LACKLAND BOILER, BUILDING L06588, BOILER #01	106.183/09/04/2000
ECOML6588B	LACKLAND BOILER, BUILDING L06588, BOILER #02	106.183/09/04/2000
ECOML6588C	LACKLAND BOILER, BUILDING L06588, BOILER #03	106.183/09/04/2000
ECOML6588D	LACKLAND BOILER, BUILDING L06588, BOILER #04	106.183/09/04/2000
ECOML6588E	LACKLAND BOILER, BUILDING L06588, BOILER #05	106.183/09/04/2000
ECOML6588F	LACKLAND BOILER, BUILDING L06588, BOILER #06	106.183/09/04/2000
ECOML6588G	LACKLAND BOILER, BUILDING L06588, BOILER #07	106.183/09/04/2000
ECOML6588H	LACKLAND BOILER, BUILDING L06588, BOILER #08	106.183/09/04/2000
ECOML6588I	LACKLAND BOILER, BUILDING L06588, BOILER #09	106.183/09/04/2000
ECOML6588J	LACKLAND BOILER, BUILDING L06588, BOILER #10	106.183/09/04/2000
ECOML6588K	LACKLAND BOILER, BUILDING L06588, BOILER #11	106.183/09/04/2000
ECOML6588L	LACKLAND BOILER, BUILDING L06588, BOILER #12	106.183/09/04/2000
ECOML6588M	LACKLAND BOILER, BUILDING L06588, BOILER #13	106.183/09/04/2000
ECOML6588N	LACKLAND BOILER, BUILDING L06588, BOILER #14	106.183/09/04/2000
ECOML6588O	LACKLAND BOILER, BUILDING L06588, BOILER #15	106.183/09/04/2000
ECOML6588P	LACKLAND BOILER, BUILDING L06588, BOILER #16	106.183/09/04/2000
ECOML6592A	LACKLAND BOILER, BUILDING L06592, BOILER #01	106.183/09/04/2000
ECOML6592B	LACKLAND BOILER, BUILDING L06592, BOILER #02	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML6592C	LACKLAND BOILER, BUILDING L06592, BOILER #03	106.183/09/04/2000
ECOML6592D	LACKLAND BOILER, BUILDING L06592, BOILER #04	106.183/09/04/2000
ECOML6596A	LACKLAND BOILER, BUILDING L06596, BOILER #01	106.183/09/04/2000
ECOML6596B	LACKLAND BOILER, BUILDING L06596, BOILER #02	106.183/09/04/2000
ECOML6596C	LACKLAND BOILER, BUILDING L06596, BOILER #03	106.183/09/04/2000
ECOML6596D	LACKLAND BOILER, BUILDING L06596, BOILER #04	106.183/09/04/2000
ECOML6596E	LACKLAND BOILER, BUILDING L06596, BOILER #05	106.183/09/04/2000
ECOML6596F	LACKLAND BOILER, BUILDING L06596, BOILER #06	106.183/09/04/2000
ECOML6596G	LACKLAND BOILER, BUILDING L06596, BOILER #07	106.183/09/04/2000
ECOML6596H	LACKLAND BOILER, BUILDING L06596, BOILER #08	106.183/09/04/2000
ECOML6596I	LACKLAND BOILER, BUILDING L06596, BOILER #09	106.183/09/04/2000
ECOML6596J	LACKLAND BOILER, BUILDING L06596, BOILER #10	106.183/09/04/2000
ECOML6596K	LACKLAND BOILER, BUILDING L06596, BOILER #11	106.183/09/04/2000
ECOML6596L	LACKLAND BOILER, BUILDING L06596, BOILER #12	106.183/09/04/2000
ECOML6596M	LACKLAND BOILER, BUILDING L06596, BOILER #13	106.183/09/04/2000
ECOML6596N	LACKLAND BOILER, BUILDING L06596, BOILER #14	106.183/09/04/2000
ECOML6596O	LACKLAND BOILER, BUILDING L06596, BOILER #15	106.183/09/04/2000
ECOML6596P	LACKLAND BOILER, BUILDING L06596, BOILER #16	106.183/09/04/2000
ECOML6612	LACKLAND BOILER, BUILDING L06612	106.183/09/04/2000
ECOML6629	LACKLAND BOILER, BUILDING L06629	106.183/06/18/1997
ECOML7025	LACKLAND BOILER, BUILDING L07025	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML7037	LACKLAND BOILER, BUILDING L07037	106.183/09/04/2000
ECOML7065A	LACKLAND BOILER, BUILDING L07065, BOILER #1	7/09/12/1989
ECOML7065B	LACKLAND BOILER, BUILDING L07065, BOILER #2	7/09/12/1989
ECOML7080	LACKLAND BOILER, BUILDING L07080	106.183/09/04/2000
ECOML7214	LACKLAND BOILER, BUILDING L07214	7/06/07/1996
ECOML7241	LACKLAND BOILER, BUILDING L07241	106.183/06/18/1997
ECOML7243	LACKLAND BOILER, BUILDING L07243	7/05/04/1994
ECOML7246	LACKLAND BOILER, BUILDING L07246	7/09/23/1982
ECOML7342	LACKLAND BOILER, BUILDING L07342	106.183/09/04/2000
ECOML7346A	LACKLAND BOILER, BUILDING L07346, BOILER #1	7/01/29/1980
ECOML7346B	LACKLAND BOILER, BUILDING L07346, BOILER #2	7/05/04/1994
ECOML7353	LACKLAND BOILER, BUILDING L07353	7/09/12/1989
ECOML7355	LACKLAND BOILER, BUILDING L07355	7/09/12/1989
ECOML7356	LACKLAND BOILER, BUILDING L07356	106.183/06/18/1997
ECOML7357	LACKLAND BOILER, BUILDING L07357	7/09/12/1989
ECOML7358	LACKLAND BOILER, BUILDING L07358	7/09/12/1989
ECOML7360	LACKLAND BOILER, BUILDING L07360	7/09/12/1989
ECOML7362	LACKLAND BOILER, BUILDING L07362	106.183/09/04/2000
ECOML7364	LACKLAND BOILER, BUILDING L07364	106.183/09/04/2000
ECOML7366	LACKLAND BOILER, BUILDING L07366	106.183/09/04/2000
ECOML7368	LACKLAND BOILER, BUILDING L07368	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
EComL7429A	LACKLAND BOILER, BUILDING L07429, BOILER #1	7/09/12/1989
EComL7429B	LACKLAND BOILER, BUILDING L07429, BOILER #2	7/05/04/1994
EComL7435	LACKLAND BOILER, BUILDING L07435	106.183/09/04/2000
EComL7445	LACKLAND BOILER, BUILDING L07445	7/09/12/1989
EComL7450	LACKLAND BOILER, BUILDING L07450	7/05/04/1994
EComL7460A	LACKLAND BOILER, BUILDING L07460, BOILER #1	106.183/06/18/1997
EComL7460B	LACKLAND BOILER, BUILDING L07460, BOILER #2	106.183/06/18/1997
EComL7475	LACKLAND BOILER, BUILDING L07475	106.183/09/04/2000
EComL7481	LACKLAND BOILER, BUILDING L07481	106.183/09/04/2000
EComL7485	LACKLAND BOILER, BUILDING L07485	106.183/09/04/2000
EComL7487	LACKLAND BOILER, BUILDING L07487	106.183/09/04/2000
EComL7538	LACKLAND BOILER, BUILDING L07538	106.183/06/18/1997
EComL7602A	LACKLAND BOILER, BUILDING L07602, BOILER #1	106.183/09/04/2000
EComL7602B	LACKLAND BOILER, BUILDING L07602, BOILER #2	106.183/09/04/2000
EComL814	LACKLAND BOILER, BUILDING L00814	7/01/29/1980
EComL817	LACKLAND BOILER, BUILDING L00817	7/09/12/1989
EComL8206	LACKLAND BOILER, BUILDING L08206	106.183/09/04/2000
EComL8210	LACKLAND BOILER, BUILDING L08210	106.183/06/18/1997
EComL825	LACKLAND BOILER, BUILDING L00825	106.183/09/04/2000
EComL826	LACKLAND BOILER, BUILDING L00826	7/06/07/1996
EComL828	LACKLAND BOILER, BUILDING L00828	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML829A	LACKLAND BOILER, BUILDING L00829, BOILER #1	7/03/15/1985
ECOML829B	LACKLAND BOILER, BUILDING L00829, BOILER #2	7/03/15/1985
ECOML830	LACKLAND BOILER, BUILDING L00830	106.183/09/04/2000
ECOML832A	LACKLAND BOILER, BUILDING L00832, BOILER #1	106.183/09/04/2000
ECOML832B	LACKLAND BOILER, BUILDING L00832, BOILER #2	106.183/09/04/2000
ECOML8420A	LACKLAND BOILER, BUILDING L08420, BOILER #1	106.183/09/04/2000
ECOML8420B	LACKLAND BOILER, BUILDING L08420, BOILER #2	106.183/09/04/2000
ECOML874	LACKLAND BOILER, BUILDING L00874	106.183/09/04/2000
ECOML896	LACKLAND BOILER, BUILDING L00896	106.183/09/04/2000
ECOML898	LACKLAND BOILER, BUILDING L00898	7/03/15/1985
ECOML9020	LACKLAND BOILER, BUILDING L09020	7/09/12/1989
ECOML9028	LACKLAND BOILER, BUILDING L09028	106.183/06/18/1997
ECOML907	LACKLAND BOILER, BUILDING L00907	7/05/04/1994
ECOML908	LACKLAND BOILER, BUILDING L00908	106.183/09/04/2000
ECOML9085A	LACKLAND BOILER, BUILDING L09085, BOILER #1	7/05/04/1994
ECOML9085B	LACKLAND BOILER, BUILDING L09085, BOILER #2	7/05/04/1994
ECOML909	LACKLAND BOILER, BUILDING L00909	106.183/09/04/2000
ECOML910A	LACKLAND BOILER, BUILDING L00910, BOILER #1	7/05/04/1994
ECOML910B	LACKLAND BOILER, BUILDING L00910, BOILER #2	7/05/04/1994
ECOML9110A	LACKLAND BOILER, BUILDING L09110, BOILER #1	106.183/06/18/1997
ECOML9110B	LACKLAND BOILER, BUILDING L09110, BOILER #2	106.183/06/18/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOML9122A	LACKLAND BOILER, BUILDING L09122, BOILER #1	7/05/04/1994
ECOML9122B	LACKLAND BOILER, BUILDING L09122, BOILER #2	106.183/09/04/2000
ECOML921	LACKLAND BOILER, BUILDING L00921	106.183/09/04/2000
ECOML9210A	LACKLAND BOILER, BUILDING L09210, BOILER #1	106.183/06/18/1997
ECOML9210B	LACKLAND BOILER, BUILDING L09210, BOILER #2	106.183/06/18/1997
ECOML9225A	LACKLAND BOILER, BUILDING L09225, BOILER #1	7/09/12/1989
ECOML9225B	LACKLAND BOILER, BUILDING L09225, BOILER #2	7/09/12/1989
ECOML9310A	LACKLAND BOILER, BUILDING L09310, BOILER #1	7/09/12/1989
ECOML9310B	LACKLAND BOILER, BUILDING L09310, BOILER #2	7/09/12/1989
ECOML9410A	LACKLAND BOILER, BUILDING L09410, BOILER #1	7/09/12/1989
ECOML9410B	LACKLAND BOILER, BUILDING L09410, BOILER #2	7/09/12/1989
ECOML950A	LACKLAND BOILER, BUILDING L00950, BOILER #1	106.183/06/18/1997
ECOML950B	LACKLAND BOILER, BUILDING L00950, BOILER #2	106.183/09/04/2000
ECOML954	LACKLAND BOILER, BUILDING L00954	106.183/09/04/2000
ECOMM124A	MEDINA ANNEX BOILER, BUILDING M00124, BOILER #1	106.183/09/04/2000
ECOMM124B	MEDINA ANNEX BOILER, BUILDING M00124, BOILER #2	106.183/09/04/2000
ECOMM124C	MEDINA ANNEX BOILER, BUILDING M00124, BOILER #3	106.183/09/04/2000
ECOMM127	MEDINA ANNEX BOILER, BUILDING M00127	106.183/09/04/2000
ECOMM145	MEDINA ANNEX BOILER, BUILDING M00145	7/09/12/1989
ECOMM147A	MEDINA ANNEX BOILER, BUILDING M00147, BOILER #1	106.183/09/04/2000
ECOMM147B	MEDINA ANNEX BOILER, BUILDING M00147, BOILER #2	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ECOMM147C	MEDINA ANNEX BOILER, BUILDING M00147, BOILER #3	7/06/07/1996
ECOMM150A	MEDINA ANNEX BOILER, BUILDING M00150, BOILER #1	7/06/07/1996
ECOMM150B	MEDINA ANNEX BOILER, BUILDING M00150, BOILER #2	7/06/07/1996
ECOMM199A	MEDINA ANNEX BOILER, BUILDING M00199, BOILER #1	106.183/09/04/2000
ECOMM199B	MEDINA ANNEX BOILER, BUILDING M00199, BOILER #1	106.183/09/04/2000
ECOMM230A	MEDINA ANNEX BOILER, BUILDING M00230, BOILER #1	7/06/07/1996
ECOMM230B	MEDINA ANNEX BOILER, BUILDING M00230, BOILER #2	7/06/07/1996
ECOMM242	MEDINA ANNEX BOILER, BUILDING M00242	7/05/04/1994
ECOMM315	MEDINA ANNEX BOILER, BUILDING M00315	106.183/09/04/2000
ECOMM321	MEDINA ANNEX BOILER, BUILDING M00321	106.183/09/04/2000
ECOMM331	MEDINA ANNEX BOILER, BUILDING M00331	106.183/06/18/1997
FDSP600065	B5023, GASOLINE DISPENSING	14/05/04/1994
FDSP601907	BLDG LAK5023, FUEL DISPENSING, E-85	106.412/09/04/2000
FLD00211DSL	B210, DIESEL DISPENSING	14/05/04/1994
FLD00894JETA	B894, JP8 DISPENSING	14/11/05/1986
FLD02890DSL	B2890, DIESEL DISPENSING	14/10/04/1995
FLD651227	FILL GENERATOR TANKS FROM TRUCK	106.412/09/04/2000
FLD827	FUEL LOADING JET-A - BLDG KFA00980	106.473/09/04/2000
ICOM159032	BLDG. 2169, 300 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM159033	BLDG. 7602, 1073 BHP (800 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM162741	BLDG. 5075, 300 KW DIESEL GENERATOR	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ICOM162743	BLDG. 1443, KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600078	BLDG. 1030, 20 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600107	BLDG 5595, 100 KW DIESEL GENERATOR	106.511/03/14/1997
ICOM600110	BLDG. 1050, 505 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600130	BLDG. 6418, 275 BHP (205 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM600217	BLDG. 7532, 33 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600220	BLDG. L07535, 34 BHP (25 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM600226	BLDG. 7633, 201 BHP (150 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM600267	BLDG. 9064, 671 BHP (500 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM600292	BLDG. 9225, 30 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600376	BLDG. 4380, 350 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600377	BLDG. 4430, 250 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600406	BLDG. 1418, 50 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM600407	BLDG. L00474, 27 BHP (20 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM600408	BLDG. 1408, 35 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM601059	BLDG. 1207, 174 BHP (130 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601061	BLDG. 2000-1, 1000 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM601062	BLDG. 2167, 402 BHP (300 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601063	BLDG. 2096, 33 BHP (24.5 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601065	BLDG. L0817, 67 BHP (50 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601067	BLDG. 935, 75 KW DIESEL GENERATOR	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ICOM601068	BLDG. 828, 335 BHP (250 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601077	BLDG. 954, 268 BHP (200 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601079	BLDG. 3425, 201 BHP (150 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM601926	BLDG. 5275, 100 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM624	BLDG. 3750, 168 BHP (125 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM649879	BLDG. 5160, 30 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649880	BLDG. 6676, 30 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649881	BLDG. 171 (ACTIVE BARRIERS), 20 KW DIESEL	106.511/09/04/2000
ICOM649883	BLDG. 3746, 100 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649884	BLDG. 8751, 180 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649888	BLDG. 10908, 300 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649889	BLDG. 1204, 350 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649890	BLDG. 6578, 300 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649891	BLDG. 6582, 400 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649893	BLDG. 1052-A, 650 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649894	BLDG. 1052-B, 650 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649895	BLDG. 16000, 750 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649896	BLDG. 2007, 1000 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649897	BLDG. 2000-2, 1250 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649898	BLDG. 2000-4, 1500 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM649899	BLDG. L01151, 130 HP EMERGENCY DIESEL GENERATOR	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ICOM658360	BLDG. 6586, 494 BHP (368 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM690	BLDG. 3106, 350 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM695896	BLDG. 2057, 34 BHP (25 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM703671	BLDG. 1623, 402 BHP (300 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM703673	BLDG. 3352, 335 BHP (250 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM703681	BLDG. L04429, 54 BHP (40 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704087	BLDG. 6596, 469 BHP (350 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704092	BLDG. 7065, 42 BHP (31 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704095	BLDG. K00171, 2012 BHP (1500 KW) EMERG. DIESEL GEN	106.511/09/04/2000
ICOM704096	BLDG. 171, 181 BHP (135 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704097	BLDG. 171, 241 BHP (180 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704099	BLDG. 171, 27 BPH (20 KW) ACTIVE BARRIER GEN	106.511/09/04/2000
ICOM704110	BLDG. K01674, 516 BHP (385 KW) LEASEBACK GEN	106.511/09/04/2000
ICOM704112	BLDG. K01675, 201 BHP (150 KW) EMERG DIESEL GEN	106.511/09/04/2000
ICOM704113	BLDG. K01531, 335 BHP (250 KW) EMERG DIESEL GEN	106.511/09/04/2000
ICOM704115	BLDG. K00178, 1207 BHP (900 KW) EMERGENCY DIESEL G	106.511/09/04/2000
ICOM704116	BLDG. K00178, 1006 BHP (750 KW) EMERG DIESEL GEN	106.511/09/04/2000
ICOM704122	BLDG. K00179, 1194 BHP (890 KW) EMERG DIESEL GEN	106.511/09/04/2000
ICOM704227	BLDG L06588, 402 BHP (300 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM704230	BLDG L06592, 536 BHP (400 KW) EMERGENCY DIESEL GEN	106.511/09/04/2000
ICOM706503	BLDG L04559, 1073 BHP, CEP EMERG DIESEL GEN #1	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
ICOM706504	BLDG L04559, 1073 BHP, EMERG DIESEL GEN #2	106.511/09/04/2000
ICOM706505	BLDG L04559, 1073 BHP, EMERG DIESEL GEN #3	106.511/09/04/2000
ICOM712	BLDG. 2058, 800 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM717028	BLDG 980, 1072 HP DIESEL EMERGENCY GENERATOR	106.511/09/04/2000
ICOM723510	BLDG 2000, 2200 HP DIESEL EMERGENCY GENERATOR	106.511/09/04/2000
ICOM735974	BLDG K00394, 51 HP EMERGENCY DIESEL GENERATOR	106.511/09/04/2000
ICOM790	BLDG. 1610, 350 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM798	BLDG. 2484, 20 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM813278	BLDG L07466, 86 HP EMERGENCY DIESEL GENERATOR	106.511/09/04/2000
ICOM814	BLDG. 1160, 80 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM815748	BLDG PRT00171, 152 HP DIESEL EMERGENCY GENERATOR	106.511/09/04/2000
ICOM904	BLDG. 826, 450 KW DIESEL GENERATOR	106.511/09/04/2000
ICOM929	BLDG. 2325, 20 KW DIESEL GENERATOR	106.511/09/04/2000
LB15311AST	BLDG 1531, VAULTED DIESEL TANK - 1,000 GAL	86/09/12/1989
LB15311AST	BLDG. PRT01531, LEASEBACK DIESEL GENERATOR TANK	106.478/09/04/2000
LB16101AST	BLDG. PRT01610, LEASEBACK DIESEL GENERATOR TANK	106.478/09/04/2000
LB16231AST	BLDG. K01623, LEASEBACK DIESEL GENERATOR TANK	106.478/09/04/2000
LB16741AST	BLDG 1674, VAULTED DIESEL TANK - 1,000 GAL	52/11/25/1985
LB16741AST	BLDG. PRT01674, LEASEBACK DIESEL GENERATOR TANK	106.478/09/04/2000
LR111011AST	BLDG 980, JP-8 TANK - 1,050,000 GAL	51/08/30/1988
LR111021AST	BLDG 980, JP-8 TANK - 1,050,000 GAL	51/08/30/1988

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
LR50231AST	BLDG. 5023, 12,000 GAL GASOLINE E-85 AST	106.478/09/04/2000
LR50232AST	BLDG. L05023, GASOLINE TANK, 12,000 GALLONS	106.478/09/04/2000
LR50233AST	BLDG. L05023, DIESEL TANK, 10,000 GALLONS	106.478/09/04/2000
MW45591AST	BLDG. L04559, DIESEL GENERATOR TANK, 10,000 GALLON	106.478/09/04/2000
MW76021AST	BLDG. LAK07602, DIESEL GENERATOR TANK, 850 GALLONS	106.478/09/04/2000
SURF600396	L05008, LRS AUTO PAINT BOOTH, SE#11749	75/08/11/1989 [11749]
SURF601064	L00829, OUTSIDE AIRCRAFT TOUCH UP SE#56777	106.433/09/04/2000
SURF656672	L07538, IAAFA PAINT BOOTH, PBR#95306	106.433/09/04/2000 [95306]
SURF714	L02058, PAINT BOOTH CCSD, PBR#124419	106.433/09/04/2000 [124419]
SURF892	L00829, SURFACE COATING BOOTH #1 SE#21103	75/08/11/1989 [21103]
TW109081AT	BLDG. L10908, DIESEL GENERATOR TANK, 1,000 GALLONS	106.478/09/04/2000

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Schedules

Compliance Schedule..... 184

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	SOP Index No.	Pollutant	Applicable Requirement	
			Citation	Text Description
WOOD600091		PM	§106.231/09/ 04/2000	Waste materials shall be stored and disposed of properly.
2. Compliance Status Assessment Method and Records Location				
Compliance Status Assessment Method			Location of Records/Documentation	
Citation	Text Description			
30 TAC 106.231 (2)	Waste material shall be stored and disposed of properly.		The Air Program and Information Management System.	
3. Non-compliance Situation Description				
Waste materials are not being disposed of properly.				
4. Corrective Action Plan Description				
Informed shop personnel that filtration and waste collection system must be attached to avoid visible emissions and release of particulate matter. Reaching out to manufacturer to acquire coupler to attach control device to collector.				
5. List of Activities/Milestones to Implement the Corrective Action Plan				
1	Manufacturer contacted regarding coupler acquisition.			
6. Previously Submitted Compliance Plan(s)		Type of Action		Date Submitted
		N/A		N/A
7. Progress Report Submission Schedule		Progress reports will be submitted semiannually as part of the semiannual deviation report until corrective actions are complete or compliance is achieved.		

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	SOP Index No.	Pollutant	Applicable Requirement	
			Citation	Text Description
ICOM649897, ICOM904	63ZZZZ	HAP	§63.6625(i)	If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of table 2c to this subpart or in items 1 or 4 of table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil and filter change requirement in tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil and filter in table 2c or 2d to this subpart.
2. Compliance Status Assessment Method and Records Location				
Compliance Status Assessment Method			Location of Records/Documentation	
Citation	Text Description			
Table 9.a.ii	Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.			
3. Non-compliance Situation Description				
Oil change/Oil analysis exceeded the 1 year + 30-day requirement.				
4. Corrective Action Plan Description				
Working with the power production shop to inform them of the updated “annual definition in 63ZZZZ and requesting the engine oil is analyzed and/or changed as required by the regulation.				
5. List of Activities/Milestones to Implement the Corrective Action Plan				
1	Collect oil samples, conduct oil analysis, review results, document/file results, ensure units with negative results receive an oil change, ensure units are scheduled to receive next analysis/oil change within 1 year +30-day requirement.			
6. Previously Submitted Compliance Plan(s)		Type of Action		Date Submitted
		N/A		N/A
7. Progress Report Submission Schedule		Progress reports will be submitted semiannually as part of the semiannual deviation report until corrective actions are complete or compliance is achieved.		

Alternative Requirement

Alternative Requirement..... 187

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 12, 2018

MS. KATHERINE MEHAFFEY
GS-13 USAF AFMC AFCEC/CZOW
ISS AIR PROGRAM MANAGER
1651 5TH ST WEST
JBSA RANDOLPH, TX 78150
katherine.mehaffey@us.af.mil

Re: Alternative Method of Compliance (AMOC) No. 104
Lackland Air Force Base
Alternative Opacity Monitoring under Chapter 111
Regulated Entity Number: RN100542729
Customer Reference Number: CN600919401
Associated Permit Numbers: 10672, 11749, 12742, 16659, 18498, 21103, 21594, 21872, 29667,
31428, 32364, 46629, 49058, 52718, 55944, 56725, 56726, 56777, 95306, 124419, 151815, and
O1393

Dear Ms. Mehaffey:

This correspondence is in response to the US Department of the Air Force JBSA Lackland's (Lackland's) request to use U.S. Environmental Protection Agency (EPA) Alternate Method 082 (ALT-082) instead of the EPA Reference Method 9 (RM 9) as Alternative Opacity Monitoring under 30 TAC Chapter 111 and use an AMOC to comply with § 111.111(a)(3).

We understand that Lackland is requesting ALT-082 because it uses a continuous video system and minimizes human error. This request is based on the U.S. EPA's published determination on the equivalency of ASTM D7520, Standard Test Method for Determining the Opacity of a Plume in the Outdoor Ambient Atmosphere in 2012. The determination was subsequently published in the Federal Register in 2013 and is notated as ALT-082 by the EPA Air Emission Measurement Center, Broadly Applicable Approved Alternate Test Methods (www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods#ATLs). This approval established the equivalency of ASTM D7520 for any reference to RM 9 in 40 CFR 60, 61, or 63 regulations. Since the ASTM D7520 is used to comply with the most stringent of federal standards, it meets both the expectations for periodic monitoring (PM) and continuous assurance monitoring (CAM) for both federal and state compliance purposes.

The Texas Commission on Environmental Quality (TCEQ) Executive Director has made a final decision to approve your AMOC request. The TCEQ has been delegated authority to enforce the above cited standards and is authorized to approve this AMOC. You are reminded that approval of any AMOC shall not abrogate the Executive Director or Administrator's authority under the Act or in any way prohibit later canceling the AMOC. By copy of this letter we are informing the EPA Region 6, of this decision as required by TCEQ's delegation of authority.

This AMOC approval may supersede certain requirements or representations in Permit by Rule (PBR) Registration Nos. 11749, 16659, 18498, 21103, 21594, 52718, 56777, 95306, 124419, and 151815. We also understand that this AMOC may apply to PBR Registration Nos. 49058 and 29667, which are to be revised and updated for current facilities and operations. To ensure effective and consistent enforceability, we request that Lackland incorporate this AMOC into the PBR representations through submittal of either a revision (via PI-7) or certification (APD-CERT) to the registrations no later than 90

P.O. Box 13087 · Austin, Texas 78711-3087 · 512-239-1000 · tceq.texas.gov

How is our customer service? tceq.texas.gov/customersurvey

printed on recycled paper

Renewal - Draft Page 187

September 12, 2018
Page 2
Ms. Kathrine Mehaffey

Re: Permit Numbers: 10672, 11749, 12742, 16659, 18498, 21103, 21594, 21872, 29667, 31428, 32364, 46629, 49058, 52718, 55944, 56725, 56726, 56777, 95306, 124419, 151815, and O1393

days after this approval. Additional facilities are covered by this AMOC which have not been registered, but instead claimed permits by rule. These include:

Description	Vents 20%, Structures & Sources 30%	PBR claimed
Misc Chemicals	In a building	106.263
Fiberglass	In a building, has a vent	106.261
Degreasers (cleaning-chemical) - Basewide	In a building	106.454
ECOM - Basewide	In a building, has a vent	106.183
Fire Training	Outside	111.205
Fuel Cell Maintenance - B829 on C5s	In a building	106.263
Fuel Dispensing/Loading - Basewide	Outside	106.412, 106.472, 106.473
ICOM (emergency generators) - Basewide	Outside	106.511
OBOD	Outside	106.261
General Welding operations - Basewide	In a building, has a vent	106.227
Cooling Towers - Basewide	Outside	106.371
General Woodworking operations - Basewide	In a building with a sawdust collector	106.231

This letter also acknowledges that PBR Registration Nos. 10672, 12742, 21872, 31428, 32364, 46629, 55944, 56725, and 52726 will be voided with this action.

This approval may also change applicable requirements for the site, which are identified in the site operating permit (SOP) O1393. The TCEQ recommends the submittal of a SOP administrative revision if any changes are necessary. Changes meeting the criteria for an administrative revision can be operated before issuance of the revision if a complete application is submitted to the TCEQ and this information is maintained with the SOP records at the site.

If you need further information or have any questions, please contact Ms. Anne Inman, P.E. at (512) 239-1276 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087. This action is taken under authority delegated by the Executive Director of the TCEQ.

Sincerely,



Michael Wilson, P.E., Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

cc: Mr Francisco Dieck, Chief of Environmental Compliance United States Department of The Air Force, JB SA Lackland
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection Agency, Region 6, Dallas
Air Section Manager, Region 13 - San Antonio
Beryl Thatcher, Manager, Mechanical/Coatings Section, Air Permits Division, OA: MC-163
Mark Meyer, Manager, Rules Registration Section, Air Permits Division, OA: MC-163
Jesse Chacon, Manager, Operating Permits Section, Air Permits Division, OA: MC-163

Project Number: 284448

Appendix A

Acronym List 190

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound