

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
ET Gathering & Processing LLC

AUTHORIZING THE OPERATION OF
Red Bluff Gas Processing Plant
Pipeline Transportation of Natural Gas

LOCATED AT
Reeves County, Texas
Latitude 31° 47' 59" Longitude 103° 55' 47"
Regulated Entity Number: RN106173644

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O4858 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	6
New Source Review Authorization Requirements	7
Compliance Requirements.....	7
Protection of Stratospheric Ozone	8
Permit Location	8
Permit Shield (30 TAC § 122.148)	8
Attachments	10
Applicable Requirements Summary.....	11
Additional Monitoring Requirements	23
Permit Shield.....	25
New Source Review Authorization References	27
Appendix A.....	31
Acronym List	32

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subpart HH or ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113,

Subchapter C, § 113.390 or 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that

does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer’s eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is

determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (4) Compliance Certification:
- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- C. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- D. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
- (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)

4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)

- B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
 6. For oil and natural gas production facilities as specified in 40 CFR Part 63, Subpart HH, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.390 incorporated by reference):
 - A. Title 40 CFR § 63.760(a)(1)(i) - (iii) (relating to Applicability and Designation of Affected Source)
 - B. Title 40 CFR § 63.775(d)(9) (relating to Reporting Requirements)
 7. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

8. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

9. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
10. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
11. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
12. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the Air Quality Standard Permit for Oil and Gas Handling and Production Facilities

Compliance Requirements

13. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
14. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:

- (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

15. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Permit Location

16. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

17. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit

shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 12

Applicable Requirements Summary 14

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
AREAFUG	FUGITIVE EMISSION UNITS	N/A	600000b	40 CFR Part 60, Subpart 0000b	No changing attributes.
AREAFUG2	FUGITIVE EMISSION UNITS	N/A	600000b	40 CFR Part 60, Subpart 0000b	No changing attributes.
DEHY	GLYCOL DEHYDRATION	N/A	63HH	40 CFR Part 63, Subpart HH	No changing attributes.
DEHY1	GLYCOL DEHYDRATION	N/A	63HH	40 CFR Part 63, Subpart HH	No changing attributes.
DEHY2	GLYCOL DEHYDRATION	N/A	63HH	40 CFR Part 63, Subpart HH	No changing attributes.
FLARE1	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FLARE1	FLARES	N/A	63A	40 CFR Part 63, Subpart A	No changing attributes.
FLARE2	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FLARE3A	FLARES	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPCOMP	FUGITIVE EMISSION UNITS	COMP 10, COMP 11, COMP 12, COMP 9	600000a	40 CFR Part 60, Subpart 0000a	No changing attributes.
GRPENG	SRIC ENGINES	ENGINE 6, ENGINE 7, ENGINE 8	60JJJJ-1	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GRPENG	SRIC ENGINES	ENGINE 6, ENGINE 7, ENGINE 8	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPENG2	SRIC ENGINES	ENGINE 10, ENGINE 11, ENGINE 12, ENGINE 9	60JJJJ-2	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GRPENG2	SRIC ENGINES	ENGINE 10, ENGINE 11, ENGINE 12,	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		ENGINE 9			
GRPHTR1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	HTR7, HTR8, HTR9	60Dc	40 CFR Part 60, Subpart Dc	No changing attributes.
PROAMINE	GAS SWEETENING/SULFUR RECOVERY UNITS	N/A	600000	40 CFR Part 60, Subpart 0000	No changing attributes.
PROAMINE2	GAS SWEETENING/SULFUR RECOVERY UNITS	N/A	600000a	40 CFR Part 60, Subpart 0000a	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
AREAFUG	EU	600000b	§111 Pollutant	40 CFR Part 60, Subpart 0000b	§ 60.5365b The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 60, Subpart 0000b
AREAFUG2	EU	600000b	§111 Pollutant	40 CFR Part 60, Subpart 0000b	§ 60.5365b The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 60, Subpart 0000b	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 60, Subpart 0000b
DEHY	EU	63HH	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.11(b) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(f)(1) § 63.771(f)(1)(iii) § 63.771(f)(2) § 63.771(f)(2)(i) § 63.771(f)(2)(ii) [G]§ 63.773(c)(3) § 63.773(c)(4)	The owner or operator must limit BTEX emissions from each new small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 2 of this section. The limits determined using Equation 2 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	[G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(2) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(ii) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(C) § 63.773(d)(3)(iii) § 63.773(d)(4) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(iv) § 63.773(d)(7)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(ii)(A) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi)	§ 63.764(b) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(11) [G]§ 63.775(d)(2) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2) § 63.775(e)(2)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	§ 63.775(e)(2)(ii) § 63.775(e)(2)(ii)(A) § 63.775(e)(2)(ii)(D) § 63.775(e)(2)(iii) [G]§ 63.775(e)(2)(vii) § 63.775(e)(2)(viii) § 63.775(e)(2)(x) § 63.775(e)(2)(xi) [G]§ 63.775(f) § 63.775(g)(1)
DEHY1	EU	63HH	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.11(b) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(f)(1) § 63.771(f)(1)(iii) § 63.771(f)(2) § 63.771(f)(2)(i) § 63.771(f)(2)(ii) [G]§ 63.773(c)(3) § 63.773(c)(4)	The owner or operator must limit BTEX emissions from each new small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 2 of this section. The limits determined using Equation 2 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	[G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(2) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(ii) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(C) § 63.773(d)(3)(iii) § 63.773(d)(4) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(iv) § 63.773(d)(7)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(ii)(A) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi) § 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	§ 63.764(b) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(11) [G]§ 63.775(d)(2) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2) § 63.775(e)(2)(i) § 63.775(e)(2)(ii) § 63.775(e)(2)(ii)(A) § 63.775(e)(2)(ii)(D) § 63.775(e)(2)(iii) [G]§ 63.775(e)(2)(vii) § 63.775(e)(2)(viii) § 63.775(e)(2)(x) § 63.775(e)(2)(xi) [G]§ 63.775(f) § 63.775(g)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DEHY2	EU	63HH	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.765(b)(1)(iii) § 63.11(b) § 63.764(a) § 63.764(j) § 63.765(b)(1)(iii)(A) § 63.771(c)(1) § 63.771(c)(2) § 63.771(f)(1) § 63.771(f)(1)(iii) § 63.771(f)(2) § 63.771(f)(2)(i) § 63.771(f)(2)(ii) [G]§ 63.773(c)(3) § 63.773(c)(4)	The owner or operator must limit BTEX emissions from each new small glycol dehydration unit process vent, as defined in §63.761, to the limit determined in Equation 2 of this section. The limits determined using Equation 2 must be met in accordance with one of the alternatives specified in paragraphs (b)(1)(iii)(A) through (D) of this section.	[G]§ 63.772(c) § 63.772(d)(1) § 63.772(e) [G]§ 63.772(e)(2) § 63.772(e)(4)(ii) [G]§ 63.772(f) [G]§ 63.773(c)(2)(ii) [G]§ 63.773(d)(1) § 63.773(d)(3) § 63.773(d)(3)(i)(C) § 63.773(d)(3)(iii) § 63.773(d)(4) § 63.773(d)(6) § 63.773(d)(6)(i) § 63.773(d)(6)(iv) § 63.773(d)(7)	§ 63.771(e)(1) § 63.771(e)(2) § 63.771(e)(3)(i) [G]§ 63.774(b)(1) § 63.774(b)(10) § 63.774(b)(11) § 63.774(b)(2) [G]§ 63.774(b)(3) § 63.774(b)(4) § 63.774(b)(4)(i) § 63.774(b)(4)(ii)(A) § 63.774(b)(7) § 63.774(b)(7)(i) § 63.774(b)(7)(ii) § 63.774(b)(7)(iii) § 63.774(b)(7)(iv) § 63.774(b)(7)(v) § 63.774(b)(7)(vi) § 63.774(b)(7)(vii) § 63.774(b)(7)(viii) § 63.774(g)	§ 63.764(b) [G]§ 63.773(c)(2)(ii) [G]§ 63.775(b)(1) § 63.775(b)(2) § 63.775(b)(3) § 63.775(b)(4) § 63.775(b)(5) § 63.775(b)(6) § 63.775(d) § 63.775(d)(10) § 63.775(d)(11) [G]§ 63.775(d)(2) § 63.775(d)(6) § 63.775(d)(7) § 63.775(e) § 63.775(e)(1) § 63.775(e)(2) § 63.775(e)(2)(i) § 63.775(e)(2)(ii) § 63.775(e)(2)(ii)(A) § 63.775(e)(2)(ii)(D) § 63.775(e)(2)(iii) [G]§ 63.775(e)(2)(vii) § 63.775(e)(2)(viii) § 63.775(e)(2)(x) § 63.775(e)(2)(xi) [G]§ 63.775(f) § 63.775(g)(1)
FLARE1	CD	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FLARE1	CD	63A	Opacity	40 CFR Part 63,	§ 63.11(b)(4)	Flares shall be designed	§ 63.11(b)(4)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Subpart A	§ 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(5) § 63.11(b)(7)(i)		
FLARE2	CD	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FLARE3A	CD	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A) § 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from an acid gas flare shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPCOMP	EU	600000a	CH4 & VOC	40 CFR Part 60, Subpart 0000a	§ 60.5385a(a)(1) § 60.5370a(a) § 60.5370a(b) § 60.5385a § 60.5385a(a) § 60.5385a(b) § 60.5385a(c) § 60.5385a(d) § 60.5410a § 60.5415a(c) § 60.5415a(c)(2) § 60.5415a(c)(3)	For each reciprocating compressor, the owner or operator must reduce GHG (in the form of a limitation on emissions of methane) and VOC emissions by replacing the rod packing on or before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored	§ 60.5410a(c)(1) § 60.5415a(c)(1)	§ 60.5410a(c)(4) § 60.5420a(c) [G]§ 60.5420a(c)(3)	§ 60.5410a(c)(3) § 60.5420a(a) § 60.5420a(a)(1) § 60.5420a(b) [G]§ 60.5420a(b)(1) [G]§ 60.5420a(b)(11) [G]§ 60.5420a(b)(13) [G]§ 60.5420a(b)(14) [G]§ 60.5420a(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						beginning upon initial startup of your reciprocating compressor affected facility, August 2, 2016, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.			
GRPENG	EU	60JJJJ-1	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency natural gas engines with a maximum engine power greater than or equal to 500 HP and were manufactured on or after 07/01/2007 and before 07/01/2010 must comply with a CO emission limit of 4.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	[G]§ 60.4245(c) § 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG	EU	60JJJJ-1	NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency natural gas engines with a maximum engine power greater than or equal to 500 HP and were manufactured on or after 07/01/2007 and before 07/01/2010 must comply with a NO _x emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	[G]§ 60.4245(c) § 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG	EU	60JJJJ-1	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii)	Owners and operators of stationary non-emergency natural gas engines with a maximum engine power greater than or equal to	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b)	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1)	[G]§ 60.4245(c) § 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4243(e) § 60.4243(g)	500 HP and were manufactured on or after 07/01/2007 and before 07/01/2010 must comply with a VOC emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4244(c) § 60.4244(f) § 60.4244(g)	§ 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	[G]§ 60.4245(i)
GRPENG	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
GRPENG2	EU	60JJJJ-2	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency natural gas engines with a maximum engine power greater than or equal to 500 HP and were manufactured on or after 07/01/2010 must comply with a CO emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	[G]§ 60.4245(c) § 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG2	EU	60JJJJ-2	NO _x	40 CFR Part 60,	§ 60.4233(e)-Table 1	Owners and operators of	§ 60.4243(b)(2)	§ 60.4243(b)(2)	[G]§ 60.4245(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Subpart JJJJ	§ 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4243(g)	stationary non-emergency natural gas engines with a maximum engine power greater than or equal to 500 HP and were manufactured on or after 07/01/2010 must comply with a NOx emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	§ 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG2	EU	60JJJJ-2	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency natural gas engines with a maximum engine power greater than or equal to 500 HP and were manufactured on or after 07/01/2010 must comply with a VOC emission limit of 0.7 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(f) § 60.4244(g)	§ 60.4243(b)(2) § 60.4243(b)(2)(ii) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	[G]§ 60.4245(c) § 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG2	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						such engines under this part.			
GRPHTR1	EU	60Dc	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
GRPHTR1	EU	60Dc	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
GRPHTR1	EU	60Dc	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
PROAMINE	EU	600000	SO ₂	40 CFR Part 60, Subpart OOOO	§ 60.5365(g)(3)	Facilities that have a design capacity less than 2 long tons per day (LT/D) of hydrogen sulfide (H ₂ S) in the acid gas (expressed as sulfur) are required to comply with recordkeeping and reporting requirements specified in §60.5423(c) but are not required to	None	§ 60.5423(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						comply with §§60.5405 through 60.5407 and §§60.5410(g) and 60.5415(g) of this subpart.			
PROAMINE 2	EU	600000a	SO ₂	40 CFR Part 60, Subpart OOOOa	§ 60.5365a(g)(3)	Owners or operators of facilities that have a design capacity less than 2 long tons per day (LT/D) of hydrogen sulfide (H ₂ S) in the acid gas (expressed as sulfur) are required to comply with recordkeeping and reporting requirements specified in §60.5423a(c), but are not required to comply with §§60.5405a through 60.5407a and §§60.5410a(g) and 60.5415a(g).	None	§ 60.5423a(c)	§ 60.5420a(a) § 60.5420a(a)(1)

Additional Monitoring Requirements

Periodic Monitoring Summary 24

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: FLARE3A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(4)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per week	
Averaging Period: N/A	
Deviation Limit: If visible emissions are observed, the permit holder shall report a deviation.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Permit Shield

Permit Shield 26

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
AREAFUG	N/A	40 CFR Part 60, Subpart OOOOa	Constructed/modified/reconstructed after December 6, 2022.
AREAFUG2	N/A	40 CFR Part 60, Subpart OOOOa	Constructed/modified/reconstructed after December 6, 2022.

New Source Review Authorization References

New Source Review Authorization References 28

New Source Review Authorization References by Emission Unit 29

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 115986	Issuance Date: 07/23/2024

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
AREAFUG	AREA FUGITIVES	115986
AREAFUG2	AREA FUGITIVES 2	115986
COMP 10	RECIPROCATING COMPRESSOR	115986
COMP 11	RECIPROCATING COMPRESSOR	115986
COMP 12	RECIPROCATING COMPRESSOR	115986
COMP 9	RECIPROCATING COMPRESSOR	115986
DEHY	RED BLUFF DEHYDRATION UNIT 1	115986
DEHY1	RED BLUFF DEHYDRATION UNIT 2	115986
DEHY2	ORLA DEHYDRATION UNIT	115986
ENGINE 10	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 11	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 12	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 6	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 7	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 8	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
ENGINE 9	CAT 3616 RESIDUE COMPRESSOR ENGINE	115986
FLARE1	PROCESS FLARE 1	115986
FLARE2	PROCESS FLARE 2	115986
FLARE3A	ACID GAS FLARE	115986
HTR7	INLET GAS HMO HEATER	115986
HTR8	DEC1 MODE HMO HEATER	115986

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
HTR9	INLET GAS HMO HEATER	115986
PROAMINE	RED BLUFF AMINE UNIT	115986
PROAMINE2	ORLA AMINE UNIT	115986

Appendix A

Acronym List 32

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound