

Statement of Basis of the Federal Operating Permit

Wyman-Gordon Forgings, Inc.

Site Name: Wyman Gordon Forgings - Cypress Facility
Physical Location: 10825 Telge Rd
Nearest City: Houston
County: Harris

Permit Number: O4688
Project Type: Significant Revision

The North American Industry Classification System (NAICS) Code: 331210
NAICS Name: Iron and Steel Pipe and Tube Manufacturing from Purchased Steel

This Statement of Basis sets forth the legal and factual basis for the draft changes to the permit conditions resulting from the significant revision project in accordance with 30 TAC §122.201(a)(4). The applicant has submitted an application for a significant permit revision per §§ 122.219-221. This document may include the following information:

- A description of the facility/area process description;
- A description of the revision project;
- A basis for applying permit shields;
- A list of the federal regulatory applicability determinations;
- A table listing the determination of applicable requirements;
- A list of the New Source Review Requirements;
- The rationale for periodic monitoring methods selected;
- The rationale for compliance assurance methods selected;
- A compliance status; and
- A list of available unit attribute forms.

Prepared on: June 30, 2026

Operating Permit Basis of Determination

Description of Revisions

This project is to update and add case-by-case the Periodic Monitoring (PM) for the required for 12 Process Heater/Furnace emission units (EU's), listed in the table below, and applicable to Ch 117 CO limits 117.310(c)(1).

EU-2830	EU-F120	EU-F500	EU-M675
EU-D132	EU-F121	EU-G126	EU-M914
EU-D249	EU-F276	EU-G127	EU-Z757

Permit Area Process Description

The Wyman-Gordon Forgings – Cypress Facility (or Cypress Facility) produces iron and steel forged and extruded parts. The majority of forged parts consist of either shapes used in mechanical applications, which are made to customer specifications, or stock piping of various lengths and thicknesses which are sold for secondary use in other industries. The Cypress Facility also produces stock forged parts and coated piping. The forging process employs primary iron and steel billets, pigs, ingots, and other shapes that are purchased from suppliers. The facility discontinued in-house metal melting and production of primary iron and steel in 1984.

The facility operates on a potential schedule of 24 hours per day (hours/day), 7 days per week (days/week), 50 weeks per year (weeks/year), at an annual schedule of 8,400 hours per year (hours/year). Specific units and processes may have an operation schedule that is less than 8,400 hours per year or that may operate intermittently on an “*as needed*” basis. In general, the significant majority of emission sources at the Cypress Facility are covered by one or more Standard Exemptions, most of which were authorized prior to 1991. The facility also has several Permit-By-Rules (PBRs) that cover specific equipment or process areas.

The Cypress Facility includes the following plant operational areas:

- Forge Shop - Heat Treatment Area.
- Extrusion Building - Machine Shop Area.
- Extrusion Building - Pipe Shop Area.
- Melt Shop and VAR Shop.
- Miscellaneous Plant Buildings and Plant Equipment

FOPs at Site

The “application area” consists of the emission units and that portion of the site included in the application and this permit. Multiple FOPs may be issued to a site in accordance with 30 TAC § 122.201(e). When there is only one area for the site, then the application information and permit will include all units at the site. Additional FOPs that exist at the site, if any, are listed below.

Additional FOPs: None

Major Source Pollutants

The table below specifies the pollutants for which the site is a major source:

Major Pollutants	NOX, CO
------------------	---------

Reading State of Texas’s Federal Operating Permit

The Title V Federal Operating Permit (FOP) lists all state and federal air emission regulations and New Source Review (NSR) authorizations (collectively known as “applicable requirements”) that apply at a particular site or permit area (in the event a site has multiple FOPs). **The FOP does not authorize new emissions or new construction activities.** The FOP begins with an introductory page which is common to all Title V permits. This page gives the details of the company,

states the authority of the issuing agency, requires the company to operate in accordance with this permit and 30 Texas Administrative Code (TAC) Chapter 122, requires adherence with NSR requirements of 30 TAC Chapter 116, and finally indicates the permit number and the issuance date.

This is followed by the table of contents, which is generally composed of the following elements. Not all permits will have all of the elements.

- General Terms and Conditions
- Special Terms and Conditions
 - Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting
 - Additional Monitoring Requirements
 - New Source Review Authorization Requirements
 - Compliance Requirements
 - Protection of Stratosphere Ozone
 - Permit Location
 - Permit Shield (30 TAC § 122.148)
- Attachments
 - Applicable Requirements Summary
 - Unit Summary
 - Applicable Requirements Summary
 - Additional Monitoring Requirements
 - Permit Shield
 - New Source Review Authorization References
 - Compliance Plan
 - Alternative Requirements
- Appendix A
 - Acronym list

General Terms and Conditions

The General Terms and Conditions are the same and appear in all permits. The first paragraph lists the specific citations for 30 TAC Chapter 122 requirements that apply to all Title V permit holders. The second paragraph describes the requirements for record retention. The third paragraph provides details for voiding the permit, if applicable. The fourth paragraph states that the permit holder shall comply with the requirements of 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit. The fifth paragraph provides details on submission of reports required by the permit.

Special Terms and Conditions

Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting. The TCEQ has designated certain applicable requirements as site-wide requirements. A site-wide requirement is a requirement that applies uniformly to all the units or activities at the site. Units with only site-wide requirements are addressed on Form OP-REQ1 and are not required to be listed separately on an OP-UA Form or Form OP-SUM. Form OP-SUM must list all units addressed in the application and provide identifying information, applicable OP-UA Forms, and preconstruction authorizations. The various OP-UA Forms provide the characteristics of each unit from which applicable requirements are established. Some exceptions exist as a few units may have both site-wide requirements and unit specific requirements.

Other conditions. The other entries under special terms and conditions are in general terms referring to compliance with the more detailed data listed in the attachments.

Attachments

Applicable Requirements Summary. The first attachment, the Applicable Requirements Summary, has two tables, addressing unit specific requirements. The first table, the Unit Summary, includes a list of units with applicable requirements, the unit type, the applicable regulation, and the requirement driver. The intent of the requirement driver is to inform the reader that a given unit may have several different operating scenarios and the differences between those operating scenarios.

The applicable requirements summary table provides the detailed citations of the rules that apply to the various units. For each unit and operating scenario, there is an added modifier called the “index number,” detailed citations specifying monitoring and testing requirements, recordkeeping requirements, and reporting requirements. The data for this table is based on data supplied by the applicant on the OP-SUM and various OP-UA forms.

Additional Monitoring Requirement. The next attachment includes additional monitoring the applicant must perform to ensure compliance with the applicable standard. Compliance assurance monitoring (CAM) is often required to provide a reasonable assurance of compliance with applicable emission limitations/standards for large emission units that use control devices to achieve compliance with applicant requirements. When necessary, periodic monitoring (PM) requirements are specified for certain parameters (i.e. feed rates, flow rates, temperature, fuel type and consumption, etc.) to determine if a term and condition or emission unit is operating within specified limits to control emissions. These additional monitoring approaches may be required for two reasons. First, the applicable rules do not adequately specify monitoring requirements (exception- Maximum Achievable Control Technology Standards (MACTs) generally have sufficient monitoring), and second, monitoring may be required to fill gaps in the monitoring requirements of certain applicable requirements. In situations where the NSR permit is the applicable requirement requiring extra monitoring for a specific emission unit, the preferred solution is to have the monitoring requirements in the NSR permit updated so that all NSR requirements are consolidated in the NSR permit.

Permit Shield. A permit may or may not have a permit shield, depending on whether an applicant has applied for, and justified the granting of, a permit shield. A permit shield is a special condition included in the permit document stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirement(s) or specified applicable state-only requirement(s).

New Source Review Authorization References. All activities which are related to emissions in the state of Texas must have a NSR authorization prior to beginning construction. This section lists all units in the permit and the NSR authorization that allowed the unit to be constructed or modified. Units that do not have unit specific applicable requirements other than the NSR authorization do not need to be listed in this attachment. While NSR permits are not physically a part of the Title V permit, they are legally incorporated into the Title V permit by reference. Those NSR permits whose emissions exceed certain PSD/NA thresholds must also undergo a Federal review of federally regulated pollutants in addition to review for state regulated pollutants.

Compliance Plan. A permit may have a compliance schedule attachment for listing corrective actions plans for any emission unit that is out of compliance with an applicable requirement.

Alternative Requirements. This attachment will list any alternative monitoring plans or alternative means of compliance for applicable requirements that have been approved by the EPA Administrator and/or the TCEQ Executive Director.

Appendix A

Acronym list. This attachment lists the common acronyms used when discussing the FOPs.

Stationary vents subject to 30 TAC Chapter 111, Subchapter A, § 111.111(a)(1)(B) addressed in the Special Terms and Conditions

The site contains stationary vents with a flowrate less than 100,000 actual cubic feet per minute (acfm) which are limited, over a six-minute average, to 20% opacity as required by 30 TAC § 111.111(a)(1)(B). As a site may have a large number of stationary vents that fall into this category, they are not required to be listed individually in the permit's Applicable Requirements Summary. This is consistent with EPA's White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995, that states that requirements that apply identically to emission units at a site can be treated on a generic basis such as source-wide opacity limits.

Periodic monitoring is specified in Special Term and Condition 3 for stationary vents subject to 30 TAC § 111.111(a)(1)(B) to verify compliance with the 20% opacity limit. These vents are not expected to produce visible emissions during normal operation. The TCEQ evaluated the probability of these sources violating the opacity standards and determined that there is a very low potential that an opacity standard would be exceeded. It was determined that continuous monitoring for these sources is not warranted as there would be very limited environmental benefit in continuously monitoring sources that have a low potential to produce visible emissions. Therefore, the TCEQ set the visible observation monitoring frequency for these sources to once per calendar quarter.

The TCEQ has exempted vents that are not capable of producing visible emissions from periodic monitoring requirements. These vents include sources of colorless VOCs, non-fuming liquids, and other materials that cannot produce emissions that obstruct the transmission of light. Passive ventilation vents, such as plumbing vents, are also included in this category. Since this category of vents are not capable of producing opacity due to the physical or chemical characteristics of the emission source, periodic monitoring is not required as it would not yield any additional data to assure compliance with the 20% opacity standard of 30 TAC § 111.111(a)(1)(B).

In the event that visible emissions are detected, either through the quarterly observation or other credible evidence, such as observations from company personnel, the permit holder shall either report a deviation or perform a Test Method 9 observation to determine the opacity consistent with the 6-minute averaging time specified in 30 TAC § 111.111(a)(1)(B). An additional provision is included to monitor combustion sources more frequently than quarterly if alternate fuels are burned for periods greater than 24 consecutive hours. This will address possible emissions that may arise when switching fuel types.

The applicant opted to comply with the more stringent 20% opacity standard under 30 TAC § 111.111(a)(1)(B) for all stationary vents that are subject to the 30% opacity standard under 30 TAC § 111.111(a)(1)(A).

Federal Regulatory Applicability Determinations

The following chart summarizes the applicability of the principal air pollution regulatory programs to the permit area:

Regulatory Program	Applicability (Yes/No)
Prevention of Significant Deterioration (PSD)	No
Nonattainment New Source Review (NNSR)	No
Minor NSR	Yes
40 CFR Part 60 - New Source Performance Standards	No
40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants (NESHAPs)	No
40 CFR Part 63 - NESHAPs for Source Categories	Yes
Title IV (Acid Rain) of the Clean Air Act (CAA)	No
Title V (Federal Operating Permits) of the CAA	Yes
Title VI (Stratospheric Ozone Protection) of the CAA	No
CSAPR (Cross-State Air Pollution Rule)	No
Federal Implementation Plan for Regional Haze (Texas SO ₂ Trading Program)	No

Basis for Applying Permit Shields

An operating permit applicant has the opportunity to specifically request a permit shield to document that specific applicable requirements do not apply to emission units in the permit. A permit shield is a special condition stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements. A permit shield has been requested in the application for specific emission units. For the permit shield requests that have been approved, the basis of determination for regulations that the owner/operator need not comply with are located in the "Permit Shield" attachment of the permit.

Insignificant Activities and Emission Units

In general, units not meeting the criteria for inclusion on either Form OP-SUM or Form OP-REQ1 are not required to be addressed in the operating permit application. Examples of these types of units include, but are not limited to, the following:

De Minimis Sources

1. Sources identified in the "De Minimis Facilities or Sources" list maintained by TCEQ. The list is available at https://www.tceq.texas.gov/permitting/air/newsourcereview/de_minimis.html.

Miscellaneous Sources

2. Office activities such as photocopying, blueprint copying, and photographic processes.
3. Outdoor barbecue pits, campfires, and fireplaces.
4. Storage and handling of sealed portable containers, cylinders, or sealed drums.
5. Vehicle exhaust from maintenance or repair shops.
6. Storage and use of non-VOC products or equipment for maintaining motor vehicles operated at the site (including but not limited to, antifreeze and fuel additives).
7. Air contaminant detectors and recorders, combustion controllers and shut-off devices, product analyzers, laboratory analyzers, continuous emissions monitors, other analyzers and monitors, and emissions associated with sampling activities. Exception to this category includes sampling activities that are deemed fugitive emissions and under a regulatory leak detection and repair program.
8. Steam vents, steam leaks, and steam safety relief valves, provided the steam (or boiler feedwater) has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
9. Storage of water that has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
10. Well cellars.
11. Fire or emergency response equipment and training, including but not limited to, use of fire control equipment including equipment testing and training, and open burning of materials or fuels associated with firefighting training.
12. Equipment used exclusively for the melting or application of wax.
13. Instrument systems utilizing air, natural gas, nitrogen, oxygen, carbon dioxide, helium, neon, argon, krypton, and xenon.
14. Battery recharging areas.

Sources Authorized by 30 TAC Chapter 106, Permits by Rule

15. Sources authorized by §106.102: Combustion units designed and used exclusively for comfort heating purposes employing liquid petroleum gas, natural gas, solid wood, or distillate fuel oil.
16. Sources authorized by §106.122: Bench scale laboratory equipment and laboratory equipment used exclusively for chemical and physical analysis, including but not limited to, assorted vacuum producing devices and laboratory fume hoods.
17. Sources authorized by §106.141: Batch mixers with rated capacity of 27 cubic feet or less for mixing cement, sand, aggregate, lime, gypsum, additives, and/or water to produce concrete, grout, stucco, mortar, or other similar products.
18. Sources authorized by §106.143: Wet sand and gravel production facilities that obtain material from subterranean and subaqueous beds where the deposits of sand and gravel are consolidated granular materials resulting from natural disintegration of rock and stone and have a production rate of 500 tons per hour or less.
19. Sources authorized by §106.148: Railcar or truck unloading of wet sand, gravel, aggregate, coal, lignite, and scrap iron or scrap steel (but not including metal ores, metal oxides, battery parts, or fine dry materials) into trucks or other railcars for transportation to other locations.
20. Sources authorized by §106.149: Sand and gravel production facilities that obtain material from deposits of sand and gravel consisting of natural disintegration of rock and stone, provided that crushing or breaking operations are not used and no blasting is conducted to obtain the material.
21. Sources authorized by §106.161: Animal feeding operations which confine animals in numbers specified and any associated on-site feed handling and/or feed millings operations, not including caged laying and caged pullet operations.
22. Sources authorized by §106.162: Livestock auction sales facilities.

23. Sources authorized by §106.163: All animal racing facilities, domestic animal shelters, zoos, and their associated confinement areas, stables, feeding areas, and waste collection and treatment facilities, other than incineration units.
24. Sources authorized by §106.229: Equipment used exclusively for the dyeing or stripping of textiles.
25. Sources authorized by §106.241: Any facility where animals or poultry are slaughtered and prepared for human consumption provided that waste products such as blood, offal, and feathers are stored in such a manner as to prevent the creation of a nuisance condition and these waste products are removed from the premises daily or stored under refrigeration.
26. Sources authorized by §106.242: Equipment used in eating establishments for the purpose of preparing food for human consumption.
27. Sources authorized by §106.243: Smokehouses in which the maximum horizontal inside cross-sectional area does not exceed 100 square feet.
28. Sources authorized by §106.244: Ovens, mixers, blenders, barbecue pits, and cookers if the products are edible and intended for human consumption.
29. Sources authorized by §106.266: Vacuum cleaning systems used exclusively for industrial, commercial, or residential housekeeping purposes.
30. Sources authorized by §106.301: Aqueous fertilizer storage tanks.
31. Sources authorized by §106.313: All closed tumblers used for the cleaning or deburring of metal products without abrasive blasting, and all open tumblers with a batch capacity of 1,000 lbs. or less.
32. Sources authorized by §106.316: Equipment used for inspection of metal products.
33. Sources authorized by §106.317: Equipment used exclusively for rolling, forging, pressing, drawing, spinning, or extruding either hot or cold metals by some mechanical means.
34. Sources authorized by §106.318: Die casting machines.
35. Sources authorized by §106.319: Foundry sand mold forming equipment to which no heat is applied.
36. Sources authorized by §106.331: Equipment used exclusively to package pharmaceuticals and cosmetics or to coat pharmaceutical tablets.
37. Sources authorized by §106.333: Equipment used exclusively for the mixing and blending of materials at ambient temperature to make water-based adhesives.
38. Sources authorized by §106.372: Any air separation or other industrial gas production, storage, or packaging facility. Industrial gases, for purposes of this list, include only oxygen, nitrogen, helium, neon, argon, krypton, and xenon.
39. Sources authorized by §106.391: Presses used for the curing of rubber products and plastic products.
40. Sources authorized by §106.394: Equipment used for compression molding and injection molding of plastics.
41. Sources authorized by §106.414: Equipment used exclusively for the packaging of lubricants or greases.
42. Sources authorized by §106.415: Laundry dryers, extractors, and tumblers used for fabrics cleaned with water solutions of bleach or detergents.
43. Sources authorized by §106.431: Equipment used exclusively to mill or grind coatings and molding compounds where all materials charged are in paste form.
44. Sources authorized by §106.432: Containers, reservoirs, or tanks used exclusively for dipping operations for coating objects with oils, waxes, or greases where no organic solvents, diluents, or thinners are used; or dipping operations for applying coatings of natural or synthetic resins which contain no organic solvents.
45. Sources authorized by §106.451: Blast cleaning equipment using a suspension of abrasives in water.
46. Sources authorized by §106.453: Equipment used for washing or drying products fabricated from metal or glass, provided no volatile organic materials are used in the process and no oil or solid fuel is burned.
47. Sources authorized by §106.471: Equipment used exclusively to store or hold dry natural gas.
48. Sources authorized by §106.531: Sewage treatment facilities, excluding combustion or incineration equipment, land farms, or grease trap waste handling or treatment facilities.

Determination of Applicable Requirements

The tables below include the applicability determinations for the emission units, the index number(s) where applicable, and all relevant unit attribute information used to form the basis of the applicability determination. The unit attribute information is a description of the physical properties of an emission unit which is used to determine the requirements to which the permit holder must comply. For more information about the descriptions of the unit attributes specific Unit Attribute Forms may be viewed at www.tceq.texas.gov/permitting/air/nav/air_all_ua_forms.html.

A list of unit attribute forms is included at the end of this document. Some examples of unit attributes include construction date; product stored in a tank; boiler fuel type; etc.. Generally, multiple attributes are needed to determine the requirements for a given emission unit and index number. The table below lists these attributes in the column entitled "Basis of Determination." Attributes that demonstrate that an applicable requirement applies will be the factual basis for

the specific citations in an applicable requirement that apply to a unit for that index number. The TCEQ Air Permits Division has developed flowcharts for determining applicability of state and federal regulations based on the unit attribute information in a Decision Support System (DSS). These flowcharts can be accessed via the internet at www.tceq.texas.gov/permitting/air/nav/air_supportsys.html. The Air Permits Division staff may also be contacted for assistance at (512) 239-1250.

The attributes for each unit and corresponding index number provide the basis for determining the specific legal citations in an applicable requirement that apply, including emission limitations or standards, monitoring, recordkeeping, and reporting. The rules were found to apply or not apply by using the unit attributes as answers to decision questions found in the flowcharts of the DSS. Some additional attributes indicate which legal citations of a rule apply. The legal citations that apply to each emission unit may be found in the Applicable Requirements Summary table of the draft permit. There may be some entries or rows of units and rules not found in the permit, or if the permit contains a permit shield, repeated in the permit shield area. These are sets of attributes that describe negative applicability, or; in other words, the reason why a potentially applicable requirement does not apply.

If applicability determinations have been made which differ from the available flowcharts, an explanation of the decisions involved in the applicability determination is specified in the column "Changes and Exceptions to RRT." If there were no exceptions to the DSS, then this column has been removed.

The draft permit includes all emission limitations or standards, monitoring, recordkeeping and reporting required by each applicable requirement. If an applicable requirement does not require monitoring, recordkeeping, or reporting, the word "None" will appear in the Applicable Requirements Summary table. If additional periodic monitoring is required for an applicable requirement, it will be explained in detail in the portion of this document entitled "Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected."

When attributes demonstrate that a unit is not subject to an applicable requirement, the applicant may request a permit shield for those items. The portion of this document entitled "Basis for Applying Permit Shields" specifies which units, if any, have a permit shield.

Operational Flexibility

When an emission unit has multiple operating scenarios, it will have a different index number associated with each operating condition. This means that units are permitted to operate under multiple operating conditions. The applicable requirements for each operating condition are determined by a unique set of unit attributes. For example, a tank may store two different products at different points in time. The tank may, therefore, need to comply with two distinct sets of requirements, depending on the product that is stored. Both sets of requirements are included in the permit, so that the permit holder may store either product in the tank.

Determination of Applicable Requirements

Unit ID	Regulation	Index Number	Basis of Determination*
A-506	30 TAC Chapter 117, Subchapter B	R7300-NG1	Type of Service = Used exclusively in emergency situations Fuel Fired = Natural gas
A-506	40 CFR Part 60, Subpart JJJJ	60JJJJ-1	Construction/Reconstruction/Modification Date = The stationary spark ignition (SI) internal combustion engine (ICE) commenced construction, reconstruction or modification prior to June 12, 2006.
A-506	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-NG1	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP greater than or equal to 100 HP and less than 250 HP. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = 4 stroke spark ignited lean burn engine.
A-507	30 TAC Chapter 117, Subchapter B	R7300-DSL1	Type of Service = Used exclusively in emergency situations Fuel Fired = Petroleum-based diesel fuel
A-507	40 CFR Part 60, Subpart IIII	60IIII-2	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification on or before 07/11/2005.
A-507	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-DSL4	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP greater than or equal to 250 HP and less than 300 HP. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = Compression ignition engine Displacement = The stationary CI RICE has a displacement of less than 30 liters per cylinder and uses diesel fuel.
H141	30 TAC Chapter 117, Subchapter B	R7300-DSL1	Type of Service = Used exclusively in emergency situations Fuel Fired = Petroleum-based diesel fuel
H141	40 CFR Part 60, Subpart IIII	60IIII-2	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification on or before 07/11/2005.
H141	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-DSL3	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP less than 100 HP. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.

Unit ID	Regulation	Index Number	Basis of Determination*
			Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = Compression ignition engine Displacement = The stationary CI RICE has a displacement of less than 30 liters per cylinder and uses diesel fuel.
H148	30 TAC Chapter 117, Subchapter B	R7300-NG1	Type of Service = New, modified, reconstructed or relocated diesel fuel-fired engine, placed into service on or after October 1, 2001, located in the Houston/Galveston/Brazoria ozone nonattainment area, operated less than 100 hours/year, on a rolling 12-month average
H148	40 CFR Part 60, Subpart JJJJ	60JJJJ-1	Construction/Reconstruction/Modification Date = The stationary spark ignition (SI) internal combustion engine (ICE) commenced construction, reconstruction or modification prior to June 12, 2006.
H148	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-NG1	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP greater than or equal to 100 HP and less than 250 HP. Construction/Reconstruction Date = Commenced construction or reconstruction on or after December 19, 2002, but before June 12, 2006. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = 4 stroke spark ignited lean burn engine.
Z541	30 TAC Chapter 117, Subchapter B	R7300-DSL1	Type of Service = New, modified, reconstructed or relocated diesel fuel-fired engine, placed into service on or after October 1, 2001, located in the Houston/Galveston/Brazoria ozone nonattainment area, operated less than 100 hours/year, on a rolling 12-month average
Z541	40 CFR Part 60, Subpart IIII	60IIII-1	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification on or before 07/11/2005.
Z541	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-DSL1	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP less than 100 HP. Construction/Reconstruction Date = Commenced construction or reconstruction on or after December 19, 2002, but before June 12, 2006. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = Compression ignition engine Displacement = The stationary CI RICE has a displacement of less than 30 liters per cylinder and uses diesel fuel.
Z542	30 TAC Chapter 117, Subchapter B	R7300-DSL1	Type of Service = New, modified, reconstructed or relocated diesel fuel-fired engine, placed into service on or after October 1, 2001, located in the Houston/Galveston/Brazoria ozone nonattainment area, operated less than 100 hours/year, on a rolling 12-month average

Unit ID	Regulation	Index Number	Basis of Determination*
Z542	40 CFR Part 60, Subpart IIII	60IIII-1	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification on or before 07/11/2005.
Z542	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-DLS1	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP less than 100 HP. Construction/Reconstruction Date = Commenced construction or reconstruction on or after December 19, 2002, but before June 12, 2006. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = Compression ignition engine Displacement = The stationary CI RICE has a displacement of less than 30 liters per cylinder and uses diesel fuel.
Z543	30 TAC Chapter 117, Subchapter B	R7300-DSL1	Type of Service = New, modified, reconstructed or relocated diesel fuel-fired engine, placed into service on or after October 1, 2001, located in the Houston/Galveston/Brazoria ozone nonattainment area, operated less than 100 hours/year, on a rolling 12-month average
Z543	40 CFR Part 60, Subpart IIII	60IIII-1	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification on or before 07/11/2005.
Z543	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-DSL2	HAP Source = The site is an area source of hazardous air pollutants as defined in 40 CFR § 63.2 Brake HP = Stationary RICE with a brake HP greater than or equal to 100 HP and less than 250 HP. Construction/Reconstruction Date = Commenced construction or reconstruction on or after December 19, 2002, but before June 12, 2006. Nonindustrial Emergency Engine = Stationary RICE is not defined in 40 CFR §63.6675 as a residential emergency RICE, a commercial emergency RICE, or an institutional emergency RICE. Service Type = Emergency use where the RICE operates for the purpose specified in 40 CFR §63.6640(f)(4)(ii). Stationary RICE Type = Compression ignition engine Displacement = The stationary CI RICE has a displacement of less than 30 liters per cylinder and uses diesel fuel.
D408	30 TAC Chapter 115, Storage of VOCs	R5112-005	Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria. Product Stored = VOC other than crude oil or condensate Storage Capacity = Capacity is greater than 1,000 gallons but less than or equal to 25,000 gallons Tank Description = Tank does not require emission controls True Vapor Pressure = True vapor pressure is less than 1.0 psia
D408	40 CFR Part 60, Subpart Kb	60Kb-2	Product Stored = Volatile organic liquid Storage Capacity = Capacity is less than 10,600 gallons (40,000 liters)
W829-1	30 TAC Chapter 115, Storage of VOCs	R5112-007	Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria.

Unit ID	Regulation	Index Number	Basis of Determination*
			Product Stored = Gasoline from a storage container in motor vehicle fuel dispensing service (as defined in 30 TAC Chapter 115) Storage Capacity = Capacity is less than 25,000 gallons Tank Description = Tank does not require emission controls True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia
W829-1	40 CFR Part 60, Subpart Kb	60Kb-2	Product Stored = Volatile organic liquid Storage Capacity = Capacity is less than 10,600 gallons (40,000 liters)
W829-2	30 TAC Chapter 115, Storage of VOCs	R5112-005	Alternate Control Requirement = Not using an alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria. Product Stored = VOC other than crude oil or condensate Storage Capacity = Capacity is greater than 1,000 gallons but less than or equal to 25,000 gallons Tank Description = Tank does not require emission controls True Vapor Pressure = True vapor pressure is less than 1.0 psia
W829-2	40 CFR Part 60, Subpart Kb	60Kb-2	Product Stored = Volatile organic liquid Storage Capacity = Capacity is less than 10,600 gallons (40,000 liters)
2830	30 TAC Chapter 117, Subchapter B	R7300-40-100	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 40 MMBtu/hr but less than 100 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
D132	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.

Unit ID	Regulation	Index Number	Basis of Determination*
D249	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
E510	30 TAC Chapter 117, Subchapter B	R7300-02	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is less than or equal to 2 MMBtu/hr
F120	30 TAC Chapter 117, Subchapter B	R7300-40-100	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 40 MMBtu/hr but less than 100 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
F121	30 TAC Chapter 117, Subchapter B	R7300-40-100	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 40 MMBtu/hr but less than 100 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
F160	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
F161	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr

Unit ID	Regulation	Index Number	Basis of Determination*
F276	30 TAC Chapter 117, Subchapter B	R7300-40-100	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 40 MMBtu/hr but less than 100 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
F500	30 TAC Chapter 117, Subchapter B	R7300-40-100	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 40 MMBtu/hr but less than 100 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
G126	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
G127	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a).

Unit ID	Regulation	Index Number	Basis of Determination*
			CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
GRPENERGY1	30 TAC Chapter 117, Subchapter B	R7300-2009	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
GRPTURBN1	30 TAC Chapter 117, Subchapter B	R7300-2009	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
GRPTURBN2	30 TAC Chapter 117, Subchapter B	R7300-2007	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H011	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H012	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H043	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H044	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H101	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H105	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H108	30 TAC Chapter 117, Subchapter B	R7300-02	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is less than or equal to 2 MMBtu/hr
H110	30 TAC Chapter 117, Subchapter B	R7300-02	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is less than or equal to 2 MMBtu/hr
H115	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H121	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr

Unit ID	Regulation	Index Number	Basis of Determination*
H124	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
H125	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
M675	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
M914	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.
W508	30 TAC Chapter 117, Subchapter B	R7300-2008	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is less than or equal to 2 MMBtu/hr
Z757	30 TAC Chapter 117, Subchapter B	R7300-20-40	Unit Type = Metallurgical reheat furnace Maximum Rate Capacity = MRC is greater than 20 MMBtu/hr but less than 40 MMBtu/hr NOx Emission Limitation = Title 30 TAC § 117.310(a) NOx Emission Limit Basis = Emission limit in lb/MMBtu on a rolling 30-day average NOx Reduction = No NO _x reduction NOx Monitoring System = Maximum emission rate testing [in accordance with 30 TAC § 117.8000] Fuel Flow Monitoring = Fuel flow is monitored with a totalizing fuel flow meter per 30 TAC §§ 117.340(a) or 117.440(a). CO Emission Limitation = Title 30 TAC § 117.310(c)(1) CO Monitoring System = Emissions are monitored using a method other than a CEMS or PEMS.

Unit ID	Regulation	Index Number	Basis of Determination*
Z879	30 TAC Chapter 117, Subchapter B	R7300-2-20	Unit Type = Metallurgical heat treating furnace Maximum Rate Capacity = MRC is greater than 2 MMBtu/hr but less than 20 MMBtu/hr
GRPCOLD	30 TAC Chapter 115, Degreasing Processes	R5412-001	Solvent Degreasing Machine Type = Cold solvent cleaning machine. Alternate Control Requirement = The TCEQ Executive Director has not approved an alternative control requirement as allowed under 30 TAC § 115.413 or not alternative has been requested. Solvent Sprayed = No solvent is sprayed. Solvent Vapor Pressure = Solvent vapor pressure is less than or equal to 0.6 psia as measured at 100 degrees Fahrenheit. Solvent Heated = The solvent is heated to a temperature greater than 120 degrees Fahrenheit Parts Larger than Drainage = Cleaned parts for which the machine is authorized to clean are larger than the internal drainage facility of the machine. Drainage Area = Area is greater than or equal to 16 square inches. Disposal in Enclosed Containers = Waste solvent is properly disposed of in enclosed containers.
GRPRRC-S	30 TAC Chapter 115, Degreasing Processes	R5412-003	Solvent Degreasing Machine Type = Remote reservoir cold solvent cleaning machine. Alternate Control Requirement = The TCEQ Executive Director has not approved an alternative control requirement as allowed under 30 TAC § 115.413 or not alternative has been requested. Solvent Sprayed = No solvent is sprayed. Solvent Vapor Pressure = Solvent vapor pressure is less than or equal to 0.6 psia as measured at 100 degrees Fahrenheit. Parts Larger than Drainage = Cleaned parts for which the machine is authorized to clean are larger than the internal drainage facility of the machine. Drainage Area = Area is less than 16 square inches. Disposal in Enclosed Containers = Waste solvent is properly disposed of in enclosed containers.
PRO-G152S	30 TAC Chapter 115, Surface Coating Operations	R5421-001	Alternative Compliance Method = No alternate method for demonstrating and documenting continuous compliance with applicable control requirements or exemption criteria has been approved by the TCEQ Executive Director under 30 TAC § 115.423(2), § 115.423(3)(A) or § 115.423(4). Facility Operations = Other miscellaneous metal parts and products coating. Maintenance Shop = Coating operation is not conducted at an on-site maintenance shop, or coating operation is not recoating of used miscellaneous metal parts and products. Alternate Requirements = No alternate requirement to 30 TAC § 115.421(8) has been approved by the TCEQ Executive Director. Miscellaneous Coating Type = A coating that is low-bake, or utilizes air or forced air driers.

* - The "unit attributes" or operating conditions that determine what requirements apply

NSR Versus Title V FOP

The state of Texas has two Air permitting programs, New Source Review (NSR) and Title V Federal Operating Permits. The two programs are substantially different both in intent and permit content.

NSR is a preconstruction permitting program authorized by the Texas Clean Air Act and Title I of the Federal Clean Air Act (FCAA). The processing of these permits is governed by 30 Texas Administrative Code (TAC) Chapter 116.111. The Title V Federal Operating Program is a federal program authorized under Title V of the FCAA that has been delegated to the state of Texas to administer and is governed by 30 TAC Chapter 122. The major differences between the two permitting programs are listed in the table below:

NSR Permit	Federal Operating Permit (FOP)
Issued Prior to new Construction or modification of an existing facility	For initial permit with application shield, can be issued after operation commences; significant revisions require approval prior to operation.
Authorizes air emissions	Codifies existing applicable requirements, does not authorize new emissions
Ensures issued permits are protective of the environment and human health by conducting a health effects review and that requirement for best available control technology (BACT) is implemented.	Applicable requirements listed in permit are used by the inspectors to ensure proper operation of the site as authorized. Ensures that adequate monitoring is in place to allow compliance determination with the FOP.
Up to two Public notices may be required. Opportunity for public comment and contested case hearings for some authorizations.	One public notice required. Opportunity for public comments. No contested case hearings.
Applies to all point source emissions in the state.	Applies to all major sources and some non-major sources identified by the EPA.
Applies to facilities: a portion of site or individual emission sources	One or multiple FOPs cover the entire site (consists of multiple facilities)
Permits include terms and conditions under which the applicant must construct and operate its various equipment and processes on a facility basis.	Permits include terms and conditions that specify the general operational requirements of the site; and include codification of all applicable requirements for emission units at the site.
Opportunity for EPA review for Federal Prevention of Significant Deterioration (PSD) and Nonattainment (NA) permits for major sources.	Opportunity for EPA review, affected states review, and a Public petition period for every FOP.
Permits have a table listing maximum emission limits for pollutants	Permit has an applicable requirements table and Periodic Monitoring (PM) / Compliance Assurance Monitoring (CAM) tables which document applicable monitoring requirements.
Permits can be altered or amended upon application by company. Permits must be issued before construction or modification of facilities can begin.	Permits can be revised through several revision processes, which provide for different levels of public notice and opportunity to comment. Changes that would be significant revisions require that a revised permit be issued before those changes can be operated.
NSR permits are issued independent of FOP requirements.	FOPs are independent of NSR permits, but contain a list of all NSR permits incorporated by reference

New Source Review Requirements

Below is a list of the New Source Review (NSR) permits for the permitted area. These NSR permits are incorporated by reference into the operating permit and are enforceable under it. These permits can be found in the main TCEQ file room, located on the first floor of Building E, 12100 Park 35 Circle, Austin, Texas. In addition, many of the permits are accessible online through the link provided below. The Public Education Program may be contacted at 1-800-687-4040 or the Air Permits Division (APD) may be contacted at 1-512-239-1250 for help with any question.

Additionally, the site contains emission units that are permitted by rule under the requirements of 30 TAC Chapter 106, Permits by Rule. Permit by Rule (PBR) registrations submitted by permittees are also available online through the link provided below. The following table specifies the PBRs that apply to the site.

The status of air permits, applications, and PBR registrations may be found by performing the appropriate search of the databases located at the following website:

www.tceq.texas.gov/permitting/air/nav/air_status_permits.html

Details on how to search the databases are available in the **Obtaining Permit Documents** section below.

New Source Review Authorization References

Permits by Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.122	Version No./Date: 09/04/2000
Number: 106.183	Version No./Date: 06/18/1997
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.221	Version No./Date: 03/14/1997
Number: 106.224	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 03/14/1997
Number: 106.265	Version No./Date: 03/14/1997
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.313	Version No./Date: 09/04/2000
Number: 106.317	Version No./Date: 03/14/1997
Number: 106.320	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 03/14/1997
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000
Number: 7	Version No./Date: 09/23/1982
Number: 7	Version No./Date: 10/04/1995
Number: 40	Version No./Date: 03/13/1993
Number: 57	Version No./Date: 10/04/1995
Number: 65	Version No./Date: 05/05/1976
Number: 65	Version No./Date: 01/08/1980
Number: 102	Version No./Date: 06/07/1996

Permits by Rule

The TCEQ has interpreted the emission limits prescribed in 30 TAC §106.4(a) as both emission thresholds and default emission limits. The emission limits in 30 TAC §106.4(a) are all considered applicable to each facility as a threshold matter to ensure that the owner/operator qualifies for the PBR authorization. Those same emission limits are also the default emission limits if the specific PBR does not further limit emissions or there is no lower, certified emission limit claimed by the owner/operator.

This interpretation is consistent with how TCEQ has historically determined compliance with the emission limits prior to the addition of the “as applicable” language. The “as applicable” language was added in 2014 as part of changes to the sentence structure in a rulemaking that made other changes to address greenhouse gases and was not intended as a substantive rule change. This interpretation also provides for effective and practical enforcement of 30 TAC §106.4(a), since for the TCEQ to effectively enforce the emission limits in 30 TAC §106.4(a) as emission thresholds, all emission limits must apply. As provided by 30 TAC §106.4(a)(2) and (3), an owner/operator shall not claim a PBR authorization if the facility is subject to major New Source Review. The practical and legal effect of the language in 30 TAC § 106.4 is that if a facility does not emit a pollutant, then the potential to emit for that particular pollutant is zero, and thus, the facility is not authorized to emit the pollutant pursuant to the PBR.

The permit holder is required to keep records for demonstrating compliance with PBRs in accordance with 30 TAC § 106.8 for the following categories:

- As stated in 30 TAC § 106.8(a), the permit holder is not required to keep records for de minimis sources as designated in 30 TAC § 116.119.
- As stated in 30 TAC § 106.8(b) for PBRs on the insignificant activities list, the permit holder is required to provide information that would demonstrate compliance with the general requirements of 30 TAC § 106.4.
- As stated in 30 TAC § 106.8(c) for all other PBRs, the permit holder must maintain sufficient records to demonstrate compliance with the general requirements specified in 30 TAC § 106.4 and to demonstrate compliance with the emission limits and any specific conditions of the PBR as applicable.

The application, or a previously submitted application, contains a PBR Supplemental Table. This table provides supplemental information for all PBR authorizations at the site or application area, including PBRs that are not listed on the OP-REQ1 form. PBRs that are not listed on the OP-REQ1 form authorize emission units that the TCEQ has determined are insignificant sources of emissions (IEUs). PBRs are enforceable through permit condition number **11**. The EPA gives States broad discretion in prescribing monitoring, recordkeeping, and reporting for generally applicable requirements that cover insignificant emission units. (see EPA *White Paper Number 2 for Improved Implementation of the Part 70 Operating Permits Program*). Federal regulations specifically identify recordkeeping as an appropriate level of monitoring necessary to assure compliance with the requirements applicable to an emissions unit. Permitting authorities have the best sense of where it is appropriate to conclude that periodic monitoring is not necessary for IEUs, when state program rules already provide sufficient monitoring for these units.

In the case of IEUs in particular, the recordkeeping in 30 TAC §106.8 is sufficient because the units do not have the potential to violate emission limitations or other requirements under normal operating conditions. In particular, where the establishment of a regular program of monitoring would not significantly enhance the ability of the permit to assure compliance with the applicable requirement, the permitting authority can provide that the applicable requirement has monitoring sufficient to yield reliable data that is representative of the emission unit's compliance with the limitations. Therefore, for IEUs compliance with 30 TAC §106.8 is sufficient to meet federal monitoring requirements.

The PBR records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, or parametric monitoring. The PBR records also satisfy the federal operating permit periodic monitoring requirements of 30 TAC § 122.142(c) as they are representative of the emission unit's compliance with 30 TAC Chapter 106.

Emission Units and Emission Points

In air permitting terminology, any source capable of generating emissions (for example, an engine or a sandblasting area) is called an Emission Unit. For purposes of Title V, emission units are specifically listed in the operating permit when they have applicable requirements other than New Source Review (NSR), or when they are listed in the permit shield table.

The actual physical location where the emissions enter the atmosphere (for example, an engine stack or a sand-blasting yard) is called an emission point. For New Source Review preconstruction permitting purposes, every emission unit has an associated emission point. Emission limits are listed in an NSR permit, associated with an emission point. This list of emission points and emission limits per pollutant is commonly referred to as the “Maximum Allowable Emission Rate Table”, or “MAERT” for short. Specifically, the MAERT lists the Emission Point Number (EPN) that identifies the emission point, followed immediately by the Source Name, identifying the emission unit that is the source of those emissions on this table.

Thus, by reference, an emission unit in a Title V operating permit is linked by reference number to an NSR authorization, and its related emission point.

Monitoring Sufficiency

Federal and state rules, 40 CFR § 70.6(a)(3)(i)(B) and 30 TAC § 122.142(c) respectively, require that each federal operating permit include additional monitoring for applicable requirements that lack periodic or instrumental monitoring (which may include recordkeeping that serves as monitoring) that yields reliable data from a relevant time period that are representative of the emission unit’s compliance with the applicable emission limitation or standard. Furthermore, the federal operating permit must include compliance assurance monitoring (CAM) requirements for emission sources that meet the applicability criteria of 40 CFR Part 64 in accordance with 40 CFR § 70.6(a)(3)(i)(A) and 30 TAC § 122.604(b).

With the exception of any emission units listed in the Periodic Monitoring or CAM Summaries in the FOP, the TCEQ Executive Director has determined that the permit contains sufficient monitoring, testing, recordkeeping, and reporting requirements that assure compliance with the applicable requirements. If applicable, each emission unit that requires additional monitoring in the form of periodic monitoring or CAM is described in further detail under the Rationale for CAM/PM Methods Selected section following this paragraph.

Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected

Periodic Monitoring:

The Federal Clean Air Act requires that each federal operating permit include monitoring sufficient to assure compliance with the terms and conditions of the permit. Most of the emission limits and standards applicable to emission units at Title V sources include adequate monitoring to show that the units meet the limits and standards. For those requirements that do not include monitoring, or where the monitoring is not sufficient to assure compliance, the federal operating permit must include such monitoring for the emission units affected. The following emission units are subject to periodic monitoring requirements because the emission units are subject to an emission limitation or standard for an air pollutant (or surrogate thereof) in an applicable requirement that does not already require monitoring, or the monitoring for the applicable requirement is not sufficient to assure compliance:

Unit/Group/Process Information	
ID No.: 2830	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-40-100
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 39 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: D132	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 85 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: D249	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 38 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: F120	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-40-100
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 2626 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: F121	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-40-100
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 1501 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: F276	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-40-100
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 339 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: F500	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-40-100
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 128 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: G126	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 54,267 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: G127	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 868 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: GRPCOLD	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-001
Pollutant: VOC	Main Standard: § 115.412(a)(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of 30 TAC § 115.412(a)(1) (A)-(F) shall be considered and reported as a deviation.	
Basis of monitoring: Maintaining monthly records of the cold solvent cleaner equipment inspections is an effective way to ensure that the system is operating in accordance with its design.	

Unit/Group/Process Information	
ID No.: M675	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 19 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: M914	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 3277 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Unit/Group/Process Information	
ID No.: Z757	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7300-20-40
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: Fuel Flow	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: A fuel flow rate of greater than 892 MMscf shall be reported as a deviation.	
Basis of monitoring: It is widely practiced and accepted to use performance tests, manufacturer's recommendations, engineering calculations and/or historical data to establish a correlation between fuel consumption and emission rates. In situations where such a correlation exists, measuring, calculating and recording the fuel consumption rate indicates whether the emission limitation or standard is being met.	

Obtaining Permit Documents

The New Source Review Authorization References table in the FOP specifies all NSR authorizations that apply at the permit area covered by the FOP. Individual NSR permitting files are located in the TCEQ Central File Room (TCEQ Main Campus located at 12100 Park 35 Circle, Austin, Texas, 78753, Building E, Room 103). They can also be obtained electronically from TCEQ's Central File Room Online (<https://www.tceq.texas.gov/goto/cfr-online>). Guidance documents that describe how to search electronic records, including Permits by Rule (PBRs) or NSR permits incorporated by reference into an FOP, archived in the Central File Room server are available at https://www.tceq.texas.gov/permitting/air/nav/air_status_permits.html

All current PBRs are contained in Chapter 106 and can be viewed at the following website:

https://www.tceq.texas.gov/permitting/air/permitbyrule/air_pbr_index.html

Previous versions of 30 TAC Chapter 106 PBRs may be viewed at the following website:

www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/old106list/index106.html

Historical Standard Exemption lists may be viewed at the following website:

www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/oldselist/se_index.html

Additional information concerning PBRs is available on the TCEQ website:

https://www.tceq.texas.gov/permitting/air/nav/air_pbr.html

Compliance Review

1. In accordance with 30 TAC Chapter 60, the compliance history was reviewed on **June 8, 2026.**

Site rating: 5.79 / Satisfactory Company rating: 5.79 / Satisfactory

(High < 0.10; Satisfactory ≥ 0.10 and < 55; Unsatisfactory > 55)

2. Has the permit changed on the basis of the compliance history or site/company rating? No

Available Unit Attribute Forms

OP-UA1 - Miscellaneous and Generic Unit Attributes
OP-UA2 - Stationary Reciprocating Internal Combustion Engine Attributes
OP-UA3 - Storage Tank/Vessel Attributes
OP-UA4 - Loading/Unloading Operations Attributes
OP-UA5 - Process Heater/Furnace Attributes
OP-UA6 - Boiler/Steam Generator/Steam Generating Unit Attributes
OP-UA7 - Flare Attributes
OP-UA10 - Gas Sweetening/Sulfur Recovery Unit Attributes
OP-UA11 - Stationary Turbine Attributes
OP-UA12 - Fugitive Emission Unit Attributes
OP-UA13 - Industrial Process Cooling Tower Attributes
OP-UA14 - Water Separator Attributes
OP-UA15 - Emission Point/Stationary Vent/Distillation Operation/Process Vent Attributes
OP-UA16 - Solvent Degreasing Machine Attributes
OP-UA17 - Distillation Unit Attributes
OP-UA18 - Surface Coating Operations Attributes
OP-UA19 - Wastewater Unit Attributes
OP-UA20 - Asphalt Operations Attributes
OP-UA21 - Grain Elevator Attributes
OP-UA22 - Printing Attributes
OP-UA24 - Wool Fiberglass Insulation Manufacturing Plant Attributes
OP-UA25 - Synthetic Fiber Production Attributes
OP-UA26 - Electroplating and Anodizing Unit Attributes
OP-UA27 - Nitric Acid Manufacturing Attributes
OP-UA28 - Polymer Manufacturing Attributes

OP-UA29 - Glass Manufacturing Unit Attributes
OP-UA30 - Kraft, Soda, Sulfite, and Stand-Alone Semichemical Pulp Mill Attributes
OP-UA31 - Lead Smelting Attributes
OP-UA32 - Copper and Zinc Smelting/Brass and Bronze Production Attributes
OP-UA33 - Mineral Processing Plant Attributes
OP-UA34 - Pharmaceutical Manufacturing
OP-UA35 - Incinerator Attributes
OP-UA36 - Steel Plant Unit Attributes
OP-UA37 - Basic Oxygen Process Furnace Unit Attributes
OP-UA38 - Lead-Acid Battery Manufacturing Plant Attributes
OP-UA39 - Sterilization Source Attributes
OP-UA40 - Ferroalloy Production Facility Attributes
OP-UA41 - Dry Cleaning Facility Attributes
OP-UA42 - Phosphate Fertilizer Manufacturing Attributes
OP-UA43 - Sulfuric Acid Production Attributes
OP-UA44 - Municipal Solid Waste Landfill/Waste Disposal Site Attributes
OP-UA45 - Surface Impoundment Attributes
OP-UA46 - Epoxy Resins and Non-Nylon Polyamides Production Attributes
OP-UA47 - Ship Building and Ship Repair Unit Attributes
OP-UA48 - Air Oxidation Unit Process Attributes
OP-UA49 - Vacuum-Producing System Attributes
OP-UA50 - Fluid Catalytic Cracking Unit Catalyst Regenerator/Fuel Gas Combustion Device/Claus Sulfur Recovery Plant Attributes
OP-UA51 - Dryer/Kiln/Oven Attributes
OP-UA52 - Closed Vent Systems and Control Devices
OP-UA53 - Beryllium Processing Attributes
OP-UA54 - Mercury Chlor-Alkali Cell Attributes
OP-UA55 - Transfer System Attributes
OP-UA56 - Vinyl Chloride Process Attributes
OP-UA57 - Cleaning/Depainting Operation Attributes
OP-UA58 - Treatment Process Attributes
OP-UA59 - Coke By-Product Recovery Plant Attributes
OP-UA60 - Chemical Manufacturing Process Unit Attributes
OP-UA61 - Pulp, Paper, or Paperboard Producing Process Attributes
OP-UA62 - Glycol Dehydration Unit Attributes
OP-UA63 - Vegetable Oil Production Attributes
OP-UA64 - Coal Preparation Plant Attributes