

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
Dow Hydrocarbons and Resources LLC

AUTHORIZING THE OPERATION OF  
Dow Texas Operations Freeport  
Stratton Ridge  
All Other Basic Organic Chemical Manufacturing

LOCATED AT  
Brazoria County, Texas  
Latitude 28° 35' 34" Longitude 95° 14' 34"  
Regulated Entity Number: RN100225945

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No:           O4673           Issuance Date:           July 2, 2025          

---

For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	9
New Source Review Authorization Requirements .....	9
Compliance Requirements.....	10
Risk Management Plan .....	12
Temporary Fuel Shortages (30 TAC § 112.15) .....	12
Permit Location .....	12
Permit Shield (30 TAC § 122.148) .....	12
Attachments .....	13
Applicable Requirements Summary.....	14
Additional Monitoring Requirements .....	43
Permit Shield.....	56
New Source Review Authorization References .....	63
Appendix A.....	67
Acronym List .....	68

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
  - E. Emission units subject to 40 CFR Part 63, Subparts EEEE, ZZZZ, and DDDDD as identified in the attached Applicable Requirements Summary table are subject to

30 TAC Chapter 113, Subchapter C, §§ 113.880, 113.1090, and 113.1130 which incorporate the 40 CFR Part 63 Subparts by reference.

- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 101.302 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
  - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
- (i) Title 30 TAC § 101.352 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
  - (v) Title 30 TAC § 101.359 (relating to Reporting)
  - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
  - (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- H. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 101.372 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
  - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit

- I. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 6 (Highly Reactive Volatile Organic Compound Emissions Cap and Trade Program) requirements:
  - (i) Title 30 TAC § 101.392 (relating to Exemptions)
  - (ii) Title 30 TAC § 101.401 (relating to Level of Activity Certification)
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
  - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
  - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
    - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
    - (ii) Title 30 TAC § 111.111(a)(1)(E)
    - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
    - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic

monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
  - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under

30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
  - (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
  - (2) Records of all observations shall be maintained.
  - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (4) Compliance Certification:
- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- D. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- E. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
  - (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
  - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
5. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter H, Division 1 for pressure relief devices not controlled by a flare:
- A. Title 30 TAC § 115.725(c)
  - B. Title 30 TAC § 115.725(c)(1), (c)(1)(A) - (C)

- C. Title 30 TAC § 115.725(c)(2)
  - D. Title 30 TAC § 115.725(c)(3), (c)(3)(A) - (E)
  - E. Title 30 TAC § 115.725(c)(4)
  - F. Title 30 TAC § 115.725(l)
  - G. Title 30 TAC § 115.726(c), (c)(1) - (4)
6. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams having no potential to emit HRVOC.
7. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams from sources exempt under 30 TAC § 115.727(c)(3).
8. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
  - B. Title 40 CFR § 60.8 (relating to Performance Tests)
  - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
  - D. Title 40 CFR § 60.12 (relating to Circumvention)
  - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
  - F. Title 40 CFR § 60.14 (relating to Modification)
  - G. Title 40 CFR § 60.15 (relating to Reconstruction)
  - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
9. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 61.05 (relating to Prohibited Activities)
  - B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)
  - C. Title 40 CFR § 61.09 (relating to Notification of Start-up)
  - D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)
  - E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)
  - F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)
  - G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)
  - H. Title 40 CFR § 61.15 (relating to Modification)

- I. Title 40 CFR § 61.19 (relating to Circumvention)
10. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
11. For the transfer of site remediation materials subject to 40 CFR Part 63, Subpart GGGGG off-site to another facility, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1160 incorporated by reference):
- A. Title 40 CFR § 63.7936(a), for the transfer of site remediation materials
  - B. Title 40 CFR § 63.7936(b) and (b)(1), for transfer to a landfill or land disposal unit
  - C. Title 40 CFR § 63.7936(b) and (b)(2), for transfer to a facility subject to 40 CFR Part 63, Subpart DD
  - D. Title 40 CFR § 63.7936(b), (b)(3), and (b)(3)(i) - (iv), for transfer to a facility managing the site remediation material according to the requirements of 40 CFR Part 63, Subpart GGGGG
  - E. Title 40 CFR § 63.7952(a)(10), for recordkeeping requirements
12. For containers managing remediation materials subject to 40 CFR Part 63, Subpart GGGGG, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.1160 incorporated by reference):
- A. Title 40 CFR § 63.922(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 1 Controls)
  - B. Title 40 CFR § 63.923(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 2 Controls)
  - C. Title 40 CFR § 63.925(a)(1) - (8), and (b)(1) - (3) (relating to Test Methods and Procedures)
  - D. Title 40 CFR § 63.926(a)(1) - (3) (relating to Inspection and Monitoring Requirements)
  - E. Title 40 CFR § 63.7900(a), for emissions limitations and work practice standards
  - F. Title 40 CFR § 63.7900(b), (b)(1), and (b)(2), for emissions limitations and work practice standards
  - G. Title 40 CFR § 63.7900(b)(3) and (b)(3)(i) - (ii), for emissions limitations and work practice standards
  - H. Title 40 CFR § 63.7901(b) and (b)(1), for initial demonstration of compliance
  - I. Title 40 CFR § 63.7901(b)(2), for initial demonstration of compliance
  - J. Title 40 CFR § 63.7901(c), (c)(1), and (c)(2), for initial demonstration of compliance
  - K. Title 40 CFR § 63.7901(d), and (d)(1) - (4), for initial demonstration of compliance
  - L. Title 40 CFR § 63.7902(a), for inspection and monitoring requirements

- M. Title 40 CFR § 63.7903(b) and (b)(1), for continuous demonstration of compliance
  - N. Title 40 CFR § 63.7903(b)(2), (b)(2)(i), (b)(2)(ii), for continuous demonstration of compliance
  - O. Title 40 CFR § 63.7903(c), (c)(1) - (4), (c)(4)(i), (c)(4)(ii), and (c)(5), for continuous demonstration of compliance
  - P. Title 40 CFR § 63.7903(d), (d)(1) - (5), (d)(5)(i), and (d)(5)(ii), for continuous demonstration of compliance
  - Q. Title 40 CFR § 63.7941(g), for initial demonstration of compliance
  - R. Title 40 CFR § 63.7941(i), for initial demonstration of compliance
13. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

#### **Additional Monitoring Requirements**

14. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

#### **New Source Review Authorization Requirements**

15. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated January 6, 2026 in the application for project 39591), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements

- B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield
16. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
17. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
18. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
- A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
  - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
  - C. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

### **Compliance Requirements**

19. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
20. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
- A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
    - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
      - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
  - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).

- C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.

21. Use of Emission Credits to comply with applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
  - (i) Title 30 TAC Chapter 115
  - (ii) Title 30 TAC Chapter 117
  - (iii) Offsets for Title 30 TAC Chapter 116
- B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
  - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
  - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
  - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
  - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
  - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

22. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
  - (i) Title 30 TAC Chapter 115
  - (ii) Title 30 TAC Chapter 117
  - (iii) If applicable, offsets for Title 30 TAC Chapter 116
  - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
  - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
  - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4

- (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

### **Risk Management Plan**

23. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

### **Temporary Fuel Shortages (30 TAC § 112.15)**

24. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
- A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
  - B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
  - C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
  - D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

### **Permit Location**

25. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

### **Permit Shield (30 TAC § 122.148)**

26. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

**Applicable Requirements Summary**

**Unit Summary** ..... 15

**Applicable Requirements Summary** ..... 20

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

**Unit Summary**

<b>Unit/Group/ Process ID No.</b>	<b>Unit Type</b>	<b>Group/Inclusive Units</b>	<b>SOP Index No.</b>	<b>Regulation</b>	<b>Requirement Driver</b>
BSRSR617	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BSRSRF200	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSRSRF200	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-01	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
BSRSRF402	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSRSRF402	FLARES	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
BSRSRF402	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-01	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
BSRSRF402	FLARES	N/A	60A-01	40 CFR Part 60, Subpart A	No changing attributes.
BSRSRFMNF	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSRSRFMNF	FLARES	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
BSRSRFMNF	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-01	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
BSRSRFMW1	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSRSRFMW1	FLARES	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
BSRSRFMW1	EMISSION POINTS/STATIONARY	N/A	R5121-01	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

**Unit Summary**

<b>Unit/Group/ Process ID No.</b>	<b>Unit Type</b>	<b>Group/Inclusive Units</b>	<b>SOP Index No.</b>	<b>Regulation</b>	<b>Requirement Driver</b>
	VENTS/PROCESS VENTS				
BSRSRFUBRK	FUGITIVE EMISSION UNITS	N/A	R5780-01	30 TAC Chapter 115, HRVOC Fugitive Emissions	No changing attributes.
BSRSRFUBRK	FUGITIVE EMISSION UNITS	N/A	61J-ALL	40 CFR Part 61, Subpart J	No changing attributes.
BSRSRFUBRK	FUGITIVE EMISSION UNITS	N/A	61V-ALL	40 CFR Part 61, Subpart V	No changing attributes.
BSRSRFUDOW	FUGITIVE EMISSION UNITS	N/A	R5780-01	30 TAC Chapter 115, HRVOC Fugitive Emissions	No changing attributes.
BSRSRFUSTV	FUGITIVE EMISSION UNITS	N/A	R5780-01	30 TAC Chapter 115, HRVOC Fugitive Emissions	No changing attributes.
BSRSRGE14	SRIC ENGINES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSRSRGE14	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
BSRSRGE55A	SRIC ENGINES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSRSRGE55A	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
BSRSRH575	PROCESS HEATERS/FURNACES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSRSRH575	PROCESS HEATERS/FURNACES	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BSRSRH628	PROCESS HEATERS/FURNACES	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BSRSRHDHT	PROCESS HEATERS/FURNACES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.

**Unit Summary**

<b>Unit/Group/ Process ID No.</b>	<b>Unit Type</b>	<b>Group/Inclusive Units</b>	<b>SOP Index No.</b>	<b>Regulation</b>	<b>Requirement Driver</b>
BSRSRHDHT	PROCESS HEATERS/FURNACES	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BSRSRHET1	PROCESS HEATERS/FURNACES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSRSRHET1	PROCESS HEATERS/FURNACES	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BSRSRHET2	PROCESS HEATERS/FURNACES	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSRSRHET2	PROCESS HEATERS/FURNACES	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BSRSRLR615	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BSRSRLR615	LOADING/UNLOADING OPERATIONS	N/A	63EEEE-01	40 CFR Part 63, Subpart EEEE	No changing attributes.
BSRSROE1	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSRSROE1	FLARES	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
BSRSROE1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-01	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
BSRSRPLHC1	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BSRSRPLHC2	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BSRSRS401	VOLATILE ORGANIC COMPOUND WATER	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.

**Unit Summary**

<b>Unit/Group/ Process ID No.</b>	<b>Unit Type</b>	<b>Group/Inclusive Units</b>	<b>SOP Index No.</b>	<b>Regulation</b>	<b>Requirement Driver</b>
	SEPARATORS				
BSRSRSC301	SOLVENT DEGREASING MACHINES	N/A	R5412-01	30 TAC Chapter 115, Degreasing Processes	No changing attributes.
BSRSRSCO1	SOLVENT DEGREASING MACHINES	N/A	R5412-01	30 TAC Chapter 115, Degreasing Processes	No changing attributes.
BSRSRSP626	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.
BSRSRST615	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BSRSRST615	STORAGE TANKS/VESSELS	N/A	63EEEE-01	40 CFR Part 63, Subpart EEEE	No changing attributes.
BSRSRST616	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BSRSRST616	STORAGE TANKS/VESSELS	N/A	63EEEE-01	40 CFR Part 63, Subpart EEEE	No changing attributes.
BSRSRTL1	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	Alternate Control Requirement (ACR) = Using the 90% overall control option specified in 30 TAC § 115.213(b)., True Vapor Pressure = True vapor pressure is greater than or equal to 0.5 and less than 11.0 psia, the overall emission controls are at least 90%, and an initial control plan and annual report has been submitted., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control

**Unit Summary**

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Device Type = No control device., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
BSRSRTL1	LOADING/UNLOADING OPERATIONS	N/A	R5211-02	30 TAC Chapter 115, Loading and Unloading of VOC	Alternate Control Requirement (ACR) = No alternate control requirements are being utilized., True Vapor Pressure = True vapor pressure less than 0.5 psia.
BSRSRVSTV	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
PROSDO	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting VOC content of the cleaning solution to 0.42 lb VOC/gal of solution, as applied.
PROSDO	CLEANING/DEPAINTING OPERATION	N/A	R5460-02	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BSRSR617	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
BSRSRF200	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
BSRSRF200	EP	R5121-01	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
BSRSRF402	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
BSRSRF402	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6)	[G]§ 115.725(d)(1) § 115.725(d)(2) §	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1)	§ 115.725(n) § 115.726(a)(1)(B)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n)	and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7)	§ 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	
BSRSRF402	EP	R5121-01	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
BSRSRF402	CD	60A-01	Opacity	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(5) § 60.18(c)(6)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(6)	None	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18(e)				
BSRSRFMN F	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
BSRSRFMN F	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B)
BSRSRFMN F	EP	R5121-01	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).			
BSRSRFM W1	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
BSRSRFM W1	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BSRSRFM W1	EP	R5121-01	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) equal to or less than 100 pounds in any continuous 24-hour period is exempt from §115.121(a)(1) of this title.	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
BSRSRFUB RK	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Heat exchanger heads, sight glasses, meters, gauges, sampling connections, bolted manways, hatches, sump covers, junction box vents, and covers and seals on VOC water separators within the process unit or processes listed in §115.780(a) in which a HRVOC is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)
BSRSRFUB RK	EU	61J-ALL	Benzene	40 CFR Part 61, Subpart J	§ 61.112(a) § 61.112(b)	Each owner or operator subject to this subpart shall comply with the requirements of 40 CFR 61, Subpart V - National Emission Standard for Equipment Leaks (Fugitive Emission Sources).	None	None	None
BSRSRFUB	EU	61V-ALL	VHAP	40 CFR Part 61,	§ 61.242-1(e)	Equipment that is in vacuum	None	[G]§ 61.246(e)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
RK				Subpart V		service is excluded from the requirements of §61.242-2 to §61.242-11, if it is identified as required in §61.246(e)(5).			
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-2 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pumps. §61.242-2(a)-(g)	[G]§ 61.242-2 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for flanges and other connectors. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-9 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d)	Each product accumulator vessel shall be equipped with a closed-vent system to capture and transport any leakage from the vessel to a control device as in §61.242-11, except in §61.242-1(c).	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in liquid service. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-5 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d)	Comply with standards for sampling connection systems. §61.242-5(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 61.242-10				
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-3 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for compressors. §61.242-3(a)-(i)	[G]§ 61.242-3 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-4 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in gas/vapor service. §61.242-4(a)-(c)	[G]§ 61.242-4 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-7 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.243-1 [G]§ 61.243-2	Comply with standards for valves. §61.242-7(a)-(h)	[G]§ 61.242-7 [G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) § 61.247(d) [G]§ 61.247(e)
BSRSRFUB RK	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-6 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for open-ended valves or lines. §61.242-6(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
BSRSRFUD OW	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B)	Heat exchanger heads, sight glasses, meters, gauges, sampling connections, bolted manways, hatches, sump covers, junction box vents, and covers and seals on VOC water separators within the process unit or processes listed in	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	§115.780(a) in which a HRVOC is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	
BSRSRFUS TV	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Heat exchanger heads, sight glasses, meters, gauges, sampling connections, bolted manways, hatches, sump covers, junction box vents, and covers and seals on VOC water separators within the process unit or processes listed in §115.780(a) in which a HRVOC is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)
BSRSRGE1 4	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) [G]§ 117.345(e) § 117.8010

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a) § 117.340(h) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(f)(9)	[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRGE14	EU	R7ICI-01	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) [G]§ 117.345(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		
BSRSRGE14	EU	63ZZZZ-01	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(a)-Table 1a.1.b § 63.6595(c) § 63.6600(a)-Table 1b.1.a § 63.6600(a)-Table 1b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6630(b) § 63.6640(b)	For each 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, except during periods of startup, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 % O2.	§ 63.6610(a) § 63.6610(b) § 63.6610(c) § 63.6615 § 63.6620(a) § 63.6620(a)-Table 3.3 § 63.6620(a)-Table 4.3.a.i § 63.6620(a)-Table 4.3.a.ii § 63.6620(a)-Table 4.3.a.iii § 63.6620(a)-Table 4.3.a.iv § 63.6620(b) § 63.6620(b)(1) § 63.6620(d) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)-Table 5.9.a.i § 63.6630(a)-Table 5.9.a.ii § 63.6630(a)-Table 5.9.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table 6.7.a.i § 63.6640(a)-Table 6.7.a.ii § 63.6640(a)-Table	§ 63.6620(i) § 63.6630(a)-Table 5.9.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) [G]§ 63.6655(b) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table 7.1.a.i § 63.6650(a)-Table 7.1.b § 63.6650(a)-Table 7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(e) § 63.6650(f)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							6.7.a.iii § 63.6640(a)-Table 6.7.a.iv § 63.6640(a)-Table 6.7.a.v § 63.6640(b)		
BSRSRGE5 5A	EU	R7ICI-01	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(6)	None
BSRSRGE5 5A	EU	63ZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.6 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(j) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary SI RICE and black start stationary SI RICE with a site rating less than or equal to 500 HP, located at a major source, you must comply with the requirements as specified in Table 2c.6.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(j) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
BSRSRH57	EU	R7ICI-01	CO	30 TAC Chapter	§ 117.310(c)(1)	CO emissions must not	[G]§ 117.335(a)(1)	§ 117.345(a)	§ 117.335(b)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
5				117, Subchapter B	§ 117.310(c)(1)(B) § 117.310(c)(3)	exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	§ 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRH575	EU	R7ICI-01	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRH575	EU	63DDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.2	A new or existing boiler or process heater with heat	§ 63.7510(g) § 63.7515(d)	§ 63.7555(a) § 63.7555(a)(1)	[G]§ 63.7521(g) § 63.7530(e)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(11) § 63.7540(a)(13)	input capacity of less than 10 million Btu per hour, but greater than 5 million Btu per hour, in a unit designed to burn gas 1 must conduct a tune-up of the boiler or process heater biennially as specified in § 63.7540.	[G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	§ 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
BSRSRH28	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.1 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(12) § 63.7540(a)(13)	For a new or existing boiler or process heater with a heat input capacity of less than or equal to 5 million Btu per hour designed to burn gas 1, a tune-up of the boiler or process heater must be conducted every 5 years as specified in § 63.7540.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
BSRSRHDHT	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							Summary		
BSRSRHDH T	EU	R7ICI-01	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRHDH T	EU	63DDDDD -01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.1 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(12) § 63.7540(a)(13)	For a new or existing boiler or process heater with a heat input capacity of less than or equal to 5 million Btu per hour designed to burn gas 1, a tune-up of the boiler or process heater must be conducted every 5 years as specified in § 63.7540.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
BSRSRHET 1	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary		[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRHET 1	EU	R7ICI-01	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRHET 1	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.7540(a)(10) § 63.7540(a)(13)	conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7560(b) § 63.7560(c)	[G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
BSRSRHET 2	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRHET 2	EU	R7ICI-01	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(p)(3)	also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
BSRSRHET 2	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
BSRSRLR6 15	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	As an alternative to §115.212(a)(1), loading operations may elect to achieve a 90% overall control of emissions at the account when loading VOC with true vapor pressure greater than 0.5 psia, but less than 11.0 psia, provided that the conditions specified in §115.213(b)(1)-(6) are met.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
BSRSRLR6 15	EU	63EEEE-01	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2343(c)	For each transfer rack subject to this subpart that loads organic liquids but is	None	§ 63.2343(c)(3)	[G]§ 63.2343(c)(1) § 63.2343(c)(2)(i) § 63.2343(c)(2)(ii)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						not subject to control based on the criteria specified in Table 2 to this subpart, items 7 through 10, you must comply with the requirements specified in §63.2343(c)(1)-(3).			§ 63.2386(b) [G]§ 63.2386(b)(1) [G]§ 63.2386(b)(2) § 63.2386(b)(3) § 63.2386(b)-Table 11.1.a § 63.2386(c) § 63.2386(c)(1) § 63.2386(c)(10)(i) § 63.2386(c)(10)(ii) § 63.2386(c)(2) § 63.2386(c)(3) § 63.2386(d) § 63.2386(d)(4)(ii) § 63.2386(f)
BSRSROE1	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
BSRSROE1	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) §	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B)

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n)		§ 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7)		
BSRSROE1	EP	R5121-01	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
BSRSRPLH C1	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BSRSRPLH C2	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
BSRSRS401	EU	R5131-01	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(3)	§ 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						recovery system which satisfies the provisions of §115.131(a) of this title.	§ 115.136(a)(4)		
BSRSRSC301	EU	R5412-01	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.412(a)(1) § 115.411(a)(1) § 115.411(a)(2) [G]§ 115.412(a)(1)(A) § 115.412(a)(1)(C) § 115.412(a)(1)(D) [G]§ 115.412(a)(1)(F)	No person shall own or operate a system utilizing a VOC for the cold solvent cleaning of objects without the controls listed in §115.412(a)(1)(A)-(F), except as exempted in §115.411.	[G]§ 115.415(1) § 115.415(4) ** See Periodic Monitoring Summary	None	None
BSRSRSCO1	EU	R5412-01	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.412(1) § 115.411(1) § 115.411(2) [G]§ 115.412(1)(A) § 115.412(1)(C) § 115.412(1)(D) [G]§ 115.412(1)(F)	No person shall own or operate a system utilizing a VOC for the cold solvent cleaning of objects without the controls listed in §115.412(1)(A)-(F), except as exempted in §115.411.	[G]§ 115.415(1) § 115.415(3) ** See Periodic Monitoring Summary	None	None
BSRSRSP626	EU	R5131-01	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor recovery system which satisfies the provisions of §115.131(a) of this title.	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	None
BSRSRST615	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
BSRSRST6 15	EU	63EEEE-01	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2343(b)	Except as specified in §63.2343(b)(4), for each storage tank subject to this subpart having a capacity of 18.9 cubic meters (5,000 gallons) or more that is not subject to control based on the criteria specified in Table 2 to this subpart, items 3 through 6 or in Table 2b to this subpart, items 1 through 3, you must comply with the requirements specified in §63.2343(b)(1) through (3).	None	§ 63.2343(b)(3)	[G]§ 63.2343(b)(1)(i) § 63.2343(b)(2)(i) § 63.2343(b)(2)(ii) § 63.2386(b) [G]§ 63.2386(b)(1) [G]§ 63.2386(b)(2) § 63.2386(b)(3) § 63.2386(b)-Table 11.1.a § 63.2386(c) § 63.2386(c)(1) § 63.2386(c)(10)(i) § 63.2386(c)(10)(ii) § 63.2386(c)(2) § 63.2386(c)(3) § 63.2386(d) § 63.2386(d)(4)(i) § 63.2386(f)
BSRSRST6 16	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						paragraph for crude oil and condensate.			
BSRSRST616	EU	63EEEE-01	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2343(b)	Except as specified in §63.2343(b)(4), for each storage tank subject to this subpart having a capacity of 18.9 cubic meters (5,000 gallons) or more that is not subject to control based on the criteria specified in Table 2 to this subpart, items 3 through 6 or in Table 2b to this subpart, items 1 through 3, you must comply with the requirements specified in §63.2343(b)(1) through (3).	None	§ 63.2343(b)(3)	[G]§ 63.2343(b)(1)(i) § 63.2343(b)(2)(i) § 63.2343(b)(2)(ii) § 63.2386(b) [G]§ 63.2386(b)(1) [G]§ 63.2386(b)(2) § 63.2386(b)(3) § 63.2386(b)-Table 11.1.a § 63.2386(c) § 63.2386(c)(1) § 63.2386(c)(10)(i) § 63.2386(c)(10)(ii) § 63.2386(c)(2) § 63.2386(c)(3) § 63.2386(d) § 63.2386(d)(4)(i) § 63.2386(f)
BSRSRTL1	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	As an alternative to §115.212(a)(1), loading operations may elect to achieve a 90% overall control of emissions at the account when loading VOC with true vapor pressure greater than 0.5 psia, but less than 11.0 psia, provided that the conditions specified in §115.213(b)(1)-(6) are met.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
BSRSRTL1	EU	R5211-02	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

**Applicable Requirements Summary**

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the requirements of this division, except as specified.			
BSRSRVST V	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
PROSDO	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(1) [G]§ 115.463(c)	The owner or operator shall limit the volatile organic compounds (VOC) content of cleaning solutions to 0.42 pound of VOC per gallon of solution (lb VOC/gal solution), as applied.	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(5)	None
PROSDO	PRO	R5460-02	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(2) [G]§ 115.463(c)	The owner or operator shall limit the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(5)	None

**Additional Monitoring Requirements**

**Periodic Monitoring Summary ..... 44**

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRH575	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
<b>Monitoring Information</b>	
Indicator: CO Concentration	
Minimum Frequency: Every 5 years	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration equals 400 ppm by volume at 3.0% O2 dry basis.	
<p>Periodic Monitoring Text: The permit holder must conduct a tune-up of the process heater every 5 years as specified in 40 CFR 63.7540(a)(10)(i)-(vi). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Measurement may be taken using a portable CO analyzer. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O2 on a dry basis shall be considered and reported as a deviation</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRH575	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
<b>Monitoring Information</b>	
Indicator: Fuel gas usage.	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Maximum annual average fuel gas usage equals 6373 SCF/hr.	
Periodic Monitoring Text: Measure fuel gas usage when the heater is in operation. Monitor shall be operated at least 95% of the time when the heater is operational, averaged over a rolling 12 month period. Any monitoring data above the maximum limit shall be considered and reported as a deviation.	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRHDHT	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
<b>Monitoring Information</b>	
Indicator: CO concentration	
Minimum Frequency: Every 5 years	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration equals 400 ppm by volume at 3.0% O2 dry basis.	
<p>Periodic Monitoring Text: The permit holder must conduct a tune-up of the process heater every 5 years as specified in 40 CFR 63.7540(a)(10)(i)-(vi). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Measurement may be taken using a portable CO analyzer. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O2 on a dry basis shall be considered and reported as a deviation.</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRHDHT	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
<b>Monitoring Information</b>	
Indicator: Fuel gas usage	
Minimum Frequency: Hourly	
Averaging Period: N/A	
Deviation Limit: Maximum annual average fuel gas usage equals 3725 SCF/hr.	
Periodic Monitoring Text: Measure fuel gas usage when the heater is in operation. Monitor shall be operated at least 95% of the time when the heater is operational, averaged over a rolling 12-month period. Any monitoring data above the maximum limit shall be considered and reported as a deviation.	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BSRSRHET1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration equals 400 ppm by volume at 3.0% O2 dry basis.	
<p>Periodic Monitoring Text: The permit holder shall comply with the annual process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Measurement may be taken using a portable CO analyzer. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O2 on a dry basis shall be considered and reported as a deviation.</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRHET2	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: R7ICI-01
Pollutant: CO	Main Standard: § 117.310(c)(1)
<b>Monitoring Information</b>	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration equals 400 ppm by volume at 3.0% O2 dry basis.	
<p>Periodic Monitoring Text: The permit holder shall comply with the annual process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Measurement may be taken using a portable CO analyzer. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O2 on a dry basis shall be considered and reported as a deviation.</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRSC301	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-01
Pollutant: VOC	Main Standard: § 115.412(a)(1)
<b>Monitoring Information</b>	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of 30 TAC Chapter 115.412(1)(A)-(F).	
Periodic Monitoring Text: Inspect equipment and record data monthly to ensure compliance with any applicable requirements in § 115.412(a)(1)(A)-(F). Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of § 115.412(a)(1)(A)-(F) shall be considered and reported as a deviation.	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRSCO1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-01
Pollutant: VOC	Main Standard: § 115.412(1)
<b>Monitoring Information</b>	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: N/A	
Deviation Limit: Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of 30 TAC Chapter 115.412(1)(A)-(F).	
Periodic Monitoring Text: Inspect equipment and record data monthly to ensure compliance with any applicable requirements in § 115.412(1)(A)-(F). Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of § 115.412(1)(A)-(F) shall be considered and reported as a deviation.	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BRSRST615	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-01
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: N/A	
Deviation Limit: Liquid level below fill pipe level.	
<p>Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BSRSRST615	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-01
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: If the repairs are not completed prior to refilling the storage vessel.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

### Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: BRSRST616	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-01
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: N/A	
Deviation Limit: Liquid level below fill pipe level.	
<p>Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BSRSRST616	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-01
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: If repairs are not completed prior to refilling the storage vessel.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

**Permit Shield**

**Permit Shield ..... 57**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
BSRSR617	N/A	40 CFR Part 60, Subpart K	Storage capacity is less than 40,000 gallons.
BSRSR617	N/A	40 CFR Part 60, Subpart Ka	Storage capacity is less than 40,000 gallons.
BSRSR617	N/A	40 CFR Part 60, Subpart Kb	Storage capacity is less than 19,800 gallons.
BSRSR617	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSR617	N/A	40 CFR Part 61, Subpart Y	This tank does not store benzene.
BSRSR617	N/A	40 CFR Part 63, Subpart G	The process unit does not manufacture as a primary product one or more of the chemicals listed in paragraphs §63.100(b)(1) or §63.100(b)(1)(ii).
BSRSR617	N/A	40 CFR Part 63, Subpart OO	No applicable subpart of 40 CFR Parts 60, 61, or 63 references the use of 40 CFR Part 63, Subpart OO.
BSRSRD404	N/A	40 CFR Part 61, Subpart J	The source does not operate in benzene service.
BSRSRF200	N/A	40 CFR Part 60, Subpart A	The flare is not controlling a source subject to 40 CFR Part 60 or 61.
BSRSRF200	N/A	40 CFR Part 63, Subpart A	Flare is not required by another subpart under 40 CFR Part 63.
BSRSRF402	N/A	40 CFR Part 63, Subpart A	The flare is not required by another subpart under 40 CFR Part 63.
BSRSRFMNF	N/A	40 CFR Part 60, Subpart A	The flare is not controlling a source subject to 40 CFR Part 60 or 61.
BSRSRFMNF	N/A	40 CFR Part 63, Subpart A	The flare is not required by another subpart under 40 CFR Part 63.
BSRSRFMW1	N/A	40 CFR Part 60, Subpart A	The flare is not controlling a source subject to 40

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			CFR Part 60 or 61.
BSRSRFMW1	N/A	40 CFR Part 63, Subpart A	The flare is not required by another subpart under 40 CFR Part 63.
BSRSRFUBRK	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The site does not contain a synthetic organic chemical manufacturing process, or natural gas/gasoline processing, or a petroleum refinery.
BSRSRFUDOW	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The site does not contain a synthetic organic chemical manufacturing process, or a natural gas/gasoline processing, or a petroleum refinery.
BSRSRFUDOW	N/A	40 CFR Part 61, Subpart J	The source does not operate in benzene service.
BSRSRFUDOW	N/A	40 CFR Part 61, Subpart V	The source does not operate in volatile hazardous air pollutants (VHAP) service.
BSRSRFUSTV	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The site does not contain a synthetic organic chemical manufacturing process, or natural gas/gasoline processing, or a petroleum refinery.
BSRSRFUSTV	N/A	40 CFR Part 61, Subpart J	The source does not operate in benzene service.
BSRSRFUSTV	N/A	40 CFR Part 61, Subpart V	The source does not operate in volatile hazardous air pollutants (VHAP) service.
BSRSRH575	N/A	30 TAC Chapter 112, Sulfur Compounds	Not a solid fossil fuel-fired steam generator, furnace, or heater.
BSRSRH628	N/A	30 TAC Chapter 112, Sulfur Compounds	Not a solid fossil fuel-fired steam generator,

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			furnace, or heater.
BSRSRH628	N/A	30 TAC Chapter 117, Commercial	Maximum rated capacity less than 2.0 MMBtu/hr.
BSRSRH628	N/A	40 CFR Part 60, Subpart D	Heat input is less than 250 MMBtu/hr.
BSRSRH628	N/A	40 CFR Part 60, Subpart Da	Not an electric utility steam generating unit.
BSRSRH628	N/A	40 CFR Part 60, Subpart Db	Heat input is less than 100 MMBtu/hr.
BSRSRH628	N/A	40 CFR Part 60, Subpart Dc	Heat input is less than 10 MMBtu/hr.
BSRSRHDHT	N/A	30 TAC Chapter 112, Sulfur Compounds	Not a solid fossil fuel-fired steam generator, furnace, or heater.
BSRSRHET1	N/A	30 TAC Chapter 112, Sulfur Compounds	Not a solid fossil fuel-fired steam generator, furnace, or heater.
BSRSRHET2	N/A	30 TAC Chapter 112, Sulfur Compounds	Not a solid fossil fuel-fired steam generator, furnace, or heater.
BSRSROE1	N/A	40 CFR Part 60, Subpart A	The flare is not controlling a source subject to 40 CFR Part 60 or 61.
BSRSROE1	N/A	40 CFR Part 63, Subpart A	The flare is not required under 40 CFR Part 63.
BSRSRPLHC1	N/A	40 CFR Part 60, Subpart K	Does not store petroleum liquids.
BSRSRPLHC1	N/A	40 CFR Part 60, Subpart Ka	Does not store petroleum liquids.
BSRSRPLHC1	N/A	40 CFR Part 60, Subpart Kb	The vessel has a capacity greater than 39,900 gallons and stores a VOL with a maximum true vapor pressure less than 0.5 psia.
BSRSRPLHC1	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRPLHC1	N/A	40 CFR Part 61, Subpart Y	Does not store benzene.

**Permit Shield**

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

<b>Unit / Group / Process ID No.</b>	<b>Group / Inclusive Units</b>	<b>Regulation</b>	<b>Basis of Determination</b>
BSRSRPLHC1	N/A	40 CFR Part 63, Subpart OO	No applicable subparts within 60, 61, or 63 reference the use of 40 CFR Part 63, Subpart OO.
BSRSRPLHC2	N/A	40 CFR Part 60, Subpart K	Does not store petroleum liquids.
BSRSRPLHC2	N/A	40 CFR Part 60, Subpart Ka	Does not store petroleum liquids.
BSRSRPLHC2	N/A	40 CFR Part 60, Subpart Kb	The vessel has a capacity greater than 39,900 gallons and stores a VOL with a maximum true vapor pressure less than 0.5 psia.
BSRSRPLHC2	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRPLHC2	N/A	40 CFR Part 61, Subpart Y	Does not store benzene.
BSRSRPLHC2	N/A	40 CFR Part 63, Subpart OO	No applicable subparts within 60, 61, or 63 reference the use of 40 CFR Part 63, Subpart OO.
BSRSRS401	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRS401	N/A	40 CFR Part 61, Subpart J	The source does not operate in benzene service.
BSRSRS401	N/A	40 CFR Part 61, Subpart V	The source does not operate in volatile hazardous air pollutants (VHAP) service.
BSRSRS401	N/A	40 CFR Part 63, Subpart VV	No applicable subpart of 40 CFR Parts 60, 61, or 63 references the use of CFR Part 63, Subpart VV.
BSRSRSC301	N/A	40 CFR Part 63, Subpart T	The solvent cleaning machine uses halogenated HAP solvents in a total concentration less than 5 percent by weight as a cleaning and/or drying agent.

**Permit Shield**

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

<b>Unit / Group / Process ID No.</b>	<b>Group / Inclusive Units</b>	<b>Regulation</b>	<b>Basis of Determination</b>
BSRSRSCO1	N/A	40 CFR Part 63, Subpart T	The solvent cleaning machine uses halogenated HAP solvents in a total concentration less than 5 percent by weight as a cleaning and/or drying agent.
BSRSRST117	N/A	30 TAC Chapter 115, Storage of VOCs	Storage capacity is less than 1,000 gallons.
BSRSRST117	N/A	40 CFR Part 60, Subpart K	Storage capacity is less than 40,000 gallons.
BSRSRST117	N/A	40 CFR Part 60, Subpart Ka	Storage capacity is less than 40,000 gallons.
BSRSRST117	N/A	40 CFR Part 60, Subpart Kb	Storage capacity is less than 19,800 gallons.
BSRSRST117	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRST117	N/A	40 CFR Part 61, Subpart Y	The tank does not store benzene.
BSRSRST615	N/A	40 CFR Part 60, Subpart K	Storage capacity is less than 40,000 gallons.
BSRSRST615	N/A	40 CFR Part 60, Subpart Ka	Storage capacity is less than 40,000 gallons.
BSRSRST615	N/A	40 CFR Part 60, Subpart Kb	Storage vessel with a capacity less than 19,800 gallons.
BSRSRST615	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRST615	N/A	40 CFR Part 61, Subpart Y	The tank does not store benzene.
BSRSRST615	N/A	40 CFR Part 63, Subpart OO	No applicable subparts within 60, 61, or 63 reference the use of 40 CFR Part 63, Subpart OO.
BSRSRST616	N/A	40 CFR Part 60, Subpart K	Storage capacity is less than 40,000 gallons.
BSRSRST616	N/A	40 CFR Part 60, Subpart Ka	Storage capacity is less than 40,000 gallons.
BSRSRST616	N/A	40 CFR Part 60, Subpart Kb	Storage vessel with capacity less than 19,800 gallons.

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
BSRSRST616	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene.
BSRSRST616	N/A	40 CFR Part 61, Subpart Y	The tank does not store benzene.
BSRSRST616	N/A	40 CFR Part 63, Subpart OO	No applicable subparts within 60, 61, or 63 reference the use of 40 CFR Part 63, Subpart OO.
BSRSRVSTV	N/A	40 CFR Part 60, Subpart K	Storage capacity is less than 40,000 gallons.
BSRSRVSTV	N/A	40 CFR Part 60, Subpart Ka	Storage capacity is less than 40,000 gallons.
BSRSRVSTV	N/A	40 CFR Part 60, Subpart Kb	Storage vessel with capacity less than 19,800 gallons.
BSRSRVSTV	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
BSRSRVSTV	N/A	40 CFR Part 61, Subpart Y	The tank does not store benzene.
BSRSRVSTV	N/A	40 CFR Part 63, Subpart OO	No applicable subparts within 60, 61, or 63 reference the use of 40 CFR Part 63, Subpart OO.
PROSRNG	N/A	40 CFR Part 63, Subpart HHH	The facility is the final end user and is not part of the natural gas transmission and storage source facilities.

**New Source Review Authorization References**

**New Source Review Authorization References ..... 64**

**New Source Review Authorization References by Emission Unit ..... 65**

### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 22072	Issuance Date: 05/07/2021
Authorization No.: 173947	Issuance Date: 09/19/2023
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000

**New Source Review Authorization References by Emissions Unit**

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
BSRSR617	TRIETHYLENE GLYCOL	22072
BSRSRD404	D-404 - LAST KNOCKOUT DRUM BEFORE FS-401 FLARE	22072
BSRSRF200	DW-6 DEHY FLARE	22072, 173947
BSRSRF200	VENTS ROUTED TO DW-6 DEHY FLARE	22072
BSRSRF402	BRINE FLARE NO.2	22072, 173947
BSRSRF402	VENTS ROUTED TO BRINE FLARE 2	22072
BSRSRFMNF	STEVENS MAIN FLARE	22072, 173947
BSRSRFMNF	VENTS ROUTED TO STEVENS MAIN FLARE	22072
BSRSRFMW1	MONITOR WELL NO.1 FLARE	22072, 173947
BSRSRFMW1	VENTS ROUTED TO MONITORING WELL NO.1 FLARE	22072
BSRSRFUBRK	BROCK PROCESS FUGITIVE AREA	22072, 106.261/11/01/2003 [152182, 157214, 157724], 106.262/11/01/2003 [157214], 106.472/09/04/2000 [157214]
BSRSRFUDOW	DOW PROCESS FUGITIVE AREA	22072, 106.261/11/01/2003 [152182]
BSRSRFUSTV	STEVENS PROCESS FUGITIVE	22072, 106.261/11/01/2003 [152182, 154273, 157724, 163128, 170207]
BSRSRGE14	C14 ENGINE EXHAUST	22072
BSRSRGE55A	GAS ENGINE EXHAUST	22072
BSRSRH575	DOWTHERM HEATER H-575	22072
BSRSRH628	DW 6 DEHY HEATER	22072
BSRSRHDHT	SALT DOME OPERATION- DOWTHERM HEATER	22072
BSRSRHET1	NORTH ETHYLENE HEATER	22072

**New Source Review Authorization References by Emissions Unit**

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
BSRSRHET2	SOUTH ETHYLENE HEATER	22072
BSRSRLR615	DW 6 HC LOADING RACK	22072
BSRSROE1	MAINTENANCE EQUIPMENT CLEARING	22072, 173947
BSRSRPLHC1	LHC SURGE POND 1	22072
BSRSRPLHC2	LHC SURGE POND 2	22072
BSRSRS401	S-401 SEPARATOR	22072
BSRSRSC301	SAFETY KLEEN DEGREASER	106.454/11/01/2001
BSRSRSCO1	SAFETY KLEEN DEGREASER	106.454/11/01/2001
BSRSRSP626	WATER SEPARATOR	22072
BSRSRST117	PETROFLO INHIBITOR STORAGE TANK	106.261/11/01/2003 [157214], 106.262/11/01/2003 [157214], 106.472/09/04/2000 [157214]
BSRSRST615	DW 6 HC TANK	22072
BSRSRST616	DW METHANOL TANK	22072
BSRSRTL1	MAINTENANCE TRUCK LOADING RACK	106.263/11/01/2001
BSRSRVSTV	T-5 (SS1) DBSA TANK AT STEVENS	22072, 106.472/09/04/2000
PROSDO	PROCESS UNIT ID FOR SDO	22072, 106.263/11/01/2001
PROSRNG	SDO NATURAL GAS DEHYDRATION UNIT	22072, 106.263/11/01/2001

\*\*This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

**Appendix A**

**Acronym List ..... 68**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO <sub>2</sub>	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound