

## Groundwater Rule on the CCR

To find out if your system had a significant deficiency call your TCEQ Regional Office.

- Any ground water system that receives an **E. coli positive ground water source sample** must include the following information in the CCR. The system must continue to inform the public annually until TCEQ determines it has been addressed.
  - the source of the fecal contamination (if the source is known);
  - the date(s) of the *E. coli* positive ground water source sample(s);
  - actions taken to address the *E. coli* contamination in the ground water source as directed by §290.116 and the date of such action;
  - for each *E. coli* contamination in the ground water source, the plan approved by the executive director and schedule for correction, including interim measures, progress to date, and any interim measures completed; and
  - for an *E. coli* positive groundwater source sample the potential health effects using the health effects language of §290.275(3).
  
- Any ground water system that receives notice from TCEQ of a **significant deficiency** must inform customers of any significant deficiency that is uncorrected at the time of the next CCR. The system must continue to inform the public annually until TCEQ determines it has been corrected. The CCR must include:
  - the nature of the significant deficiency;
  - the date the significant deficiency was identified by the executive director;
  - for each significant deficiency, the plan approved by the TCEQ and schedule for correction, including interim measures, progress to date, and any interim measures completed; and
  - if corrected before the next report, the nature of the significant deficiency, how the deficiency was corrected, and the date of the corrections.