




Revised Total Coliform Rule (RTCR) Repeat Sampling Requirements

What to do when notified of a **POSITIVE ROUTINE (distribution) sample** result?



Within **24 HOURS** Collect **THREE (3) REPEAT SAMPLES:**

- **Original** sample site
- **Downstream** (within 5 connections)
- **Upstream** (within 5 connections)

Fewer than 3 connections? Call the RTCR Program at (512) 239 4691


☆ Mark all 3 as REPEAT

Groundwater wells?



In addition to repeats, Collect one (1) **RAW WELL** sample from **EACH** active well for **EACH** positive sample

△ Mark as RAW WELL



No wells?

Provide sample ID and collection date of the originating positive

◇ For ALL SAMPLES

Sample Identification/Location Use Specific Address/Location identified in Sample Siting Plan	Sample Type (✓one)					Collected				Replacement	Sample ID & Date of Originating Sample ◆	Circle "F" for Free, "T" for Total (mg/L)		
	Routine	★ Repeat	▲ Raw Well	Special*	Construction*	Date			Time					
Raw Wells – Use Source ID for Well Sampled (Example: G1234567A)						Month	Day	Year	Please circle AM or PM					
121 Example Rd (upstream)		✓				5	9	18	7:12	am pm		508123 5/8/18	1.39	F T
123 Example Rd (original)		✓				5	9	18	7:38	am pm		508123 5/8/18	1.24	F T
125 Example Rd (downstream)		✓				5	9	18	7:47	am pm		508123 5/8/18	1.17	F T
G1234567A			✓			5	9	18	8:32	am pm		508123 5/8/18	0.00	F T
G1234567B			✓			5	9	18	9:06	am pm		508123 5/8/18	0.00	F T

Note: Public Water Systems (PWSs) should contact the RTCR Program at (512) 239-4691 after receiving notification of a positive sample result.