



Turnstone EH&S Inc. Laboratory Air Sample Analysis

Encycle Asbestos Abatement Project

Date	Wind Direction	Wind Speed	Sample #	Upwind/ Downwind	Location	Sample Result f/cc	Fiber Density	Detection Limit
7/5/2011	SE	14 MPH	A-1	Upwind	Next to Guard Shack	0.004	37.6	0.001
7/5/2011	SE	14 MPH	A-2	Downwind	SE Corner of Plant	0.005	39.5	0.001
7/6/2011	SW	4 MPH	A-1	Upwind	Next to Guard Shack	0.005	39.5	0.001
7/6/2011	SW	4 MPH	A-2	Downwind	SE Corner of Plant	0.006	48.4	0.001
7/7/2011	SW	9 MPH	A-1	Downwind	Next to Guard Shack	0.003	26.8	0.001
7/7/2011	SW	9 MPH	A-2	Upwind	SE Corner of Plant	0.004	32.5	0.001
7/8/2011	SSW	8 MPH	A-1	Downwind	Next to Guard Shack	0.005	43.3	0.001
7/8/2011	SSW	8 MPH	A-2	Upwind	SE Corner of Plant	0.006	49	0.001

All asbestos air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

