



Turnstone EH&S Inc. Laboratory Air Sample Analysis

Encycle Asbestos Abatement Project

Date	Wind Direction	Wind Speed	Sample #	Upwind/ Downwind	Location	Sample Result f/cc	Fiber Density	Detection Limit
7/11/2011	South	13 MPH	A-1	Upwind	Next to Guard Shack	0.004	32.5	0.001
7/11/2011	South	13 MPH	A-2	Downwind	SE Corner of Plant	0.005	39.5	0.001
7/12/2011	South	8 MPH	A-1	Upwind	Next to Guard Shack	0.004	32.5	0.001
7/12/2011	South	8 MPH	A-2	Downwind	SE Corner of Plant	0.005	39.5	0.001
7/13/2011	SSE	12 MPH	A-1	Downwind	Next to Guard Shack	0.004	36.9	0.001
7/13/2011	SSE	12 MPH	A-2	Upwind	SE Corner of Plant	0.003	28	0.001
7/14/2011	South	15 MPH	A-1	Downwind	Next to Guard Shack	0.003	26.8	0.001
7/14/2011	South	15 MPH	A-2	Upwind	SE Corner of Plant	0.004	34.4	0.001
7/15/2011	SSE	14 MPH	A-1	Downwind	Next to Guard Shack	0.005	47.8	0.001
7/15/2011	SSE	14 MPH	A-2	Upwind	SE Corner of Plant	0.006	56.1	0.001

All absbests air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

AIHA Accredited Laboratory #101435 TDH Laboratory License #30-0005
NIOSH 7400 Method, Rev. 3, Issue 2, 8/15/94 Estimated L.O.D. 8.9 Fibers / Square MM

5449 Bear Lane Suite 440 Corpus Christi TX 361-289-2510

