



**Turnstone EH&S Inc. Laboratory Air Sample Analysis**

**Encycle Asbestos Abatement Project**

Date	Wind Direction	Wind Speed	Sample #	Upwind/Downwind		Location	Sample Result f/cc	Fiber Density	Detection Limit
				Upwind	Downwind				
8/22/2011	South	3 MPH	A-1	Upwind	Next to Guard Shack	0.005	47.8	0.001	
8/22/2011	South	3 MPH	A-2	Downwind	SE Corner of Plant	0.006	56.1	0.001	
8/23/2011	South	8 MPH	A-1	Upwind	Next to Guard Shack	0.004	39.5	0.001	
8/23/2011	South	8 MPH	A-2	Downwind	SE Corner of Plant	0.004	35.7	0.001	
8/24/2011	South	9 MPH	A-1	Downwind	Next to Guard Shack	0.005	44.6	0.001	
8/24/2011	South	9 MPH	A-2	Upwind	SE Corner of Plant	0.004	42.7	0.001	
8/25/2011	SSW	3 MPH	A-1	Downwind	Next to Guard Shack	0.004	31.2	0.001	
8/25/2011	SSW	3 MPH	A-2	Upwind	SE Corner of Plant	0.005	45.9	0.001	
8/26/2011	ENE	3 MPH	A-1	Downwind	Next to Guard Shack	0.004	39.5	0.001	
8/26/2011	ENE	3 MPH	A-2	Upwind	SE Corner of Plant	0.005	44.6	0.001	
8/27/2011	NW	5 MPH	A-1	Downwind	Next to Guard Shack	0.004	19.1	0.001	
8/27/2011	NW	5 MPH	A-2	Upwind	SE Corner of Plant	0.003	14	0.001	

All asbestos air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

