



Turnstone EH&S Inc. Laboratory Air Sample Analysis
Encycle Asbestos Abatement Project

Date	Wind Direction	Wind Speed	Sample #	Upwind/Downwind		Location	Sample Result f/cc	Fiber Density	Detection Limit
				Upwind	Downwind				
9/19/2011	NE	4 MPH	A-1	Upwind	Downwind	Next to Guard Shack	0.004	15.3	0.001
9/19/2011	NE	4 MPH	A-2	Downwind	Downwind	SE Corner of Plant	0.005	19.7	0.001
9/20/2011	ENE	4 MPH	A-1	Upwind	Downwind	Next to Guard Shack	0.003	19.7	0.001
9/20/2011	ENE	4 MPH	A-2	Downwind	Downwind	SE Corner of Plant	0.003	20.4	0.001
9/21/2011	SOUTH	3 MPH	A-1	Downwind	Downwind	Next to Guard Shack	0.005	47.8	0.001
9/21/2011	SOUTH	3 MPH	A-2	Upwind	Downwind	SE Corner of Plant	0.004	40.8	0.001
9/22/2011	NE	4 MPH	A-1	Downwind	Downwind	Next to Guard Shack	0.002	15.3	0.001
9/22/2011	NE	4 MPH	A-2	Upwind	Downwind	SE Corner of Plant	0.002	13.4	0.001
9/23/2011	NW	5 MPH	A-3	Downwind	Downwind	Next to Guard Shack	<0.005	<7.0	0.005
9/23/2011	NW	5 MPH	A-4	Upwind	Upwind	SE Corner of Plant	<0.005	<7.0	0.005

On 9/23/11 the sample concentrations are below the detection limit due to the lower volume then the rest of the samples.

All asbests air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

