



Turnstone EH&S Inc. Laboratory Air Sample Analysis

Encycle Asbestos Abatement Project

Date	Wind Direction	Wind Speed	Sample #	Upwind/ Downwind	Location	Sample Result f/cc	Fiber Density	Detection Limit
10/17/2011	SSW	3 MPH	A-1	Upwind	NW Corner of Plant	0.004	34.4	0.001
10/17/2011	SSW	3 MPH	A-2	Downwind	Bldg. # 42	0.004	39.5	0.001
10/18/2011			A-1	Upwind	N/A Due to weather conditions			
10/18/2011			A-2	Downwind	N/A Due to weather conditions			
10/19/2011	NNW	10 MPH	A-1	Upwind	NW Corner of Plant	0.003	17.2	0.001
10/19/2011	NNW	10 MPH	A-2	Downwind	Bldg. # 42	0.004	30.6	0.001
10/20/2011	NNW	3 MPH	A-1	Downwind	NEXt to Guard Shack	0.003	28	0.001
10/20/2011	NNW	3 MPH	A-2	Upwind	NE Corner of Plant	0.004	34.4	0.001
10/21/2011	SSE	6 MPH	A-1	Downwind	NW Corner of Plant	0.005	50.3	0.001
10/21/2011	SSE	6 MPH	A-2	Upwind	Bldg. # 48	0.004	44.6	0.001

All asbestos air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

