



Turnstone EH&S Inc. Laboratory Air Sample Analysis

Encycle Asbestos Abatement Project

| Date | Wind Direction | Wind Speed | Sample # | Upwind/ Downwind | Location | Sample Result f/cc | Fiber Density | Detection Limit |
|-------------|-----------------------|-------------------|-----------------|-----------------------------|--------------------|---------------------------|----------------------|------------------------|
| 11/7/2011 | SSE | 13 MPH | A-1 | Upwind | NW Corner of Plant | 0.004 | 34.4 | 0.001 |
| 11/7/2011 | SSE | 13 MPH | A-2 | Downwind | Bldg. # 48 | 0.003 | 28 | 0.001 |
| 11/8/2011 | SSE | 17 MPH | A-1 | Upwind | NW Corner of Plant | 0.004 | 42 | 0.001 |
| 11/8/2011 | SSE | 17 MPH | A-2 | Downwind | Bldg. # 48 | 0.005 | 36.9 | 0.001 |
| 11/11/2011 | West | 2 MPH | A-1 | Upwind | NW Corner of Plant | 0.004 | 39.5 | 0.001 |
| 11/11/2011 | West | 2 MPH | A-2 | Downwind | Bldg. # 48 | 0.005 | 45.2 | 0.001 |
| 11/12/2011 | South | 8 MPH | A-1 | Downwind | NW Corner of Plant | 0.005 | 36.9 | 0.001 |
| 11/12/2011 | South | 8 MPH | A-2 | Upwind | Bldg. # 48 | 0.004 | 31.8 | 0.001 |

All asbestos air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

No samples for the 9th because of weather and 10th because of E-BAM samples to high

