



Turnstone EH&S Inc. Laboratory Air Sample Analysis

Encycle Asbestos Abatement Project

Date	Wind Direction	Wind Speed	Sample #	Upwind/ Downwind	Location	Sample Result f/cc	Fiber Density	Detection Limit
11/28/2011	NNW	5 MPH	A-1	Downwind	Next to Guard Shack	0.003	28	0.001
11/28/2011	NNW	5 MPH	A-2	Upwind	NW Corner of Plant	0.003	24.8	0.001
11/29/2011	NE	6 MPH	A-1	Downwind	Next to Guard Shack	0.004	34.4	0.001
11/29/2011	NE	6 MPH	A-2	Upwind	NW Corner of Plant	0.003	29.9	0.001
11/30/2011	NE	7 MPH	A-1	Downwind	Next to Guard Shack	0.004	40.8	0.001
11/30/2011	NE	7 MPH	A-2	Upwind	NW Corner of Plant	0.003	33.1	0.001
12/1/2011	SE	27 MPH	A-1	Downwind	NW Corner of Plant	0.003	33.8	0.001
12/1/2011	SE	27 MPH	A-2	Upwind	Next to Bldg. #46	0.002	23.6	0.001
12/02/2011	SE	9 MPH	A-1	Downwind	NW Corner of Plant	0.003	30.6	0.001
12/02/2011	SE	9 MPH	A-2	Upwind	Next to Bldg. #46	0.003	31.8	0.001

All asbestos air monitoring, sample collections and analysis is done in accordance with the Asbestos Abatement Plan set-fourth by Turnstone EH&S and approved by the TCEQ.

