



3465 Curry Lane
Abilene, Texas 79606
325-695-1070
www.JacobMartin.com

1508 Santa Fe Drive
Suite 204-205
Weatherford, Texas 76086
817-594-9880
Fax: 817-594-9882

August 26, 2013

Mr. Frank Burleson
Manager – Program Support Section
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Re: City of Gordon Certificate of Adjudication No. 12-4024
Revised Pass-Through Plan

Dear Mr. Burleson:

The City of Gordon is in receipt of your letter dated August 7, 2013 requesting additional information for inflow calculation for the priority call on the above referenced water right. The Plan has been revised as follows:

The City maintains an overflow spillway inside the dam at Lake C.B. Long which allows for the overflow and release of inflow to the lake. The City intends to keep this spillway open allowing release of inflow as required. Additionally, inflow in excess of the capacity of the overflow spillway would be released over the emergency spillway and conveyed downstream. The volume of inflow will be calculated by monitoring the lake level and using existing topographical information for the lake. The volume will be calculated by multiplying the inflow level by the corresponding contour area and applying the end-area volume calculation method.

Please don't hesitate to call me if you have any questions.

Sincerely,
JACOB & MARTIN, LTD.


Derek Turner, P.E.

xc: Barbara Epperson, City of Gordon