

Executive Summary – Enforcement Matter – Case No. 61407

City of Port Lavaca

RN103098992

Docket No. 2021-1304-PWS-E

Order Type:

Findings Agreed Order

Findings Order Justification:

Three or more enforcement actions (NOVs, orders, etc.) over the prior five year period for the same violation(s).

Media:

PWS

Small Business:

No

Location(s) Where Violation(s) Occurred:

City of Port Lavaca PWS, 800 North Commerce Street, Port Lavaca, Calhoun County

Type of Operation:

Public water supply

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: May 27, 2022

Comments Received: No

Penalty Information

Total Penalty Assessed: \$3,625

Amount Deferred for Disinfection Byproducts for Eligible Systems: \$3,625

Total Paid to General Revenue: \$0

Total Due to General Revenue: \$0

Payment Plan: N/A

Compliance History Classifications:

Person/CN - Satisfactory

Site/RN - N/A

Major Source: Yes

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: January 2021

Investigation Information

Complaint Date(s): N/A

Complaint Information: N/A

Date(s) of Investigation: September 13, 2021 through September 24, 2021

Date(s) of NOE(s): September 24, 2021

Executive Summary – Enforcement Matter – Case No. 61407

City of Port Lavaca

RN103098992

Docket No. 2021-1304-PWS-E

Violation Information

Failed to comply with the maximum contaminant level of 0.080 milligrams per liter for total trihalomethanes based on the locational running annual average [30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

The Respondent implemented a corrective measure by returning to compliance with the maximum contaminant level for total trihalomethanes by December 9, 2021.

Technical Requirements:

N/A

Contact Information

TCEQ Attorney: N/A

TCEQ Enforcement Coordinator: Ecko Beggs, Enforcement Division, Enforcement Team 4, MC R-06, (915) 834-4968; Michael Parrish, Enforcement Division, MC 219, (512) 239-2548

Respondent: The Honorable Jack Whitlow, Mayor, City of Port Lavaca, 202 North Virginia Street, Port Lavaca, Texas 77979-3431

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

DATES	Assigned	27-Sep-2021	Screening	29-Sep-2021	EPA Due	31-Dec-2021
	PCW	29-Sep-2021				

RESPONDENT/FACILITY INFORMATION	
Respondent	City of Port Lavaca
Reg. Ent. Ref. No.	RN103098992
Facility/Site Region	14-Corpus Christi
Major/Minor Source	Major

CASE INFORMATION			
Enf./Case ID No.	61407	No. of Violations	1
Docket No.	2021-1304-PWS-E	Order Type	Findings
Media Program(s)	Public Water Supply	Government/Non-Profit	Yes
Multi-Media		Enf. Coordinator	Ecko Beggs
		EC's Team	Enforcement Team 2
Admin. Penalty \$ Limit Minimum	\$50	Maximum	\$5,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$2,500
---	-------------------	----------------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	55.0%	Adjustment	Subtotals 2, 3, & 7	\$1,375
---------------------------	--------------	------------	--------------------------------	----------------

Notes: Enhancement for three NOVs with the same/similar violations and two Agreed Orders containing a denial of liability.

Culpability	No	0.0%	Enhancement	Subtotal 4	\$0
--------------------	----	-------------	-------------	-------------------	------------

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments	Subtotal 5	-\$250
--	-------------------	---------------

Economic Benefit	0.0%	Enhancement*	Subtotal 6	\$0
-------------------------	-------------	--------------	-------------------	------------

Total EB Amounts: \$4,852
 Estimated Cost of Compliance: \$100,000
 *Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$3,625
-----------------------------	-----------------------	----------------

OTHER FACTORS AS JUSTICE MAY REQUIRE	0.0%	Adjustment	\$0
---	-------------	------------	------------

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes:

Final Penalty Amount	\$3,625
-----------------------------	----------------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$3,625
-----------------------------------	-------------------------------	----------------

DEFERRAL	100.0%	Reduction	Adjustment	-\$3,625
-----------------	---------------	-----------	-------------------	-----------------

Reduces the Final Assessed Penalty by the indicated percentage.

Notes: The Executive Director recommends a conditional deferral for disinfection byproducts.

PAYABLE PENALTY	\$0
------------------------	------------

Screening Date 29-Sep-2021

Docket No. 2021-1304-PWS-E

PCW

Respondent City of Port Lavaca

Policy Revision 5 (January 28, 2021)

Case ID No. 61407

PCW Revision February 11, 2021

Reg. Ent. Reference No. RN103098992

Media Public Water Supply

Enf. Coordinator Ecko Beggs

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Number	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	3	15%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	2	40%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 55%

>> Repeat Violator (Subtotal 3)

N/A

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

Satisfactory Performer

Adjustment Percentage (Subtotal 7) 0%

>> Compliance History Summary

Compliance History Notes

Enhancement for three NOVs with the same/similar violations and two Agreed Orders containing a denial of liability.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) 55%

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100% 55%

Screening Date 29-Sep-2021
Respondent City of Port Lavaca
Case ID No. 61407
Reg. Ent. Reference No. RN103098992

Docket No. 2021-1304-PWS-E

PCW

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

Media Public Water Supply
Enf. Coordinator Ecko Beggs

Violation Number 1

Rule Cite(s) 30 Tex. Admin. Code § 290.115(f)(1) and Tex. Health & Safety Code § 341.0315(c)

Violation Description Failed to comply with the maximum contaminant level ("MCL") of 0.080 milligrams per liter ("mg/L") for total trihalomethanes ("TTHM"), based on the locational running annual average ("LRAA"). Specifically, the LRAA concentrations of TTHM for Stage 2 Disinfection Byproducts ("DBP2") at Site 3 were 0.081 mg/L for the first quarter of 2021, 0.089 mg/L for the second quarter of 2021, and 0.084 mg/L for the third quarter of 2021.

Base Penalty \$5,000

>> Environmental, Property and Human Health Matrix

OR	Release	Harm			Percent
		Major	Moderate	Minor	
	Actual		x		50.0%
	Potential				

>> Programmatic Matrix

	Falsification	Major	Moderate	Minor	Percent
					0.0%

Matrix Notes Exceeding the MCL for TTHM caused persons served by the Facility to be exposed to a significant amount of contaminants which did not exceed levels protective of human health.

Adjustment \$2,500

\$2,500

Violation Events

Number of Violation Events 1 272 Number of violation days

daily	
weekly	
monthly	
quarterly	
semiannual	
annual	x
single event	

Violation Base Penalty \$2,500

One annual event is recommended.

Good Faith Efforts to Comply

10.0%

Reduction \$250

Before NOE/NOV NOE/NOV to EDPRP/Settlement Offer

Extraordinary		
Ordinary		x
N/A		

Notes The Respondent achieved compliance on December 9, 2021.

Violation Subtotal \$2,250

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$4,852

Violation Final Penalty Total \$3,625

This violation Final Assessed Penalty (adjusted for limits) \$3,625

Economic Benefit Worksheet

Respondent City of Port Lavaca
Case ID No. 61407
Reg. Ent. Reference No. RN103098992
Media Public Water Supply
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Costs Saved	EB Amount
------------------	-----------	---------------	------------	-----	----------------	-------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)	\$100,000	31-Mar-2021	9-Dec-2021	0.69	\$231	\$4,621	\$4,852
Engineering/Construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

The delayed cost includes the estimated amount to investigate, identify, and implement the necessary corrective actions to return to compliance with the MCL for TTHM, calculated from the last day of the first quarter of noncompliance to the date of compliance.

Avoided Costs

ANNUALIZE avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance				0.00	\$0	\$0	\$0
ONE-TIME avoided costs				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance

\$100,000

TOTAL

\$4,852

The TCEQ is committed to accessibility.

To request a more accessible version of this report, please contact the TCEQ Help Desk at (512) 239-4357.



Compliance History Report

Compliance History Report for CN600755052, RN103098992, Rating Year 2021 which includes Compliance History (CH) components from September 1, 2016, through August 31, 2021.

Customer, Respondent, or Owner/Operator: CN600755052, City of Port Lavaca **Classification:** SATISFACTORY **Rating:** 17.25

Regulated Entity: RN103098992, CITY OF PORT LAVACA **Classification:** NOT APPLICABLE **Rating:** N/A

Complexity Points: N/A **Repeat Violator:** N/A

CH Group: 14 - Other

Location: 800 NORTH COMMERCE STREET IN PORT LAVACA, CALHOUN COUNTY, TEXAS

TCEQ Region: REGION 14 - CORPUS CHRISTI

ID Number(s):
PUBLIC WATER SYSTEM/SUPPLY REGISTRATION 0290002 **WATER LICENSING LICENSE** 0290002

Compliance History Period: September 01, 2016 to August 31, 2021 **Rating Year:** 2021 **Rating Date:** 09/01/2021

Date Compliance History Report Prepared: February 24, 2022

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: February 24, 2017 to February 24, 2022

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.
Name: Ecko Beggs **Phone:** (512) 239-2905

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

- 1 Effective Date: 10/16/2018 ADMINORDER 2017-0813-PWS-E (1660 Order-Agreed Order With Denial)
- Classification: Minor
- Citation: 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(D)(ii)
- Description: Failed by a public water system, serving more than 250 connections, to meet a total storage capacity of 200 gallons per connection.
- Classification: Moderate
- Citation: 30 TAC Chapter 290, SubChapter D 290.42(l)
- Description: Failed to compile a thorough plant operations manual and kept up to date for operator review and reference.
- Classification: Moderate
- Citation: 30 TAC Chapter 290, SubChapter D 290.46(z)
- Description: Failed to maintain a Nitrification Action Plan (NAP) as part of the monitoring plan.
- Classification: Minor
- Citation: 30 TAC Chapter 290, SubChapter D 290.46(f)(2)
- 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(ix)
- Description: Failed to maintain records for free and total chlorine, monochloramine, ammonia, nitrite, and nitrate monitoring results if chloramines are used in the water system.
- Classification: Minor
- Citation: 30 TAC Chapter 290, SubChapter D 290.46(f)(2)
- 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(E)(iv)
- Description: Failed to maintain records of all Customer Service Inspections (CSI) for at least ten years.
- Classification: Major
- Citation: 30 TAC Chapter 290, SubChapter D 290.46(e)(3)(C)

Description: Failed to operate the purchase water system, which serves more than 1,000 connections, with at least two operators where both of the operators hold Class "C" or higher licenses and who each work at least 16 hours each month at the public water system's treatment or distribution facilities.

Classification: Minor

Citation: 30 TAC Chapter 290, SubChapter F 290.110(c)(4)(B)

Description: Failed to monitor the disinfectant residual at representative locations in the distribution system at least once per day.

2 Effective Date: 04/23/2019 ADMINORDER 2018-0788-PWS-E (1660 Order-Agreed Order With Denial)

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

5A THSC Chapter 341, SubChapter A 341.0315(c)

Description: TTHM LRAA MCL 1Q2018 - During the 1st quarter of 2018 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.082 mg/L at 522 W George, Port Lavaca (DBP2-01), 0.086 mg/L at 312 Rouen DR, Port Lavaca, TX (DBP2-02), 0.090 mg/L at 503 Sand Dollar, Port Lavaca (DBP2-03), and 0.085 mg/L at 521 S Virginia ST, Port Lavaca, ST (DBP2-04).

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

5A THSC Chapter 341, SubChapter A 341.0315(c)

Description: TTHM LRAA MCL 4Q2017 - During the 4th quarter of 2017 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.081 mg/L at 522 W George, Port Lavaca (DBP2-01), 0.085 mg/L at 312 Rouen DR, Port Lavaca, TX (DBP2-02), 0.088 mg/L at 503 Sand Dollar, Port Lavaca (DBP2-03), and 0.081 mg/L at 521 S Virginia ST, Port Lavaca, ST (DBP2-04).

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(e)(2)

Description: DBP2 TTHM OEL Reporting - This system failed to submit the Operational Evaluation Report (OEL) after exceeding the operational evaluation level for trihalomethanes at 503 Sand Dollar, Port Lavaca (DBP2-03) within the required timeline.

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1 January 31, 2019 (1541052)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

1 Date: 04/15/2021 (1762928)

Self Report? NO

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: TTHM LRAA MCL 1Q2021 - During the 1st quarter of 2021 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.081 mg/L at 503 Sand Dollar, Port Lavaca (DBP2-03).

2 Date: 07/01/2021 (1762928)

Self Report? NO

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: TTHM LRAA MCL 2Q2021 - During the 2nd quarter of 2021 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.089 mg/L at 503 Sand Dollar, Port Lavaca (DBP2-03).

3 Date: 09/10/2021 (1762928)

Self Report? NO

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: TTHM LRAA MCL 3Q2021 - During the 3rd quarter of 2021 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.084 mg/L at 503 Sand Dollar, Port Lavaca (DBP2-03).

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



**IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
CITY OF PORT LAVACA
RN103098992**

**§ BEFORE THE
§
§ TEXAS COMMISSION ON
§
§ ENVIRONMENTAL QUALITY**

AGREED ORDER DOCKET NO. 2021-1304-PWS-E

On _____, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding the City of Port Lavaca (the "Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 341. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent, presented this Order to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated agreement of the parties. The provisions of this Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a public water supply located at 800 North Commerce Street in Port Lavaca, Calhoun County, Texas (the "Facility"). The Facility provides water for human consumption, has approximately 6,130 service connections, and serves at least 25 people per day for at least 60 days per year. As such, the Facility is a public water system as defined in 30 TEX. ADMIN. CODE § 290.38(71).
2. During a record review conducted on September 13, 2021 through September 24, 2021, an investigator documented that the locational running annual average concentrations of total trihalomethanes ("TTHM") for Stage 2 Disinfection Byproducts ("DBP2") at Site 3 were 0.081 milligrams per liter ("mg/L") for the first quarter of 2021, 0.089 mg/L for the second quarter of 2021, and 0.084 mg/L for the third quarter of 2021.
3. The Executive Director recognizes that the Respondent implemented a corrective measure at the Facility by returning to compliance with the maximum contaminant level ("MCL") for TTHM by December 9, 2021.

II. CONCLUSIONS OF LAW

1. As evidenced by Finding of Fact No. 1, the Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. HEALTH & SAFETY CODE ch. 341 and the rules of the TCEQ.
2. As evidenced by Finding of Fact No. 2, the Respondent failed to comply with the MCL of 0.080 mg/L for TTHM, based on the locational running annual average, in violation of 30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
3. Pursuant to TEX. HEALTH & SAFETY CODE § 341.049(a), the TCEQ has the authority to assess an administrative penalty against the Respondent for violations of state statutes within the TCEQ's jurisdiction, for violations of rules adopted under such statutes, or for violations of orders or permits issued under such statutes.
4. An administrative penalty in the amount of \$3,625 is justified by the facts recited in this Order, and considered in light of the factors set forth in TEX. HEALTH & SAFETY CODE § 341.049(b). The amount of \$3,625 is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Order and shall be waived only upon full compliance with all the terms and conditions contained in this Order. If the Respondent fails to timely and satisfactorily comply with any requirement contained in this Order, the Executive Director may demand payment of all or part of the conditionally deferred penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed a penalty as set forth in Conclusion of Law No. 4 for violations of state statutes and rules of the TCEQ. The payment of this penalty and the Respondent's compliance with all the requirements set forth in this Order resolve only the matters set forth by this Order in this action. The Commission shall not be constrained in any manner from requiring corrective actions or penalties for violations that are not raised here. Penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: City of Port Lavaca, Docket No. 2021-1304-PWS-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. All relief not expressly granted in this Order is denied.
3. The duties and provisions imposed by this Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of this Order to personnel who maintain day-to-day control over the Facility operations referenced in this Order.

4. The Executive Director may grant an extension of any deadline in this Order or in any plan, report, or other document submitted pursuant to this Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
5. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms in this Order.
6. This Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Order, whichever is later.
7. This Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
8. This Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms: electronic transmission, owner, person, writing, and written, shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.
9. The effective date of this Order is the date it is signed by the Commission. A copy of this fully executed Order shall be provided to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Date



For the Executive Director

8/15/2022


Date

I, the undersigned, have read and understand the attached Order. I am authorized to agree to the attached Order, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this Order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.



Signature

5-4-2022

Date

Jack O. "Jack" Whitlow

Name (Printed or typed)
Authorized Representative of
City of Port Lavaca

Mayor

Title

If mailing address has changed, please check this box and provide the new address below:

Instructions: Send the original, signed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Ordering Provision 1 of this Order.