

Executive Summary – Enforcement Matter – Case No. 61778
MIMS WATER SUPPLY CORPORATION
RN101458875
Docket No. 2022-0070-PWS-E

Order Type:

Findings Agreed Order

Findings Order Justification:

Three or more enforcement actions (NOVs, orders, etc.) over the prior five year period for the same violation(s).

Media:

PWS

Small Business:

Yes

Location(s) Where Violation(s) Occurred:

Mims WSC, 12688 Farm-to-Market Road 729 near Avinger, Marion County

Type of Operation:

Public water supply

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: September 9, 2022

Comments Received: No

Penalty Information

Total Penalty Assessed: \$2,625

Amount Deferred for Disinfection Byproducts for Eligible Systems: \$2,625

Total Paid to General Revenue: \$0

Total Due to General Revenue: \$0

Payment Plan: N/A

Compliance History Classifications:

Person/CN - N/A

Site/RN - N/A

Major Source: No

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: January 2021

Investigation Information

Complaint Date(s): N/A

Complaint Information: N/A

Date(s) of Investigation: December 20, 2021 through January 7, 2022

Date(s) of NOE(s): January 7, 2022

**Executive Summary – Enforcement Matter – Case No. 61778
MIMS WATER SUPPLY CORPORATION
RN101458875
Docket No. 2022-0070-PWS-E**

Violation Information

Failed to comply with the maximum contaminant level of 0.060 milligrams per liter for haloacetic acids based on the locational running annual average [30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

The Respondent has implemented a corrective measure by returning to compliance with the maximum contaminant level for haloacetic acids based on the locational running annual average by March 31, 2022.

Technical Requirements:

N/A

Contact Information

TCEQ Attorney: N/A

TCEQ Enforcement Coordinator: America Ruiz, Enforcement Division, Enforcement Team 4, MC 219, (512) 239-2601; Michael Parrish, Enforcement Division, MC 219, (512) 239-2548

Respondent: Bruce Dedman, President, MIMS WATER SUPPLY CORPORATION, 12688 Farm-to-Market Road 729, Avinger, Texas 75630

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

DATES	Assigned	10-Jan-2022	Screening	10-Jan-2022	EPA Due	31-Mar-2022
	PCW	17-Jan-2022				

RESPONDENT/FACILITY INFORMATION	
Respondent	MIMS WATER SUPPLY CORPORATION
Reg. Ent. Ref. No.	RN101458875
Facility/Site Region	5-Tyler
Major/Minor Source	Minor

CASE INFORMATION			
Enf./Case ID No.	61778	No. of Violations	1
Docket No.	2022-0070-PWS-E	Order Type	Findings
Media Program(s)	Public Water Supply	Government/Non-Profit	Yes
Multi-Media		Enf. Coordinator	America Ruiz
		EC's Team	Enforcement Team 2
Admin. Penalty \$ Limit Minimum	\$50	Maximum	\$5,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$2,500
---	-------------------	---------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	15.0% Adjustment	Subtotals 2, 3, & 7	\$375
---------------------------	------------------	--------------------------------	-------

Notes: Enhancement for three NOVs with the same/similar violations.

Culpability	No	0.0% Enhancement	Subtotal 4	\$0
--------------------	----	------------------	-------------------	-----

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments	Subtotal 5	-\$250
--	-------------------	--------

Economic Benefit	0.0% Enhancement*	Subtotal 6	\$0
-------------------------	-------------------	-------------------	-----

Total EB Amounts: \$2,102
 Estimated Cost of Compliance: \$40,000
 *Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$2,625
-----------------------------	-----------------------	---------

OTHER FACTORS AS JUSTICE MAY REQUIRE	0.0%	Adjustment	\$0
---	------	-------------------	-----

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes:

Final Penalty Amount	\$2,625
-----------------------------	---------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$2,625
-----------------------------------	-------------------------------	---------

DEFERRAL	100.0%	Reduction	Adjustment	-\$2,625
-----------------	--------	-----------	-------------------	----------

Reduces the Final Assessed Penalty by the indicated percentage.

Notes: The Executive Director recommends a conditional deferral for disinfection byproducts.

PAYABLE PENALTY	\$0
------------------------	-----

Screening Date 10-Jan-2022

Docket No. 2022-0070-PWS-E

PCW

Respondent MIMS WATER SUPPLY CORPORATION

Policy Revision 5 (January 28, 2021)

Case ID No. 61778

PCW Revision February 11, 2021

Reg. Ent. Reference No. RN101458875

Media Public Water Supply

Enf. Coordinator America Ruiz

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Number	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	3	15%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	0	0%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 15%

>> Repeat Violator (Subtotal 3)

N/A

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

N/A

Adjustment Percentage (Subtotal 7) 0%

>> Compliance History Summary

Compliance History Notes

Enhancement for three NOVs with the same/similar violations.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) 15%

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100% 15%

Screening Date 10-Jan-2022 **Docket No.** 2022-0070-PWS-E **PCW**
Respondent MIMS WATER SUPPLY CORPORATION *Policy Revision 5 (January 28, 2021)*
Case ID No. 61778 *PCW Revision February 11, 2021*
Reg. Ent. Reference No. RN101458875
Media Public Water Supply
Enf. Coordinator America Ruiz

Violation Number 1
Rule Cite(s) 30 Tex. Admin. Code § 290.115(f)(1) and Tex. Health & Safety Code § 341.0315(c)
Violation Description Failed to comply with the maximum contaminant level ("MCL") of 0.060 milligram per liter ("mg/L") for haloacetic acids ("HAA5") based on the locational running annual average. Specifically, the locational running annual average concentrations of HAA5 for Stage 2 Disinfection Byproducts at Site 1 were 0.061 mg/L for the fourth quarter of 2021, and at Site 2 were 0.062 mg/L for the second quarter of 2021, 0.061 mg/L for the third quarter of 2021, and 0.062 mg/L for the fourth quarter of 2021.

Base Penalty \$5,000

>> Environmental, Property and Human Health Matrix

OR	Release	Harm			Percent
		Major	Moderate	Minor	
	Actual		x		25.0%
	Potential				

>> Programmatic Matrix

	Falsification	Major	Moderate	Minor	Percent
					0.0%

Matrix Notes Exceeding the MCL for HAA5 caused persons served by the Facility to be exposed to a significant amount of contaminants which did not exceed levels protective of human health.

Adjustment \$3,750

\$1,250

Violation Events

Number of Violation Events 2 274 Number of violation days

daily	
weekly	
monthly	
quarterly	
semiannual	
annual	x
single event	

Violation Base Penalty \$2,500

Two annual events are recommended, one event per Site.

Good Faith Efforts to Comply 10.0% Reduction \$250

	Before NOE/NOV	NOE/NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary		x
N/A		

Notes The Respondent achieved compliance by March 31, 2022.

Violation Subtotal \$2,250

Economic Benefit (EB) for this violation **Statutory Limit Test**

Estimated EB Amount \$2,102 **Violation Final Penalty Total** \$2,625

This violation Final Assessed Penalty (adjusted for limits) \$2,625

Economic Benefit Worksheet

Respondent MIMS WATER SUPPLY CORPORATION
Case ID No. 61778
Reg. Ent. Reference No. RN101458875
Media Public Water Supply
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Costs Saved	EB Amount
------------------	-----------	---------------	------------	-----	----------------	-------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)	\$40,000	30-Jun-2021	31-Mar-2022	0.75	\$100	\$2,002	\$2,102
Engineering/Construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs
 The other (as needed) cost includes the estimated amount to investigate, identify, and implement the necessary corrective actions to return to compliance with the MCL for HAA5, calculated from the last day of the first quarter of noncompliance to the date of compliance.

Avoided Costs

ANNUALIZE avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance				0.00	\$0	\$0	\$0
ONE-TIME avoided costs				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs
 (Empty box for notes)

Approx. Cost of Compliance \$40,000

TOTAL \$2,102



Compliance History Report

Compliance History Report for CN600687685, RN101458875, Rating Year 2021 which includes Compliance History (CH) components from September 1, 2016, through August 31, 2021.

Customer, Respondent, or Owner/Operator: CN600687685, MIMS WATER SUPPLY CORPORATION
Classification: NOT APPLICABLE **Rating:** N/A

Regulated Entity: RN101458875, MIMS WSC
Classification: NOT APPLICABLE **Rating:** N/A

Complexity Points: N/A
Repeat Violator: N/A

CH Group: 14 - Other

Location: 12688 FARM-TO-MARKET ROAD 729 NEAR AVINGER, MARION COUNTY, TEXAS

TCEQ Region: REGION 05 - TYLER

ID Number(s):

PUBLIC WATER SYSTEM/SUPPLY REGISTRATION
1580064

Compliance History Period: September 01, 2016 to August 31, 2021 **Rating Year:** 2021 **Rating Date:** 09/01/2021

Date Compliance History Report Prepared: June 02, 2022

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: June 02, 2017 to June 02, 2022

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: America Ruiz

Phone: (512) 239-2601

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five-year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:
N/A

B. Criminal convictions:
N/A

C. Chronic excessive emissions events:
N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):
N/A

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

- 1 Date: 06/29/2021 (1782386)
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)
Description: HAA5 LRAA MCL 2Q2021 - During the 2nd quarter of 2021 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.062 mg/L at NW CR 1599/CR 1512, Avinger (DBP2-02).
- 2 Date: 10/22/2021 (1782386)
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: HAA5 LRAA MCL 3Q2021 - During the 3rd quarter of 2021 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.061 mg/L at NW CR 1599/CR 1512, Avinger (DBP2-02).

3

Date: 12/15/2021 (1782386)

Self Report? NO

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: HAA5 LRAA MCL 4Q2021 - During the 4th quarter of 2021 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.062 mg/L at NW CR 1599/CR 1512, Avinger (DBP2-02) and with a LRAA of 0.061 mg/L at 1249 Locks Mountain Road, Avinger (DBP2-01).

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

Item 3	June 08, 2020**	(1651346)
Item 4	October 16, 2020**	(1672251)
Item 5	January 04, 2022	(1782386)
Item 6	January 07, 2022	(1782695)

* No violations documented during this investigation

**Investigation applicable for the Compliance History Rating period between 09/01/2016 and 08/31/2021.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



**IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
MIMS WATER SUPPLY
CORPORATION
RN101458875**

§
§
§
§
§
§

**BEFORE THE

TEXAS COMMISSION ON

ENVIRONMENTAL QUALITY**

**AGREED ORDER
DOCKET NO. 2022-0070-PWS-E**

On _____, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding MIMS WATER SUPPLY CORPORATION (the "Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 341. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent presented this Order to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated agreement of the parties. The provisions of this Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a public water supply located at 12688 Farm-to-Market Road 729 near Avinger, Marion County, Texas (the "Facility"). The Facility provides water for human consumption, has approximately 857 service connections, and serves at least 25 people per day for at least 60 days per year. As such, the Facility is a public water system as defined in 30 TEX. ADMIN. CODE § 290.38(71).
2. During a record review for the Facility conducted on December 20, 2021 through January 7, 2022, an investigator documented that the locational running annual average concentrations of haloacetic acids ("HAA5") for Stage 2 Disinfection Byproducts at Site 1 were 0.061 milligrams per liter ("mg/L") for the fourth quarter of 2021, and at Site 2 were 0.062 mg/L for the second quarter of 2021, 0.061 mg/L for the third quarter of 2021, and 0.062 mg/L for the fourth quarter of 2021.

3. The Executive Director recognizes that the Respondent has implemented a corrective measure at the Facility by returning to compliance with the maximum contaminant level ("MCL") for HAA5 based on the locational running annual average by March 31, 2022.

II. CONCLUSIONS OF LAW

1. As evidenced by Finding of Fact No. 1, the Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. HEALTH & SAFETY CODE ch. 341 and the rules of the TCEQ.
2. As evidenced by Finding of Fact No. 2, the Respondent failed to comply with the MCL of 0.060 mg/L for HAA5, based on the locational running annual average, in violation of 30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
3. Pursuant to TEX. HEALTH & SAFETY CODE § 341.049(a), the TCEQ has the authority to assess an administrative penalty against the Respondent for violations of state statutes within the TCEQ's jurisdiction, for violations of rules adopted under such statutes, or for violations of orders or permits issued under such statutes.
4. An administrative penalty in the amount of \$2,625 is justified by the facts recited in this Order, and considered in light of the factors set forth in TEX. HEALTH & SAFETY CODE § 341.049(b). The amount of \$2,625 is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Order and shall be waived only upon full compliance with all the terms and conditions contained in this Order. If the Respondent fails to timely and satisfactorily comply with any requirement contained in this Order, the Executive Director may demand payment of all or part of the conditionally deferred penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed a penalty as set forth in Conclusion of Law No. 4 for violations of state statutes and rules of the TCEQ. The payment of this penalty and the Respondent's compliance with all the requirements set forth in this Order resolve only the matters set forth by this Order in this action. The Commission shall not be constrained in any manner from requiring corrective actions or penalties for violations that are not raised here. Penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: MIMS WATER SUPPLY CORPORATION, Docket No. 2022-0070-PWS-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. All relief not expressly granted in this Order is denied.
3. The duties and provisions imposed by this Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of this Order to personnel who maintain day-to-day control over the Facility operations referenced in this Order.
4. The Executive Director may grant an extension of any deadline in this Order or in any plan, report, or other document submitted pursuant to this Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
5. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms in this Order.
6. This Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Order, whichever is later.
7. This Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
8. This Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively,

MIMS WATER SUPPLY CORPORATION

DOCKET NO. 2022-0070-PWS-E

Page 4

the terms: electronic transmission, owner, person, writing, and written, shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.

9. The effective date of this Order is the date it is signed by the Commission. A copy of this fully executed Order shall be provided to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Date



10/24/2022

For the Executive Director

Date

I, the undersigned, have read and understand the attached Order. I am authorized to agree to the attached Order, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this Order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.


Signature

August 12, 2022
Date

Bruce Dedman
Name (Printed or typed)
Authorized Representative of
MIMS WATER SUPPLY CORPORATION

President
Title

If mailing address has changed, please check this box and provide the new address below:

Instructions: Send the original, signed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Ordering Provision 1 of this Order.