

EXECUTIVE SUMMARY – ENFORCEMENT MATTER – CASE NO. 63045
SRC Water Supply Inc
RN104443734
Docket No. 2022-1259-UTL-E

Order Type:
Default Order

Media:
PWS

Small Business:
Yes

Location(s) Where Violation(s) Occurred:
1785 Limestone County Road 822, near Groesbeck, Limestone County (the “Utility”)

Type of Operation:
water utility

Other Significant Matters:

Additional Pending Enforcement Actions: Yes, Case No. 62546 (pending OAG referral);
2021-1047-PWS-E; 2022-1163-UTL-E;
2022-1266-UTL-E; 2022-1277-UTL-E;
2022-1332-UTL-E; 2022-1329-UTL-E;
2022-1328-UTL-E

Past-Due Penalties: \$228

Past-Due Fees: \$18,356.76

Other: None

Interested Third-Parties: None

Texas Register Publication Date: July 21, 2023

Comments Received: None

Penalty Information

Total Penalty Assessed: \$510

Total Paid to General Revenue: \$0

Total Due to General Revenue: \$510

Compliance History Classifications:

Person/CN - High
Site/RN - Unclassified

Major Source: No

Statutory Limit Adjustment: None

Applicable Penalty Policy: January 28, 2021

Investigation Information

Complaint Date(s): N/A

Date(s) of Investigation: September 9, 2022 through September 22, 2022

Date(s) of NOV(s): July 8, 2022

Date(s) of NOE(s): September 23, 2022

SRC Water Supply Inc
RN104443734
Docket No. 2022-1259-UTL-E

Violation Information

Failed to adopt and submit to TCEQ for approval an emergency preparedness plan ("EPP") that demonstrates the Utility's ability to provide emergency operations [TEX. WATER CODE § 13.1394(b)(2)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

None

Technical Requirements:

1. Within 90 days develop and submit to TCEQ for approval an EPP that demonstrates the Utility's ability to provide emergency operations. The EPP must demonstrate Respondent's ability to provide emergency operations.
Respond completely to all requests for information about the submitted or forthcoming EPP.
2. Within 105 days submit written certification to demonstrate compliance with Technical Requirement No. 1.
3. Within 270 days obtain approval from TCEQ for the EPP submitted pursuant to Technical Requirement No. 1.
4. Within 285 days submit written certification to demonstrate compliance with Technical Requirement No. 3.

Litigation Information

Date Petition(s) Filed: April 14, 2023

Date(s) of Service: April 25, 2023

Date Answer(s) Filed: N/A

Contact Information

TCEQ Attorneys: Megan L. Grace, Litigation Division, (512) 239-3400
Sheldon Wayne, Public Interest Counsel, (512) 239-6363

TCEQ Litigation Agenda Coordinator: Katherine McKenzie, Litigation Division, (512) 239-2575

TCEQ Enforcement Coordinator: Samantha Salas, Enforcement Division, (512) 239-1543

TCEQ Regional Contact: Richard Monreal, Waco Regional Office, (254) 761-0335

Respondent Contact: Sandra R. Barbey, President, SRC Water Supply Inc, P.O. Box 385, Mount Enterprise, Texas 75681-0385

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

DATES	Assigned	26-Sep-2022	Screening	29-Sep-2022	EPA Due	
	PCW	25-Oct-2022				

RESPONDENT/FACILITY INFORMATION	
Respondent	SRC Water Supply Inc
Reg. Ent. Ref. No.	RN104443734
Facility/Site Region	9-Waco
Major/Minor Source	Minor

CASE INFORMATION			
Enf./Case ID No.	63045	No. of Violations	1
Docket No.	2022-1259-UTL-E	Order Type	1660
Media Program(s)	Public Water Supply	Government/Non-Profit	No
Multi-Media		Enf. Coordinator	Samantha Salas
		EC's Team	Enforcement Team 4
Admin. Penalty \$ Limit Minimum	\$50	Maximum	\$5,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$500
---	-------------------	--------------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	-8.0% Adjustment	Subtotals 2, 3, & 7	-\$40
---------------------------	-------------------------	--------------------------------	--------------

Notes: Enhancement for one NOV with dissimilar violations. Reduction for high performer classification.

Culpability	No	0.0% Enhancement	Subtotal 4	\$0
--------------------	----	-------------------------	-------------------	------------

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments	Subtotal 5	\$0
--	-------------------	------------

Economic Benefit	0.0% Enhancement*	Subtotal 6	\$0
-------------------------	--------------------------	-------------------	------------

Total EB Amounts: \$7
 Estimated Cost of Compliance: \$180
 *Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$460
-----------------------------	-----------------------	--------------

OTHER FACTORS AS JUSTICE MAY REQUIRE	10.9% Adjustment	\$50
---	-------------------------	-------------

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes: Enhancement to offset the reduction for high performer.

Final Penalty Amount	\$510
-----------------------------	--------------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$510
-----------------------------------	-------------------------------	--------------

DEFERRAL	0.0% Reduction Adjustment	\$0
-----------------	----------------------------------	------------

Reduces the Final Assessed Penalty by the indicated percentage.

Notes: Deferral not offered for non-expedited settlement.

PAYABLE PENALTY	\$510
------------------------	--------------

Screening Date 29-Sep-2022

Docket No. 2022-1259-UTL-E

PCW

Respondent SRC Water Supply Inc

Policy Revision 5 (January 28, 2021)

Case ID No. 63045

PCW Revision February 11, 2021

Reg. Ent. Reference No. RN104443734

Media Public Water Supply

Enf. Coordinator Samantha Salas

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Number	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	0	0%
	Other written NOVs	1	2%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	0	0%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 2%

>> Repeat Violator (Subtotal 3)

No

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

High Performer

Adjustment Percentage (Subtotal 7) -10%

>> Compliance History Summary

Compliance History Notes

Enhancement for one NOV with dissimilar violations. Reduction for high performer classification.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) -8%

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100% -8%

Screening Date 29-Sep-2022
Respondent SRC Water Supply Inc
Case ID No. 63045
Reg. Ent. Reference No. RN104443734
Media Public Water Supply
Enf. Coordinator Samantha Salas

Docket No. 2022-1259-UTL-E

PCW

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

Violation Number

Rule Cite(s)

Tex. Water Code § 13.1394(b)(2)

Violation Description

Failed to adopt and submit to the TCEQ for approval an emergency preparedness plan ("EPP") that demonstrates the Facility's ability to provide emergency operations.

Base Penalty

>> Environmental, Property and Human Health Matrix

OR

Release	Harm		
	Major	Moderate	Minor
Actual	<input type="text"/>	<input type="text"/>	<input type="text"/>
Potential	<input type="text"/>	<input type="text"/>	<input type="text"/>

Percent

>> Programmatic Matrix

Falsification	Major	Moderate	Minor
<input type="text"/>	<input checked="" type="text" value="x"/>	<input type="text"/>	<input type="text"/>

Percent

Matrix Notes

100% of the rule requirements were not met.

Adjustment

Violation Events

Number of Violation Events Number of violation days

daily	<input type="text"/>
weekly	<input type="text"/>
monthly	<input type="text"/>
quarterly	<input type="text"/>
semiannual	<input type="text"/>
annual	<input type="text"/>
single event	<input checked="" type="text" value="x"/>

Violation Base Penalty

One single event is recommended.

Good Faith Efforts to Comply

Reduction

Before NOE/NOV NOE/NOV to EDPRP/Settlement Offer

Extraordinary	<input type="text"/>	<input type="text"/>
Ordinary	<input type="text"/>	<input type="text"/>
N/A	<input checked="" type="text" value="x"/>	<input type="text"/>

Notes

The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount

Violation Final Penalty Total

This violation Final Assessed Penalty (adjusted for limits)

Economic Benefit Worksheet

Respondent SRC Water Supply Inc
Case ID No. 63045
Reg. Ent. Reference No. RN104443734
Media Public Water Supply
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Costs Saved	EB Amount
------------------	-----------	---------------	------------	-----	----------------	-------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/Construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)	\$180	9-Sep-2022	8-Jul-2023	0.83	\$7	n/a	\$7

Notes for DELAYED costs

The delayed cost includes the estimated amount to develop and submit to the TCEQ for approval an EPP that demonstrates the Facility's ability to provide emergency operations, calculated from the date of the investigation to the estimated date of compliance.

Avoided Costs

ANNUALIZE avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance				0.00	\$0	\$0	\$0
ONE-TIME avoided costs				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance

\$180

TOTAL

\$7



Compliance History Report

Compliance History Report for CN604841528, RN104443734, Rating Year 2022 which includes Compliance History (CH) components from September 1, 2017, through August 31, 2022.

Customer, Respondent, or Owner/Operator: CN604841528, SRC Water Supply Inc **Classification:** HIGH **Rating:** 0.00

Regulated Entity: RN104443734, GREEN LAKE ESTATES WATER SUPPLY **Classification:** UNCLASSIFIED **Rating:** -----

Complexity Points: 3 **Repeat Violator:** NO

CH Group: 14 - Other

Location: 1785 LIMESTONE COUNTY ROAD 822 NEAR GROESBECK, LIMESTONE COUNTY, TEXAS

TCEQ Region: REGION 09 - WACO

ID Number(s):

PUBLIC WATER SYSTEM/SUPPLY REGISTRATION 1470034 **WATER QUALITY NON PERMITTED ID NUMBER** RN104443734

Compliance History Period: September 01, 2017 to August 31, 2022 **Rating Year:** 2022 **Rating Date:** 09/01/2022

Date Compliance History Report Prepared: December 12, 2022

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: December 12, 2017 to December 12, 2022

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: Ecko Beggs

Phone: (512) 239-2905

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

N/A

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1	August 02, 2019	(1581572)
Item 2	November 18, 2019	(1609625)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

- 1 Date: 04/13/2022 (1803106)
Self Report? NO Classification: Major
Citation: 30 TAC Chapter 290, SubChapter D 290.46(f)(2)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(ii)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(iii)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(iv)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(v)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(D)(ii)
 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(E)(i)

 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(E)(iv)

Description:	30 TAC Chapter 290, SubChapter D 290.46(f)(3)(E)(ix)		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.46(j)		
Description:	Failure to complete a Customer Service Inspection prior to providing continuous water service to new construction.		
Self Report?	NO	Classification:	Moderate
Citation:	30 TAC Chapter 290, SubChapter D 290.45(b)(1)(A)(ii)		
Description:	Failure to provide adequate pressure tank capacity.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 288, SubChapter B 288.20(c)		
Description:	Failure to provide an adequate drought contingency plan.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.43(d)(3)		
Description:	Failure to equip an air injection line with a filter.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.41(c)(3)(Q)		
Description:	Failure to screen the well air release device.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.41(c)(3)(M)		
Description:	Failure to provide a raw water sample tap on the well discharge pipe.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.41(c)(3)(B)		
Description:	Failure to provide a well casing that extends a minimum of 18 inches above the elevation of the finished floor of the pump room or natural ground surface.		
Self Report?	NO	Classification:	Minor
Citation:	30 TAC Chapter 290, SubChapter D 290.45(b)(1)(A)(i)		
Description:	Failure to provide adequate well capacity.		

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
SRC WATER SUPPLY INC;
RN104443734

§
§
§
§
§

BEFORE THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

DEFAULT ORDER

DOCKET NO. 2022-1259-UTL-E

On _____, the Texas Commission on Environmental Quality ("Commission" or "TCEQ") considered the Executive Director's Preliminary Report and Petition, filed pursuant to TEX. WATER CODE ch. 13 and TEX. HEALTH & SAFETY CODE ch. 341, which requests appropriate relief, including the imposition of an administrative penalty and corrective action of the respondent. The respondent made the subject of this Order is SRC Water Supply Inc ("Respondent").

The Commission makes the following Findings of Fact and Conclusions of Law:

FINDINGS OF FACT

1. Respondent owns and/or operates a retail public utility, exempt utility, or provider or conveyor of potable or raw water service located at 1785 Limestone County Road 822 near Groesbeck, Limestone County, Texas (the "Utility"). The Utility furnishes water service to more than one customer and is not located in a county with a population of 3.3 million or more or in a county with a population of 550,000 or more adjacent to a county with a population of 3.3 million or more.
2. During a record review conducted on September 9, 2022, through September 22, 2022, an investigator documented that Respondent failed to adopt and submit to TCEQ for approval an emergency preparedness plan ("EPP") that demonstrates the Utility's ability to provide emergency operations.
3. The Executive Director filed the "Executive Director's Preliminary Report and Petition Recommending that the Texas Commission on Environmental Quality Enter an Enforcement Order Assessing an Administrative Penalty Against and Requiring Certain Actions of SRC Water Supply Inc" (the "EDPRP") in the TCEQ Chief Clerk's office on April 14, 2023.
4. By letter dated April 14, 2023, sent to Respondent's last known address via certified mail, return receipt requested, postage prepaid, the Executive Director served Respondent with notice of the EDPRP. According to the return receipt "green card," Respondent received notice of the EDPRP on April 25, 2023, as evidenced by the signature on the card.
5. More than 20 days have elapsed since Respondent received notice of the EDPRP. Respondent failed to file an answer and failed to request a hearing.

CONCLUSIONS OF LAW

1. As evidenced by Finding of Fact No. 1, Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. WATER CODE ch. 13 and TEX. HEALTH & SAFETY CODE ch. 341.
2. As evidenced by Finding of Fact No. 2, Respondent failed to adopt and submit to TCEQ for approval an EPP that demonstrates the Utility's ability to provide emergency operations, in violation of TEX. WATER CODE § 13.1394(b)(2).

3. As evidenced by Findings of Fact Nos. 3 and 4, the Executive Director timely served Respondent with proper notice of the EDPRP, as required by TEX. WATER CODE § 13.4151, TEX. HEALTH & SAFETY CODE § 341.049, and 30 TEX. ADMIN. CODE § 70.104(b)(1).
4. As evidenced by Finding of Fact No. 5, Respondent failed to file a timely answer as required by TEX. WATER CODE § 13.4151, TEX. HEALTH & SAFETY CODE § 341.049, and 30 TEX. ADMIN. CODE § 70.105. Pursuant to TEX. WATER CODE § 13.4151, TEX. HEALTH & SAFETY CODE § 341.049, and 30 TEX. ADMIN. CODE § 70.106, the Commission may enter a Default Order against Respondent and assess the penalty recommended by the Executive Director.
5. Pursuant to TEX. WATER CODE § 13.4151 and TEX. HEALTH & SAFETY CODE § 341.049, the Commission has the authority to assess an administrative penalty against Respondent for violations of state statutes within TCEQ's jurisdiction, for violations of rules adopted under such statutes, or for violations of orders or permits issued under such statutes.
6. An administrative penalty in the amount of five hundred ten dollars (\$510.00) is justified by the facts recited in this Order, and considered in light of the factors set forth in TEX. WATER CODE § 13.4151(b).
7. TEX. WATER CODE §§ 5.102 and 7.002 authorize the Commission to issue orders and make determinations necessary to effectuate the purposes of the statutes within its jurisdiction.

ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. Respondent is assessed an administrative penalty in the amount of five hundred ten dollars (\$510.00) for violations of state statutes and rules of the TCEQ. The payment of this penalty and Respondent's compliance with all the requirements set forth in this Order resolve only the matters set forth by this Order in this action. The Commission shall not be constrained in any manner from requiring corrective actions or penalties for violations not raised here.
2. The penalty assessed by this Order shall be paid within 30 days after the effective date of this Order. All checks submitted to pay the penalty imposed by this Order shall be made out to TCEQ and shall be sent with the notation "Re: SRC Water Supply Inc; Docket No. 2022-1259-UTL-E" to:

Financial Administration Division
Revenue Operations Section
Texas Commission on Environmental Quality
Attention: Cashier's Office, MC 214
P.O. Box 13088
Austin, Texas 78711-3088

3. Respondent shall undertake the following technical requirements:
 - a. Within 90 days after the effective date of this Order, develop and submit to TCEQ for approval an EPP that demonstrates the Utility's ability to provide emergency operations, in accordance with TEX. WATER CODE § 13.1394(b)(2). The EPP must demonstrate Respondent's ability to provide emergency operations, as described by TEX. WATER CODE § 13.1394(b)(1), and shall be submitted to:

Emergency Response and Preparedness Section, MC 155
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711

Respondent shall respond completely and adequately, as determined by TCEQ, within 10 days or by any other deadline specified in writing, to all requests for information about the submitted or forthcoming EPP.

- b. Within 105 days after the effective date of this Order, submit written certification, in accordance with Ordering Provision No. 3.e., to demonstrate compliance with Ordering Provision No. 3.a.
- c. Within 270 days after the effective date of this Order, obtain approval from TCEQ for the EPP submitted pursuant to Ordering Provision No. 3.a., in accordance with TEX. WATER CODE § 13.1394(b)(2).
- d. Within 285 days after the effective date of this Order, submit written certification, in accordance with Ordering Provision No. 3.e., to demonstrate compliance with Ordering Provision No. 3.c.
- e. The certifications required by these Ordering Provisions shall be accompanied by detailed supporting documentation including photographs, receipts, and/or other records, shall be signed by Respondent, and shall include the following certification language:

“I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

The written certifications and supporting documentation necessary to demonstrate compliance with these Ordering Provisions shall be sent to:

Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

and:

Section Manager, Public Drinking Water
Water Supply Division, MC 155
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

4. All relief not expressly granted in this Order is denied.
5. The provisions of this Order shall apply to and be binding upon Respondent. Respondent is ordered to give notice of this Order to personnel who maintain day-to-day control over the Facility operations referenced in this Order.
6. The Executive Director may grant an extension of any deadline in this Order or in any plan, report, or other document submitted pursuant to this Order, upon a written and substantiated showing of good cause. All requests for extensions by Respondent shall be made in writing to the Executive Director. Extensions are not effective until Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director. Extension requests shall be sent to the Enforcement Division at the address listed above.
7. If Respondent fails to comply with any of the Ordering Provisions in this Order within the prescribed schedules, and that failure is caused solely by an act of God, war, strike, riot, or other catastrophe, Respondent's failure to comply is not a violation of this Order. Respondent shall have the burden of establishing to the Executive Director's satisfaction that such an event has occurred. Respondent shall notify the Executive Director within

seven days after Respondent becomes aware of a delaying event and shall take all reasonable measures to mitigate and minimize any delay.

8. The Executive Director may refer this matter to the Office of the Attorney General of the State of Texas for further enforcement proceedings without notice to Respondent if the Executive Director determines that Respondent has not complied with one or more of the terms or conditions in this Order.
9. The provisions of this Order are deemed severable, and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Order unenforceable, the remaining provisions shall be valid and enforceable.
10. This Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Order, whichever is later.
11. The Chief Clerk shall provide a copy of this fully executed Order to each of the parties. By law, the effective date of this Order shall be the date the Order is final, as provided by 30 TEX. ADMIN. CODE § 70.106(d) and TEX. GOV'T CODE § 2001.144.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Date

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



UNSWORN DECLARATION OF MEGAN L. GRACE

“On behalf of the Executive Director of the Texas Commission on Environmental Quality, the ‘Executive Director’s Preliminary Report and Petition Recommending that the Texas Commission on Environmental Quality Enter an Enforcement Order Assessing an Administrative Penalty Against and Requiring Certain Actions of SRC Water Supply Inc’ (the “EDPRP”) was filed in the TCEQ Chief Clerk’s office on April 14, 2023.

The EDPRP was mailed to Respondent’s last known address on April 14, 2023, via certified mail, return receipt requested. According to the return receipt ‘green card,’ Respondent received notice of the EDPRP on April 25, 2023, as evidenced by the signature on the card.

More than 20 days have elapsed since Respondent received notice of the EDPRP. Respondent failed to file an answer and failed to request a hearing.”

"My name is Megan L. Grace, and I am an employee of the following governmental agency: Texas Commission on Environmental Quality. I am executing this declaration as part of my assigned duties and responsibilities. I declare under penalty of perjury that the foregoing is true and correct.”

Executed in Travis County,
State of Texas,
on the 12th day of June, 2023

A handwritten signature in black ink, appearing to read "Megan L. Grace".

Declarant