

Executive Summary – Enforcement Matter – Case No. 67418

Undine Texas, LLC

RN102679842

Docket No. 2025-0265-PWS-E

Order Type:

Findings Agreed Order

Findings Order Justification:

Three repeated enforcement actions (or two orders with nuisance violations) over the prior five year period for the same violation(s).

Media:

PWS

Small Business:

No

Location(s) Where Violation(s) Occurred:

Crowley II Acre Subdivision, located approximately 750 feet north of the intersection of County Road 1015 and Rock Creek Road, Crowley, Johnson County

Type of Operation:

Public water supply

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Past-Due Fees: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: August 15, 2025

Comments Received: No

Penalty Information

Total Penalty Assessed: \$937

Total Paid to General Revenue: \$937

Total Due to General Revenue: \$0

Payment Plan: N/A

Compliance History Classifications:

Person/CN - Unclassified

Site/RN - N/A

Major Source: Yes

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: January 2021

Investigation Information

Complaint Date(s): N/A

Complaint Information: N/A

Date(s) of Investigation: February 4, 2025

Date(s) of NOE(s): February 14, 2025

Executive Summary – Enforcement Matter – Case No. 67418

Undine Texas, LLC

RN102679842

Docket No. 2025-0265-PWS-E

Violation Information

Failed to provide a well capacity of 0.6 gallon per minute per connection [30 TEX. ADMIN. CODE § 290.45(b)(1)(C)(i) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

N/A

Technical Requirements:

The Order will require the Respondent to:

- a. Within 180 days, provide a well capacity of at least 0.6 gallons per connection; and
- b. Within 195 days, submit written certification to demonstrate compliance with a.

Contact Information

TCEQ Attorney: N/A

TCEQ Enforcement Coordinator: Mason DeMasi, Enforcement Division, Enforcement Team 5, MC R-13, (210) 657-8425; Michael Parrish, Enforcement Division, MC R-12, (512) 239-2548

Respondent: William A. Thomas, Senior Vice President, Undine Texas, LLC, 17681 Telge Road, Cypress, Texas 77429-7080

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

DATES	Assigned	18-Feb-2025	Screening	19-Feb-2025	EPA Due	
	PCW	20-Feb-2025				

RESPONDENT/FACILITY INFORMATION

Respondent	Undine Texas, LLC
Reg. Ent. Ref. No.	RN102679842
Facility/Site Region	4-Dallas/Fort Worth
Major/Minor Source	Major

CASE INFORMATION

Enf./Case ID No.	67418	No. of Violations	1
Docket No.	2025-0265-PWS-E	Order Type	Findings
Media Program(s)	Public Water Supply	Government/Non-Profit	No
Multi-Media		Enf. Coordinator	Mason DeMasi
		EC's Team	Enforcement Team 5
Admin. Penalty \$ Limit Minimum	\$50	Maximum	\$5,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$750
---	-------------------	--------------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	25.0%	Adjustment	Subtotals 2, 3, & 7	\$187
---------------------------	--------------	-------------------	--------------------------------	--------------

Notes	Enhancement for one NOV with the same/similar violations and one agreed order containing denial of liability.
--------------	---

Culpability	No	0.0%	Enhancement	Subtotal 4	\$0
--------------------	----	-------------	--------------------	-------------------	------------

Notes	The Respondent does not meet the culpability criteria.
--------------	--

Good Faith Effort to Comply Total Adjustments	Subtotal 5	\$0
--	-------------------	------------

Economic Benefit	0.0%	Enhancement*	Subtotal 6	\$0
-------------------------	-------------	---------------------	-------------------	------------

Total EB Amounts	\$608
Estimated Cost of Compliance	\$5,000

*Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$937
-----------------------------	-----------------------	--------------

OTHER FACTORS AS JUSTICE MAY REQUIRE	0.0%	Adjustment	\$0
---	-------------	-------------------	------------

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes	
--------------	--

Final Penalty Amount	\$937
-----------------------------	--------------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$937
-----------------------------------	-------------------------------	--------------

DEFERRAL	0.0%	Reduction	Adjustment	\$0
-----------------	-------------	------------------	-------------------	------------

Reduces the Final Assessed Penalty by the indicated percentage.

Notes	No deferral is recommended for Findings Orders.
--------------	---

PAYABLE PENALTY	\$937
------------------------	--------------

Screening Date	19-Feb-2025	Docket No.	2025-0265-PWS-E	PCW
Respondent	Undine Texas, LLC			
Case ID No.	67418			
Reg. Ent. Reference No.	RN102679842			
Media	Public Water Supply			
Enf. Coordinator	Mason DeMasi			

Policy Revision 5 (January 28, 2021)

PCW Revision February 11, 2021

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Number	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	1	5%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	1	20%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 25%

>> Repeat Violator (Subtotal 3)

N/A

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

Unclassified

Adjustment Percentage (Subtotal 7) 0%

>> Compliance History Summary

Compliance History Notes

Enhancement for one NOV with the same/similar violations and one agreed order containing denial of liability.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) 25%

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100% 25%

Screening Date 19-Feb-2025 Respondent Undine Texas, LLC Case ID No. 67418 Reg. Ent. Reference No. RN102679842 Media Public Water Supply Enf. Coordinator Mason DeMasi	Docket No. 2025-0265-PWS-E <div style="text-align: right;"> PCW <i>Policy Revision 5 (January 28, 2021)</i> <i>PCW Revision February 11, 2021</i> </div>
--	---

Violation Number	1		
Rule Cite(s)	30 Tex. Admin. Code § 290.45(b)(1)(C)(i) and Tex. Health & Safety Code § 341.0315(c)		
Violation Description	Failed to provide a well capacity of 0.6 gallons per minute ("gpm") per connection. Specifically, the Facility had 112 connections requiring a well capacity of 67.2 gpm. However, only 38 gpm of well capacity was provided, indicating a 43.5% deficiency.		

Base Penalty	\$5,000
---------------------	---------

>> Environmental, Property and Human Health Matrix

OR		Harm			
	Release	Major	Moderate	Minor	
	Actual				
	Potential		x		Percent 15.0%

>> Programmatic Matrix

	Falsification	Major	Moderate	Minor	
					Percent 0.0%

Matrix Notes	Failure to provide adequate well capacity could expose persons served by the Facility to a significant amount of contaminants which would not exceed levels protective of human health.
--------------	---

Adjustment	\$4,250
-------------------	---------

	\$750
--	-------

Violation Events

Number of Violation Events	1	15	Number of violation days
----------------------------	---	----	--------------------------

	daily		Violation Base Penalty \$750
	weekly		
	monthly		
	quarterly	x	
	semiannual		
	annual		
	single event		

One quarterly event is recommended, calculated from the February 4, 2025 record review to the February 19, 2025 screening date.

Good Faith Efforts to Comply

0.0%	Reduction
Before NOE/NOV NOE/NOV to EDPRP/Settlement Offer	
Extraordinary	
Ordinary	
N/A	x
Notes	The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal	\$750
---------------------------	-------

Economic Benefit (EB) for this violation

Estimated EB Amount	\$608
----------------------------	-------

Statutory Limit Test

Violation Final Penalty Total	\$938
--------------------------------------	-------

This violation Final Assessed Penalty (adjusted for limits)	\$938
--	-------

Economic Benefit Worksheet

Respondent Undine Texas, LLC
Case ID No. 67418
Reg. Ent. Reference No. RN102679842
Media Public Water Supply
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Costs Saved	EB Amount
------------------	-----------	---------------	------------	-----	----------------	-------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/Construction	\$5,000	5-Jun-2024	1-Mar-2026	1.74	\$29	\$579	\$608
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0
Notes for DELAYED costs	The delayed cost includes the estimated amount to provide a well capacity of at least 0.6 gpm per connection, calculated from the date of the investigation initially documenting the violation to the estimated date of compliance.						

Avoided Costs

ANNUALIZE avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance				0.00	\$0	\$0	\$0
ONE-TIME avoided costs				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Notes for AVOIDED costs							

Approx. Cost of Compliance	\$5,000	TOTAL	\$608
----------------------------	---------	--------------	-------



Compliance History Report

Compliance History Report for CN605397827, RN102679842, Rating Year 2024 which includes Compliance History (CH) components from September 1, 2019, through August 31, 2024.

Customer, Respondent, or Owner/Operator: CN605397827, Undine Texas, LLC **Classification:** UNCLASSIFIED **Rating:** -----

Regulated Entity: RN102679842, CROWLEY II ACRE SUBDIVISION **Classification:** NOT APPLICABLE **Rating:** N/A

Complexity Points: N/A **Repeat Violator:** N/A

CH Group: 14 - Other

Location: 750 FEET NORTH OF THE INTERSECTION OF COUNTY ROAD 1015 AND ROCK CREEK ROAD IN CROWLEY, JOHNSON COUNTY, TEXAS

TCEQ Region: REGION 04 - DFW METROPLEX

ID Number(s):
PUBLIC WATER SYSTEM/SUPPLY REGISTRATION 1260012

Compliance History Period: September 01, 2019 to August 31, 2024 **Rating Year:** 2024 **Rating Date:** 09/01/2024

Date Compliance History Report Prepared: June 02, 2025

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: June 02, 2020 to June 02, 2025

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.
Name: Mason DeMasi **Phone:** (210) 657-8425

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

- 1 Effective Date: 10/05/2021 ADMINORDER 2021-0019-PWS-E (1660 Order-Agreed Order With Denial)
Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C)(i)
5A THSC Chapter 341, SubChapter A 341.0315(c)
Description: Failure to provide a minimum production capacity of 0.6 gallons per minute (gpm) per connection.
EIC B18(c)(9) Mod(2)(G)

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1 February 27, 2024 (1938882)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

- 1 Date: 08/23/2024 (1988527)

Self Report?	NO	Classification:	Moderate
Citation:	30 TAC Chapter 290, SubChapter D 290.46(f)(2) 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B) 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(iv)		
Description:	Failure to calibrate the well meters for Wells 1, 2, and 4 at least once every three years. EIC B1 MOD(2)(E)		
Self Report?	NO	Classification:	Moderate
Citation:	30 TAC Chapter 290, SubChapter D 290.45(b)(1) 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C) 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C)(i)		
Description:	Failure to provide the minimum required production capacity of 0.6 gallons per minute (gpm) per connection. EIC B18.c.(10) MOD 2(G)		

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

Component Appendices

Appendix A

All NOVs Issued During Component Period 6/2/2020 and 6/2/2025

1	Date: 08/12/2020 (1665093)	
	Self Report? NO	Classification: Minor
	Citation: 30 TAC Chapter 290, SubChapter D 290.46(r)	
	Description: Failure to provide a minimum pressure of 35 psi throughout the distribution system under normal operating conditions.	
	C4, Minor (3)(D)	
	Self Report? NO	Classification: Moderate
	Citation: 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C)(i) 5A THSC Chapter 341, SubChapter A 341.0315(c)	
	Description: Failure to provide a minimum production capacity of 0.6 gallons per minute (gpm) per connection. EIC B18(c)(9) Mod(2)(G)	
2*	Date: 08/23/2024 (1988527)	
	Self Report? NO	Classification: Moderate
	Citation: 30 TAC Chapter 290, SubChapter D 290.46(f)(2) 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B) 30 TAC Chapter 290, SubChapter D 290.46(f)(3)(B)(iv)	
	Description: Failure to calibrate the well meters for Wells 1, 2, and 4 at least once every three years. EIC B1 MOD(2)(E)	
	Self Report? NO	Classification: Moderate
	Citation: 30 TAC Chapter 290, SubChapter D 290.45(b)(1) 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C) 30 TAC Chapter 290, SubChapter D 290.45(b)(1)(C)(i)	
	Description: Failure to provide the minimum required production capacity of 0.6 gallons per minute (gpm) per connection. EIC B18.c.(10) MOD 2(G)	

* NOVs applicable for the Compliance History rating period 9/1/2019 to 8/31/2024

Appendix B

All Investigations Conducted During Component Period June 02, 2020 and June 02, 2025

Item 1	August 10, 2020**	(1665093)
Item 2	December 04, 2020**	(1691374)
Item 3*	February 27, 2024**	(1938882)
Item 4	August 19, 2024**	(1988527)
Item 5	November 19, 2024	(2022530)
Item 6	February 12, 2025	(2039909)

* No violations documented during this investigation

**Investigation applicable for the Compliance History Rating period between 09/01/2019 and 08/31/2024.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
UNDINE TEXAS, LLC
RN102679842

§ BEFORE THE
§ TEXAS COMMISSION ON
§ ENVIRONMENTAL QUALITY
§

AGREED ORDER DOCKET NO. 2025-0265-PWS-E

On _____, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Undine Texas, LLC (the "Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 341. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent presented this Order to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated agreement of the parties. The provisions of this Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a public water supply located approximately 750 feet north of the intersection of County Road 1015 and Rock Creek Road in Crowley, Johnson County, Texas (the "Facility"). The Facility provides water for human consumption, has approximately 112 service connections, and serves at least 25 people per day for at least 60 days per year. As such, the Facility is a public water system as defined in 30 TEX. ADMIN. CODE § 290.38(73).
2. During a record review for the Facility conducted on February 4, 2025, an investigator documented that the Facility had 112 connections requiring a well capacity of 67.2 gallons per minute ("gpm"). However, only 38 gpm of well capacity was provided, indicating an 43.5% deficiency.

II. CONCLUSIONS OF LAW

1. As evidenced by Finding of Fact No. 1, the Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. HEALTH & SAFETY CODE ch. 341 and the rules of the TCEQ.
2. As evidenced by Finding of Fact No. 2, the Respondent failed to provide a well capacity of 0.6 gpm per connection, in violation of 30 TEX. ADMIN. CODE § 290.45(b)(1)(C)(i) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
3. Pursuant to TEX. HEALTH & SAFETY CODE § 341.049(a), the TCEQ has the authority to assess an administrative penalty against the Respondent for violations of state statutes within the TCEQ's jurisdiction, for violations of rules adopted under such statutes, or for violations of orders or permits issued under such statutes.
4. An administrative penalty in the amount of \$937 is justified by the facts recited in this Order, and considered in light of the factors set forth in TEX. HEALTH & SAFETY CODE § 341.049(b). The Respondent paid the \$937 penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed a penalty as set forth in Conclusion of Law No. 4 for violations of state statutes and rules of the TCEQ. The payment of this penalty and the Respondent's compliance with all the requirements set forth in this Order resolve only the matters set forth by this Order in this action. The Commission shall not be constrained in any manner from requiring corrective actions or penalties for violations that are not raised here. Penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Undine Texas, LLC, Docket No. 2025-0265-PWS-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088
2. The Respondent shall undertake the following technical requirements:
 - a. Within 180 days after the effective date of this Order, provide a well capacity of at least 0.6 gallons per connection, in accordance with 30 TEX. ADMIN. CODE § 290.45.
 - b. Within 195 days after the effective date of this Order, submit written certification, and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision No. 2.a. The certification shall be signed by the Respondent and shall include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

The certification shall be submitted to:

Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Water Section Manager
Dallas/Fort Worth Regional Office
Texas Commission on Environmental Quality
2309 Gravel Drive
Fort Worth, Texas 76118-6951

3. All relief not expressly granted in this Order is denied.
4. The duties and provisions imposed by this Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of this Order to personnel who maintain day-to-day control over the Facility operations referenced in this Order.
5. The Executive Director may grant an extension of any deadline in this Order or in any plan, report, or other document submitted pursuant to this Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director. Extension requests shall be sent to the Enforcement Division at the address listed above.
6. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms in this Order.
7. This Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Order, whichever is later.
8. This Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Order; or (2) pursue violations of a statute within the Commission's

jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.

9. This Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms: electronic transmission, owner, person, writing, and written, shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.
10. The effective date of this Order is the date it is signed by the Commission. A copy of this fully executed Order shall be provided to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Date



For the Executive Director

09/07/2025

Date

I, the undersigned, have read and understand the attached Order. I am authorized to agree to the attached Order, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this Order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the OAG for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the OAG of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.


In addition, any falsification of any compliance documents may result in criminal prosecution.

William A. Thomas

Signature

____July 1, 2025____

Date



Name (Printed or typed)
Authorized Representative of
Undine Texas, LLC

__Sr. VP
_Title

☐ *If mailing address has changed, please check this box and provide the new address below:*

Instructions: Send the original, signed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Ordering Provision 1 of this Order.