
## **Appendix C: Example FPR**


VIELIC WATER	City of Example 1294567		LANT NAME R NUMBER: Treat	Treatment Plant	
W5 ID No.:			onth: Febru	EST DATE OF THE STREET	
	OBVIOUS REASONS				
		FILTER NO.: 1 DATE: 02-04-02 TIME: 15-00 AM DURATION: 45-00 TURBIDITY: 1.23	TIME: 7	FILTER NO.: 5 0-04-02 DATE: 03-04-02 15-FM TIME: 11-45-AM 5.05 DURATION: 15-00 57 TURBIOTY: 1-05	
100 W D 100 C 100	<u>IONS</u> (Check all that apply) ED - A Filter Profile must be submitted	(See Profile No. )	☐ ¿See Protie f	No. ) [ (See Profile No. )	
Filter Problems		a (see Francis)	- inechione	/ <b>_</b>	
Post Sackwash Turbidity Spike Protonged Filter Run Time Excessive Filter-Loading Flate Rate of Flow Control Valve Faiture Media Defects (insufficient depth, mudballs, etc.) Inadequate Surface Wash or Backwash Facisties Backwash Artfact Turbidineter Errors		000000	8000000	000000	
Incorrect Ca Air Bubble		8		B	
Debris			: D:		
Coaguant.	Equipment Failure	0	0		
Coagulant A	No.	8		8	
Filter Aid Poor Raw Water	r Quality	ă	ä	ä	
	t Process Failures Maintenance Activities	0		Backwash Filter No. 1	
		CONTROLS DELEGATE			
		OBVIOUS REASONS	FILTER NO.:	FILTER NO.:	
ORISONO PEAN		DATE: 02:13:00 TIME: 2:15:P0 DURATION: 15:00 TURBIDITY: 1:24	DATE: TIME: DURATION: TURBIDITY:	DATE: TIME: DURATION: TURRIDITY:	
NONE IDENTIFI	SN(S (Check all that apply) ED - A Filter Profile must be submitted	☑ (See Profile No. 1 )	☐ (See Profile)	No /	
Protonged F Excessive F Rate-of-Flox Media Deter	ash Turbidity Spike Ster Run Time Ster-Loading Rale v Control Valve Failure Sta (insufficient depth, mudbalta, etc.) Surface Wash or Buckwash Facilities	000000	000000	مممممم	
Turbidimeter & Incorrect Ca Air Bubble Debris	ilbration			000	
Chemical Feed Coagulant		00	000	000	
Coagulant A Filter Aid	Quality				

June 2022 245

UBLIC WATER	City of Example		PLANT NAME OR NUMBER	Trestment Plant	
WS ID No.;	1234567		Month:	February	Year: 2002
		NARRATIVE DESCRIPTION OF	FILTER PROFILE		
FILTER NO.: PROFILE NO.:	—	DATE OF PROFILE:	econorce action no	55	
DETAILS: 45-minute ide tin offline for the day made during the 11 there was a sig 21 the 4 for IFE to 31 a turbidity opix 41 the maximum of 51 the alter was 51 the alter was 63 the alter ide 71 the 4 for IFE to 81 at 2:35 pro on	ne that we allow for filter pre-cipens. Filter No.5 was backwashed and filter profile include: gnificant increase in the IFE turbid ribidity level on Filter No. 5 was sec a was observed when Filter No. 3 and 15 m Filter No. 3 are severe, turbidity spike that occurre no eading for Filter No. 5 occurred at 1 the 20th, we took Filter No. 6 offlin	to began at 1:28 pm on Tuesday, February 1: ng. The filter profile edded at 12:30 am on Thu- metured before the plant was returned to sensi- by level at 0:00 pm on the 19th when the plant coded at 12:20 pm and was 0:202 NTU. was taken office and backwashed at 8:28 pm let No. 5 occurred at 8:30 pm on the 19th with of less not stated up again until 8:00 m on V d at 11:46 am on the 20th was an unusual rea- 2:00 pm and was 0:235 NTU.	reday, February 21, 21 se the following morns is production rate was on the 8th, is we were backwashi ladeweday, February ding that occurred wh	002, when the plant was ing. Some specific observa- increased from 9.6 MGD ing Fitter No. 3 2001 en we flushed the surbidin	sten stone we to 10.2 MGD.
FILTER NO.: PROFILE NO.: DETAILS:	=	NARRATIVE DESCRIPTION OF DATE OF PROFILE:	FILTER PROFILI		
PROFILE NO.:			FILTER PROFILI		

**246** June 2022





June 2022 247