



Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

August 21, 2015

Mr. Thomas Poschmann
Beijing Scinor Membrane Technology Co., Ltd
16 Mallard Cove
Centerpoint, New York 11721

Re: Beijing Scinor Membrane Technologies SMT 600-P50 and SMT 600-P80 UF Modules
Review and Approval of Challenge Testing
Removal of Microbial Contaminants

Dear Mr. Poschmann:

Membrane filtration systems installed on, or replaced after, April 1, 2012 for the removal of *Cryptosporidium* and *Giardia* must undergo challenge testing to evaluate the membrane's removal efficiency and for the Texas Commission on Environmental Quality (TCEQ) to establish a challenge test log removal value (LRV_{C-Test}) as required by Title 30 of the Texas Administrative Code (30 TAC) §290.42(g)(3). In addition, these TCEQ regulations require a membrane manufacturer to provide the non-destructive performance test (NDPT) and associated quality control release value (QCRV) that will be used to verify that all manufactured membrane modules, which were not subject to challenge testing, will achieve at least the same log removal as those that were challenge tested.

On May 6, 2015, the TCEQ received a copy of the May 1, 2015 report of the challenge study conducted on the Beijing Scinor Membrane Technologies (BSMT) SMT 600-P50 ultrafiltration (UF) membrane modules. The NSF International report stated that the data for the SMT 600-P50 module can be transferred to the SMT 600-P80 module provided that the same QCRV and Non-Destructive Performance Test (NDPT) are used. Therefore, this letter addresses the review and approval of both the SMT 600-P50 and SMT-P80 UF modules.

The NSF International challenge study was conducted in accordance with NSF International (NSF)/American National Standards Institute (ANSI) Standard 419-2015: Public Drinking Water Equipment Performance - Filtration. According to the Test Report, the NSF/ANSI Standard 419 is based on the Environmental Technology Verification (ETV) *Generic Protocol for the Product Specific Challenge Testing of Microfiltration or Ultrafiltration Modules* (May 2011) and the product-specific challenge testing requirements in the United States Environmental Protection Agency (USEPA) Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR). The NSF certification of performance is only based on reduction of *Cryptosporidium* as it is linked to QCRV.

CHALLENGE STUDY DATA FOR SMT 600-P50 UF MEMBRANE MODULES

We reviewed the submitted challenge study data for compliance with the *Cryptosporidium* treatment requirements in the LT2ESWTR. The criteria for compliance is found in Title 40 of the Code of Federal Regulations (40 CFR) §141.719(b)(2). Additional guidance for compliance with these requirements can be found in the USEPA Membrane Filtration Guidance Manual (EPA 815-R-06-009). Based on our review of the challenge study data for the SMT 600-P50 UF membrane modules, we have determined that the challenge study is compliant with LT2ESWTR requirements. Please review the conditions in the following pages regarding the approved log removal value demonstrated

during challenge testing (LRV_{C-Test}) and the approved NDPT for production membrane modules that did not undergo challenge testing.

TCEQ-APPROVED LRV_{C-TEST}

For the Beijing Scinor Membrane Technologies SMT 600-P50 and SMT-P80 UF modules, the TCEQ is approving a **LRV_{C-Test} of 6.26** for the removal of *Cryptosporidium* for systems operated in deposition mode. The LRV_{C-Test} approval by the TCEQ does not apply to systems operated in cross flow mode, as this hydraulic configuration was not demonstrated in this challenge test study. The following are the parameters of the approved challenge study:

Full-scale module tested	Beijing Scinor Membrane Technologies SMT 600-P50 UF Modules
Number of Independent Modules Tested	5
Criterion of Selected Modules	None*
Model Number / Part Number / Serial Numbers of Tested Modules	BC201100001, BC201100002, BC201100005, BC201100004 and BC201100006
Nondestructive Performance Testing (NDPT) Process	Pressure Decay Test
Quality Control Release Value (QCRV)	0.088 pounds per square inch (psi) per minute (min.)
Challenge Particulate	<i>Bacillus atrophaeus</i> (as a surrogate for <i>Cryptosporidium</i>) with an average diameter of 0.8 μ m and an average length of 1.8 μ m
Detection Limit	1 colony forming unit (CFU) per 100 milliliters (mL)
Feed Concentration Range	1.81×10^6 to 2.7×10^6 CFU per 100 mL
Max Filtrate Flux Rate	120 gallons per square-foot per day (gfd) @ 20° C
Mode of Operation / Flow Configuration	Deposition mode / Outside In

* In regards to the selection of modules for testing, there was no consideration of manufacturing variability. However, the challenge study established a quality control release value (QCRV) of 0.088 psi/min. based on the pressure decay test results of the modules used to establish the LRV_{C-Test} (as required by 40 CFR 141.719(b)(2)(vii)). Any membrane module that does not meet the QCRV established in the challenge study is not eligible for the approved LRV_{C-Test} of 6.26-log.

LIMITS OF TCEQ-APPROVED LRV_{C-TEST}

The TCEQ-approved LRV_{C-Test} is valid for only the Beijing Scinor Membrane Technologies SMT 600-P50 and SMT 600-P80 UF modules operated under the parameters used for the challenge testing and only for modules that have passed the NDPT. From our review of the challenge study, an acceptable SMT 600-P50 or SMT 600-P80 UF module must comply with the following specifications to receive the TCEQ-approved LRV_{C-Test} :

- 1) Specifications of the approved Beijing Scinor Membrane Technologies SMT 600-P50 and SMT-P80 UF modules:
 - a) Polyvinylidene fluoride (PVDF) hollow fiber membranes;
 - b) Nominal membrane pore size of 0.01 μ m (0.01 microns);
 - c) Fiber inner diameter - 0.7 millimeters (mm)
 - d) Fiber outer diameter - 1.3 mm
 - e) Module diameter - 160 mm

- f) Nominal membrane surface area of 538.2-ft² (SMT 600-P50) and 861-ft²(SMT 600-P80);
 - g) An outside-to-inside flow path;
 - h) Operational mode: deposition (no cross-flow);
 - i) Maximum filtrate flux at 20 °C: 120 gallons per square-foot per day (gfd);
 - j) Maximum operating temperature of 40° C (104°F);
 - k) Maximum trans-membrane pressure (TMP) of 43.5 psi;
 - l) Operating pH range: 1 – 11; and,
 - m) Maximum chlorine tolerance: 5,000 mg/L.
- 2) For use by public water systems in Texas for microbial contaminant removal credit, only Beijing Scinor Membrane Technologies SMT 600-P50 and SMT 600-P80 UF modules that have been certified for performance by NSF International are allowed. As defined in the NSF International challenge study report (page 13), this means that only modules that have passed a Non-Destructive Performance Test with a Quality Control Release Value (QCRV) of 0.088 psi/min.
 - 3) The Beijing Scinor Membrane Technologies must record the results of each SMT 600-P50 and SMT 600-P80 UF membrane module's NDPT with the module's assigned unique serial number. The NDPT result for each SMT 600-P50 and SMT 600-P80 UF membrane module delivered to a Texas PWS must be provided upon delivery of the SMT 600-P50 and SMT 600-P80 UF membrane modules to a system.
 - 4) The Beijing Scinor Membrane Technologies must notify the TCEQ in writing if the SMT 600-P50 or SMT 600-P80 UF membrane modules are modified, or if the NDPT method is modified in any manner. After receiving written notification, the TCEQ shall determine if the modified SMT 600-P50 or SMT 600-P80 UF membrane module shall be required to undergo challenge testing or if the modified NDPT method is acceptable.
 - 5) The TCEQ shall grant log removal credits to Texas PWSs using membrane filtration for *Giardia* and *Cryptosporidium*. The log removal credits shall not exceed the lower of:
 - a) The TCEQ-approved LRV_{C-Test}; or,
 - b) The maximum removal efficiency that can be verified through a membrane unit's site-specific direct integrity test (LRV_{DIR}).
 - 6) Each SMT 600-P50 and SMT 600-P80 UF membrane module must conform to American National Standards Institute/NSF International (ANSI/NSF) Standard 61 and must be certified by a testing organization accredited by ANSI.
 - 7) Please note that the approved LRV_{C-Test} is for the current Federal and Texas statutes, and the EPA and TCEQ rules. If any of these statutes or rules are revised, the TCEQ-approved LRV_{C-Test} in this letter may also be revised.

Please provide a copy of this letter to each of your Texas PWS customers. This letter is **not** to be construed as:

- A granted TCEQ exception for any Texas PWS to use the Beijing Scinor Membrane Technologies SMT 600-P50 or SMT 600-P80 UF membrane modules. Each Texas PWS must request and receive site-specific approval to use membrane filtration in accordance with 30 TAC §290.42(g) and §290.39(l);
- TCEQ approval for a Texas PWS to install a Beijing Scinor Membrane Technologies SMT 600-P50 or SMT 600-P80 UF membrane module; or
- TCEQ approval for the Texas public water system's required concentration time (CT) study.

Mr. Thomas Poschmann
Page 4 of 4
August 21, 2015

If you have any questions about this letter, or if we can be of additional assistance, please contact David A. Williams, P.E., at the letterhead address, by e-mail at david.a.williams@tceq.texas.gov, or by telephone at (512) 239-0945.

Sincerely,



David A. Williams, P.E.
Technical Review and Oversight Team
Plan & Technical Review Section
Texas Commission on Environmental Quality



Joel Klumpp, Manager
Plan & Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

JPK/daw

cc: Mr. James C. Vickers, Separation Processes, Inc., 3156 Lionshead Ave., Suite 2, Carlsbad, California 92010