

40 CFR Part 60, Subpart D: Standards of Performance for Fossil-Fuel-Fired Steam Generators - Requirements Reference Tables

Subpart D Standards

- [§60.42\(a\)\(1\)](#) Particulate matter requirements
- [§60.42\(a\)\(2\)](#) PM Opacity requirements
- [§60.42\(b\)\(1\)](#) PM Opacity requirements for Southwestern Public Service Company's Harrington Station #1
- [§60.42\(c\)](#) §60.42Da(a) alternate to meeting requirements for particulate matter
- [§60.43\(a\)\(1\)](#) SO₂ requirements for liquid fossil fuel or liquid fossil fuel/wood residue facilities
- [§60.43\(a\)\(2\)](#) SO₂ requirements for solid fossil fuel or solid fossil fuel/wood residue facilities
- [§60.43\(b\)](#) SO₂ requirements for facilities combusting liquid and solid fossil fuels simultaneously (with or without wood residue)
- [§60.43\(d\)1](#) §60.43Da(i)(3) alternate to meeting SO₂ requirements
- [§60.43\(d\)2](#) §60.42b(k)(4) alternate to meeting SO₂
- [§60.44\(a\)\(1\)](#) NO_x requirements for gaseous fossil fuel facilities
- [§60.44\(a\)\(2\)](#) NO_x requirements for liquid fossil fuel, liquid fossil fuel/wood residue, or gaseous fossil fuel/wood residue
- [§60.44\(a\)\(3\)](#) NO_x requirements for solid fossil fuel or solid fossil fuel/wood residue (except lignite)
- [§60.44\(a\)\(4\)](#) NO_x requirements for lignite or lignite/wood residue facilities
- [§60.44\(a\)\(5\)](#) NO_x requirements for lignite mined in ND, SD, MT and cyclone-fired unit
- [§60.44\(b\)](#) NO_x requirements for facilities combusting fossil fuels simultaneously
- [§60.44\(c\)](#) NO_x requirements for facilities combusting in combination coal refuse (25%w) with gaseous, liquid, or other solid fossil fuels or wood residue
- [§60.44\(e\)](#) §60.44Da(e)(3) alternate to meeting NO_x requirements which necessitate specific reporting

These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.

Last modified: February 18, 2022