

40 CFR Part 63, Subpart EEEE – Storage Tanks - Requirements Reference Tables

MACT EEEE – Storage Tanks - Standards

- [§63.2343\(a\)1](#) Exemption for storage tanks with capacity less than 5000 gallons
- [§63.2343\(b\)](#) Exemption for storage tanks with capacity greater than or equal to 5000 gallons that do not meet the criteria in Table 2 or Table 2b of 40 CFR Part 63, Subpart EEEE.
- [§63.2346\(a\)\(1\)–Table 2.1.a.i1](#) Storage tanks must reduce total organic HAP emissions by 95% by weight by venting emissions through a closed vent system to any combination of control devices meeting the requirements of 40 CFR Part 63, Subpart SS.
- [§63.2346\(a\)\(1\)–Table 2.1.a.i2](#) Storage tanks must reduce total organic HAP emissions to an exhaust concentration of 20 ppmv by venting emissions through a closed vent system to any combination of control devices meeting the requirements of 40 CFR Part 63, Subpart SS.
- [§63.2346\(a\)\(2\)](#) Emissions from the storage tank are routed to a fuel gas system or back to a process as specified in 40 CFR Part 63, Subpart SS.
- [§63.2346–Table 4.1.a1](#) The storage tank is using an internal floating roof in compliance with 40 CFR Part 63, Subpart WW for control.
- [§63.2346–Table 4.1.a2](#) The storage tank is using an external floating roof in compliance with 40 CFR Part 63, Subpart WW for control.
- [§63.2346–Table 4.1.a3](#) The storage tank is using a floating roof equivalent in compliance with 40 CFR Part 63, Subpart WW for control.
- [§63.2346\(a\)\(4\)](#) The storage tank uses a vapor balancing system.
- [§63.2346\(a\)\(5\)–Table 2b.1.a.i1](#) Storage tanks must reduce total organic HAP emissions by 95% by weight by venting emissions through a closed vent system to a flare meeting the requirements of §63.983 and §63.2380.
- [§63.2346\(a\)\(5\)–Table 2b.1.a.i2](#) Storage tanks must reduce total organic HAP emissions to an exhaust concentration of 20 ppmv by venting emissions through a closed vent system to a flare meeting the requirements of §63.983 and §63.2380.
- [§63.2346\(a\)\(5\)–Table 2b.1.a.i3](#) Storage tanks must reduce total organic HAP emissions by 95% by weight by venting emissions through a closed vent system to any combination of nonflare control devices meeting the requirements of 40 CFR Part 63, Subpart SS and §63.2346(l).
- [§63.2346\(a\)\(5\)–Table 2b.1.a.i1](#) Storage tanks must reduce total organic HAP emissions to an exhaust concentration of 20 ppmv by venting emissions through a closed vent system to any combination of nonflare control devices meeting the requirements of 40 CFR Part 63, Subpart SS and §63.2346(l).
- [§63.2346\(g\)](#) Alternative Means of Compliance for 40 CFR Part 63, Subpart EEEE
- [§63.2396\(a\)\(1\)](#) Exemption for storage tanks that are controlled with a floating roof and in compliance with either 40 CFR Part 60, Subpart Kb or 40 CFR Part 61, Subpart Y.
- [§63.2396\(a\)\(2\)1](#) Storage tanks at an OLD affected source are in compliance with this subpart if the storage tank has a fixed roof and is controlled with a closed vent system and control device and is in compliance with 40 CFR Part 60, Subpart Kb while meeting the monitoring, recordkeeping, and reporting requirements of this subpart.
- [§63.2396\(a\)\(2\)2](#) Storage tanks at an OLD affected source are in compliance with this subpart if the storage tank has a fixed roof and is controlled with a closed vent system and control device and is in compliance with 40 CFR Part 61, Subpart Y while meeting the monitoring, recordkeeping, and reporting requirements of this subpart

These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.