

40 CFR 60 Subpart Da - Rule Interpretation Memos

! [Typographical error in citation § 60.47a\(h\)\(3\) -Retired.](#) [November 10, 1998]

! [Typographical error in §60.47a\(I\)\(4\).](#) [December 10, 1998]

Last Modified: October 17, 2000

Retired as a result of amendments to 40 CFR Part 60, Subpart Da adopted on 10/17/2000 (Federal Register, Volume 65, pg. 61744

Last Modified: October 17, 2000

Rule Interpretation Summary Form

Code Number	60D_a.002
-------------	-----------

Rule/Regulation Citation(s):	<div style="display: flex; justify-content: space-between;"> Federal Rule: <u> X </u> State Regulation: <u> </u> </div> Description:
40 C.F.R. Part 60, Subpart Da	Standards of Performance for Electric Utility Steam Generating Units for Which Construction Is Commenced After September 18, 1978
Interpretation Request:	
There is a typographical error in Title 40 Code of Federal Regulations Part 60 (40 C.F.R. 60) § 60.47a(i)(4) in the sentence “All span values computed under paragraph (b)(3) of this section for burning combinations of fossil fuels are rounded to the nearest 500 ppm.” Should 40 C.F.R. § 60.47a(i)(4) read: “All span values computed under paragraph (i)(3) of this section for burning combinations of fossil fuels are rounded to the nearest 500 ppm.”?	
Determination:	
The reference to paragraph “(b)(3)” contained in 40 C.F.R. § 60.47a(i)(4) should be “(i)(3).”	

Bibliography:

40 C.F.R. Part 60, Subpart Da (Revised as of July 1, 1997)

40 C.F.R. Part 60, Method 19, Appendix A (Revised as of July 1, 1997)

Please note, in the event that an external customer feels that this rule interpretation is in error or a source of information has been overlooked which would change the determination, a request for reconsideration may be submitted. Requests must be submitted on a Reconsideration Process Form which is available at the TNRCC's homepage: <http://www.tnrcc.state.tx.us/air/opd/rmhmpg.htm>, or from any of the rule interpretation team members. [AOPDG95A/10101-v2]