

30 TAC 115/140, Industrial Wastewater - Requirements Reference Tables

30 TAC 115/140 Standards

- [§115.142\(1\)](#) Wastewater component fully covered or equipped with water seal controls.
- [§115.142\(1\)\(D\)\(i\)2](#) Vapor control system requirements for wastewater drains, lift stations, and weirs with vented covers in the Dallas-Fort Worth, El Paso, and Houston-Galveston-Brazoria (until 12/31/02) areas
- [§115.142\(1\)\(D\)\(ii\)\(I\)](#) Vapor control system requirements for wastewater drains, junction boxes, lift stations, and weirs with vented covers in the Beaumont-Port Arthur, Bexar County and Houston-Galveston-Brazoria (after 12/31/02) areas
- [§115.142\(2\)](#) Wastewater component equipped with an internal or external floating roof.
- [§115.142\(3\)](#) Properly operated biotreatment units in the Beaumont-Port Arthur and Bexar County areas, and after December 31, 2002 in the Houston-Galveston-Brazoria area.
- [§115.143\(a\)](#) Alternate means of control.
- [§115.143\(b\)](#) 90% overall control option.
- [§115.147\(2\)](#) Annual VOC loading in wastewater less than 10 Mg (11.03 tons).
- [§115.147\(4\)](#) Safety hazard exemption.
- [§115.147\(7\)\(C\)](#) Properly operated biotreatment units in petroleum refineries in the Houston-Galveston-Brazoria area.

These requirement reference tables are for sources subject to the Texas Federal Operating Permits Program and subject to revision.

Last Modified: September 8, 2025