

30 TAC Chapter 115 Highly-Reactive VOCs-Cooling Tower Heat Exchange Systems - Requirements Reference Tables

30 TAC 115/760 Standards

- [§115.761\(c\)\(1\)](#) Harris County
- [§115.761\(c\)\(2\)](#) Houston/Galveston/Brazoria area, excluding Harris county
- [§115.767\(1\)](#) Exemption for heat exchanger with greater than 100 ppmw HRVOC in the process side fluid operated with the minimum pressure on the cooling water side at least five psig greater than the maximum pressure on the process side
- [§115.767\(2\)](#) Exemption for heat exchanger with less than 100 ppmw HRVOCs in the process side fluid
- [§115.767\(3\)](#) Exemption from the requirements of §115.761 to a cooling tower heat exchange system for which no stream directed to a cooling tower exchange system contains 5.0% or greater by weight HRVOC contains 5.0% or greater by weight HRVOC
- [§115.767\(4\)](#) Exemption for cooling tower heat exchange systems that was permanently out of service by April 1, 2006
- [§115.767\(5\)](#) Exemption for cooling tower heat exchange systems with an intervening cooling fluid containing less than 100 ppmw of HRVOC between the process and the cooling water
- [§115.767\(6\)](#) Exemption from §115.761(b) and (c)(2) for cooling tower heat exchange systems that are located in the Houston/ Galveston/Brazoria area, excluding Harris County

These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.

Last modified: January 08, 2008