

30 TAC Chapter 117, Subchapter B, Division 4: Engines Requirements Reference Tables

30 TAC 117/Engine Standards

- [§117.403\(a\)\(7\)\(D\)](#) Exemption for stationary internal combustion engines that are used exclusively in emergency situations
- [§117.403\(a\)\(8\)](#) Exemption for stationary diesel engine placed into service before June 1, 2007, that operates less than 100 hours per year
- [§117.403\(a\)\(9\)](#) Exemption for stationary diesel engine placed into service on or after June 1, 2007, that operates less than 100 hours per year and meets the requirements for non-road engines as specified
- [§117.403\(b\)\(2\)\(D\)](#) Exemption for stationary internal combustion engines located in Wise County that are used exclusively in emergency situations
- [§117.405\(b\)\(2\)\(A\)](#) NOx emission limit for gas-fired rich-burn stationary, reciprocating internal combustion engines located in Wise County
- [§117.405\(b\)\(2\)\(B\)\(i\)\(I\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are White Superior four-cycle units place into service before June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(i\)\(II\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are White Superior four-cycle units place into service on or after June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(ii\)\(I\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are Clark two-cycle units place into service before June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(ii\)\(II\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are Clark two-cycle units place into service on or after June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(iii\)\(I\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are Fairbanks Morse MEP two-cycle units place into service before June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(iii\)\(II\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County and are Fairbanks Morse MEP two-cycle units place into service on or after June 1, 2015
- [§117.405\(b\)\(2\)\(B\)\(iv\)](#) NOx emission limit for gas-fired lean-burn stationary, reciprocating internal combustion engines located in Wise County
- [§117.405\(d\)\(1\)](#) CO emission limit for stationary reciprocating internal combustion engines located in Wise County
- [§117.405\(d\)\(2\)](#) NH₃ emission limit for stationary reciprocating internal combustion engines located in Wise County and that inject urea or ammonia into the exhaust stream for NOx control
- [§117.410\(a\)\(4\)\(A\)\(i\)](#) NOx emission limit for gas-fired rich-burn engines fired on landfill gas
- [§117.410\(a\)\(4\)\(A\)\(ii\)](#) NOx emission limit for gas-fired rich-burn engines fired on other than landfill gas
- [§117.410\(a\)\(4\)\(B\)\(i\)](#) NOx emission limit for gas-fired lean-burn engines placed into service before June 1, 2007
- [§117.410\(a\)\(4\)\(B\)\(ii\)\(I\)](#) NOx emission limit for gas-fired lean-burn engines placed into service on or after June 1, 2007 fired on landfill gas
- [§117.410\(a\)\(4\)\(B\)\(ii\)\(II\)](#) NOx emission limit for gas-fired lean-burn engines placed into service on or after June 1, 2007 fired on other than landfill gas
- [§117.410\(a\)\(4\)\(C\)](#) NOx emission limit for dual-fuel engines

- [§117.410\(a\)\(4\)\(D\)](#) NOx emission limit for diesel engines, excluding dual-fuel engines, placed into service before March 1, 2009
- [§117.410\(a\)\(4\)\(E\)\(i\)](#) NOx emission limit for diesel engines, excluding dual-fuel engines, with a hp rating of less than 50 hp that are installed on or after March 1, 2009
- [§117.410\(a\)\(4\)\(E\)\(ii\)](#) NOx emission limit for diesel engines, excluding dual-fuel engines, with a hp rating of 50 hp or greater, but less than 100 hp, that are installed on or after March 1, 2009
- [§117.410\(a\)\(4\)\(E\)\(iii\)](#) NOx emission limit for diesel engines, excluding dual-fuel engines, with a hp rating of 100 hp or greater, but less than 750 hp, that are installed on or after March 1, 2009
- [§117.410\(a\)\(4\)\(E\)\(iv\)](#) NOx emission limit for diesel engines, excluding dual-fuel engines, with a hp rating of 750 hp or greater that are installed on or after March 1, 2009
- [§117.410\(a\)\(14\)](#) Alternative NOx emission specification to §117.410(b)(1)-(13)
- [§117.410\(c\)\(1\)2](#) CO emission limit for all engines
- [§117.410\(c\)\(2\)5](#) NH₃ emission limit for gas-fired lean-burn engines and diesel engines
- [§117.410\(c\)\(2\)7](#) NH₃ emission limit for other than gas-fired lean-burn engines or diesel engines
- [§117.423\(a\)1](#) Alternative NOx emission specification to §117.405 or §117.410 based on source cap limitation
- [§117.425\(a\)1](#) Alternative CO emission specification to §117.405(d) or §117.410(c) as approved by the executive director
- [§117.425\(a\)2](#) Alternative NH₃ emission specification to §117.405(d) or §117.410(c) as approved by the executive director

These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.

Last Modified: October 28, 2024