

**Plain Language Summary for New Source Review (NSR) Renewal Certification  
Application for Air New Source Review Permit Number 108182**

*The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

PHR HOLDINGS LLC (CN605541424) has submitted an application for renewal of permit number 108182. The PH Robinson Electric Generating Station (RN101062826) is an existing peaking electric power generation facility located at 5051 Highway 146, Bacliff, Galveston County, Texas. The facility consists of six (6) natural gas-fired, simple cycled combustion turbines and ancillary equipment, with a nominal output of 71 Megawatts (MW).

This renewal will authorize the continued operation all six (6) turbine peaking units. PHR Holdings LLC has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

<b>Pollutant</b>	<b>Total Amount Allowed (tons per year)</b>
<b>NOx</b>	<b>152.10</b>
<b>CO</b>	<b>188.93</b>
<b>VOC</b>	<b>11.65</b>
<b>PM (TSP)</b>	<b>25.22</b>
<b>PM10</b>	<b>25.22</b>
<b>PM2.5</b>	<b>18.21</b>
<b>SO2</b>	<b>10.22</b>
<b>H2SO4</b>	<b>0.45</b>
<b>HCHO (formaldehyde)</b>	<b>0.82</b>

The combustion turbines being renewed continue to be controlled by Dry Low NOx (DLN) burners capable of achieving 15 ppmvd NOx emissions @ 15% O2 .

PHR HOLDINGS LLC is submitting this application.