

## Soo koobida Luqadda Cad ee Dib u eegista Isha Cusub (NSR) Codsiga Shahaadada Cusboonaysiinta ee Nambarka Ogolaanshaha Dib u Eegista Isha Cusub ee Hawada 1388

*Soo koobida soo socota ayaa lagu bixiyaa codsigan ogolaanshaha hawada ee la sugayo oo ay dib u eegayaan Komishanka Texas ee Tayada Deegaanka sida looga baahan yahay 30 Texas Code Administrative Code matalaadda codsiga ogolaanshaha.*

Shirkadda Adeegga Dadweynaha ee Koonfur-galbeed (CN601481336) waxay soo gudbisay codsiga dib u cusboonaysiinta oggolaanshaha lambarka 1388. Qaybta Dhirta Korontada ee Saldhigga Harrington 1 (RN100224849) waxay soo saartaa koronto 8300 N. Lakeside Drive, Amarillo, Potter County.

Cusboonaysiintani waxay oggolaan doontaa sii socoshada hawlgalka ee Xarunta Harrington Station Unit 1, oo ah gaaska iyo dhuxusha la riday kuleyliyaha uumi-dhalinta koronto dhalisa. Shirkada Adeegga Dadwaynaha ee Koonfur Galbeed ayaa caddeeyay in aysan jiri doonin wax laga bedeli doono ruqsadda. Heerka qiiqa ee la ogol yahay ee soo socda ayaa sii ahaan doona.

<b>wasakhaysan</b>	<b>Wadarta qaddarka la oggol yahay (tan sannadkii)</b>
Nitrogen Oxides	3975
Carbon Monoxide	5247
Volatile Organic Compounds	58.72
Particulate Matter	1263.43
PM10	1259.27
PM2.5	1128.61
Sulfur Dioxide	15080
Fluoride (as Hydrogen Fluoride)	67.8
Hydrogen Chloride	45.6
Beryllium	0.04

Sii daynta PM ee kuleyliyaha Cutubka 1 waxaa lagu kontaroolaa iyadoo la isticmaalayo koronto-dhaliye. Sii daynta kale ee xarumaha dib loo cusboonaysiiyay waxaa xakameeya dhaqamo gubasho oo wanaagsan.