

Plain Language Summary for New Source Review (NSR) Renewal Application for Air New Source Review Permit Number 1467

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

El Paso Electric Company (CN600352819) has submitted an application for renewal of permit number 1467. The Newman Power Station (RN100211309) produces electrical power at Latitude 31° 59' 09" Longitude 106° 25' 56", El Paso, El Paso County.

This renewal will authorize the continued operation of the Newman Power Station, which is an electric generating facility. El Paso Electric Company has listed in the application the pollutants and amounts that will be emitted for each facility. Below is the total amount for each pollutant that is proposed to be emitted each year for all the facilities.

Pollutant	Proposed Emissions (tons per year)
NO _x	2316.79
CO	5205.71
VOC	273.51
PM	213.58
SO ₂	88.79
NH ₃	184.51
H ₂ SO ₄	16.39
H ₂ S	0.1
Cl ₂	0.75
HOCl	0.1
HAPS	6.37

The facilities being renewed continue to be controlled by water injection (S4-1, S4-2), dry low-NO_x combustors (SC-S6A, SC-S6B, SC-7) and selective catalytic reduction (CC-S6A, CC-S6B, SC-7).