Plain Language Summary for New Source Review (NSR) Renewal Certification Appliation for Air New Source Review Permit Number 16907

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Tenet Hospital Limited, (CN601453897) has submitted an application for renewal of Permit Number 16907, Providence Memorial Hospital, (RN100223858) is a hospital located at 2001 North Oregon Street, El Paso, El Paso County, Texas 79902.

This renewal will authorize the continued operation of the two (2) cogeneration units. Tenet Hospitals Limited has certified there will be no changes to the permit. The following permitted emission rates will remain the same

Pollutant	Proposed Emissions (Tons Per Year)
VOC	1.14
NOx	11.96
SO ₂	0.34
PM	0.16
СО	11.38

The facility is being renewed to continue to use 94% natural gas and 6% diesel fuel.