

Plain Language Summary for New Source Review (NSR) Initial Application for Air New Source Review Permit Number 169888L001

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

G & S Concrete, Inc. (CN602742678) has submitted an application for initial permit number 169888L001. The Concrete Crusher (RN111549044) will produce/manufacture crushed concrete at 6425 Stockdick School Road, Katy, Harris County.

This permit will authorize Concrete Crushing Operations. G & S Concrete, Inc. has listed in the application the pollutants and amounts that will be emitted for each facility. Below is the total amount for each pollutant that is proposed to be emitted each year for all the facilities.

| Pollutant | Proposed Emissions (tons per year) |
|------------------|---|
| PM | 2.81 |
| PM10 | 1.85 |
| PM2.5 | 1.25 |
| NOx | 16.25 |
| CO | 3.50 |
| SO2 | 1.07 |
| VOC | 1.29 |

The new facilities will be controlled by water sprays as required.