

Plain Language Summary for New Source Review (NSR) Initial Application for Air New Source Review Permit Number 175211

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

PowerSecure, Inc. (CN604772343) has submitted an application for initial permit number 175211. The Target Store #2917 (RN111851358) will produce/manufacture an electric power generation system at 2655 West University Drive, Denton, Denton County.

This permit will authorize the use of a stationary engine for as needed backup power generation. PowerSecure Inc. has listed in the application the pollutants and amounts that will be emitted for each facility. Below is the total amount for each pollutant that is proposed to be emitted each year for all the facilities.

Pollutant	Proposed Emissions (tons per year)
VOC	0.07
NOx	0.25
CO	1.32
PM	0.01
PM10	0.01
PM2.5	0.01
SO2	<0.01
Other HAPs	0.01

The new facilities will be controlled by installing an EPA certified stationary engine.