

Plain Language Summary for New Source Review (NSR) Initial Application for Air New Source Review Permit Number 182768

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Ascension Texas (CN604397935) has submitted an application for initial permit number 182768. The Ascension Seton Williamson Hospital (RN105862148) will produce/manufacture electrical power at 201 Seton Parkway, Round Rock, Williamson County.

This permit will authorize the construction and operation of diesel-fired stationary engines for emergency and non-emergency operation. Ascension Texas has listed in the application the pollutants and amounts that will be emitted for each facility. Below is the total amount for each pollutant that is proposed to be emitted each year for all the facilities.

Pollutant	Proposed Emissions (tons per year)
NOx	0.72
SO2	<0.01
CO	1.87
VOC	0.01
PM10	0.02
PM2.5	0.02
HAPs	<0.01
Fuel Tank VOCs	<0.01

The new facilities will be controlled by installing USEPA-certified stationary engines.