

**Plain Language Summary for New Source Review (NSR) Renewal Certification
Application for Air New Source Review Permit Number 19225**

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Vistra Operations Company LLC (CN605255900) has submitted an application for renewal of permit number 19225. The Comanche Peak Nuclear Power Plant (RN103044053) produces electricity at 6322 North Farm-to-Market Road 56, Glen Rose, Somervell County.

This renewal will authorize the continued operation of one auxiliary boiler and various maintenance activities. Vistra Operations Company LLC has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
Oxides of nitrogen	1.11
Carbon monoxide	1.11
Volatile organic compounds	0.19
Particulate matter	0.62
Particulate matter with diameters of 10 micrometers or less	0.62
Particulate matter with diameters of 2.5 micrometers or less	0.62
Sulfur dioxide	3.84

The facilities being renewed continue to be controlled by limiting the hours of operation per year and limiting fuels to low-sulfur no. 2 fuel oil. The permit includes references to several emergency-use fire water pump and electric generator engines that are authorized by a Permit by Rule.