

**Plain Language Summary for New Source Review (NSR) Renewal Certification
Application for Air New Source Review Permit Number 21394**

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Brazos Electric Power Cooperative, Inc (CN600128821) has submitted an application for renewal of permit number 21394 The R.W. Miller Plant (RN102033891) produces/manufactures electrical power at 2217 FM 3137, Palo Pinto, Palo Pinto County.

This renewal will authorize the continued operation of two natural gas-fired combustion turbine generators with fuel oil backup firing capability. Brazos Electric Power Cooperative, Inc has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
Nitrogen Oxide (NOx)	322.01
Sulfur Dioxide (SO ₂)	59.8
Carbon Monoxide (CO)	448
Particulate Matter including particulate less than 10 micron in diameter (PM ₁₀)	14.61
Volatile Organic Compounds (VOC)	98.85

The facilities being renewed continue to be controlled by use of limited fuel types with limitation on annual operation.