

Plain Language Summary for New Source Review (NSR) Renewal Certification Application for Air New Source Review Permit Number 3401

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Texas Tech University (CN600272256) has submitted an application for renewal of permit number 3401. The Texas Tech University (RN100213404) produces/manufactures steam at 3224 Main Street, Lubbock, Lubbock County.

This renewal will authorize the continued operation of the boilers located at the Central Heating and Cooling Plants No.1 and No. 2. Texas Tech University has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
Nitrogen oxides	280.58
Carbon monoxide	247.06
Organic compounds	16.16
Sulfur dioxide	8.73
Particulate Matter with diameters of 10 microns or less and 2.5 microns or less	22.92

The facilities being renewed continue to be controlled by [*summary of the type of controls for the facilities being renewed; not a BACT discussion*].