

**Plain Language Summary for New Source Review (NSR) Renewal Certification
Application for Air New Source Review Permit Number 4660**

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Houston (CN600128995) has submitted an application for renewal of permit number 4660. The Almeda Sims Wastewater Treatment Plant (RN100217140) produces/manufactures Wastewater Treatment and Sludge Drying at 12319 1/2 Almeda Road, Houston, Harris County.

This renewal will authorize the continued operation of drum dryers and storage silos. City of Houston has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutants	Total Amount Allowed (Tons Per Year)
PM	16.8
VOC	1.68
NOX	7.32
SO2	7.00
CO	40.4

The facilities being renewed continue to be controlled by the dryer/regenerative thermal oxidizers (“RTOs”) which burn off gases that lower the emissions that go into the air.