

**Plain Language Summary for New Source Review (NSR) Renewal
Certification Application for Air New Source Review Permit Number 56653**

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

University of Texas Medical Branch at Galveston (CN601246887) has submitted an application for renewal of permit number 56653. The University of Texas Medical Branch at Galveston facility (RN101921138) is a Medical University located at 301 University Blvd., Galveston, Galveston County.

This renewal will authorize the continued operation of two (2) existing combined heat and power (CHP) plants, a natural gas-fired boiler, and ancillary equipment. University of Texas Medical Branch at Galveston has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
NOx	13.21
CO	180.25
VOC	9.87
PM	18.14
PM10	16.2
PM2.5	14.71
SO2	1.4
H2SO4	0.24
(NH4)2SO4	0.32
NH3	10.56

The facilities being renewed continue to be controlled by low-NO_x combustors and selective catalytic reduction systems.