

**Plain Language Summary for New Source Review (NSR) Renewal  
Application for Air New Source Review Permit Number 70861**

*The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Sandy Creek Services, LLC (CN604335455) has submitted an application for renewal of permit number 70861. The Sandy Creek Energy Station (RN104136700) produces electric power at 2161 Rattlesnake Road, Riesel, McLennan County.

This renewal will authorize the continued operation of the pulverized coal-fired boiler, material handling of the coal, and other associated facilities to produce electricity. Sandy Creek Services, LLC has listed in the application the pollutants and amounts that will be emitted for each facility. Below is the total amount for each pollutant that is proposed to be emitted each year for all the facilities.

<b>Pollutant</b>	<b>Proposed Emissions (tons per year)</b>
VOC	129.04
PM	1080.32
PM <sub>10</sub>	52.08
NO <sub>x</sub>	1794.46
CO	5378.16
SO <sub>2</sub>	3585.03
Pb	0.41
HAPs	8.50
H <sub>2</sub> SO <sub>4</sub>	133.00
HFI	8.60
HCl	9.70
Halogenated Compounds	10.70
NH <sub>3</sub>	55.70
Hg	0.04

The facilities being renewed continue to be controlled by an SCR, fabric filter baghouse, spray dry absorber, activated carbon injection system, strip curtains, dust suppression water sprays, drift eliminators, and conservation vent valves.