

Plain Language Summary for New Source Review (NSR) Renewal Certification Application for Air New Source Review Permit Number 72579

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Golden Spread Electric Cooperative, Inc. (CN602663387) has submitted an application for renewal of permit number 72579. Mustang Station (RN101286433) produces/manufactures electrical power at 1937 County Road 390, Denver City, Yoakum County.

This renewal will authorize the continued operation of Gas Turbines 4, 5, and 6. Golden Spread Electric Cooperative, Inc. has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
Nitrogen oxides	653.82
Carbon monoxide	426.07
Volatile organic compounds	28.23
Particulate matter (any of three size categories)	105.40
Sulfur dioxide	201.57
Hazardous air pollutants	17.13

The facilities being renewed continue to be controlled by the use of low sulfur natural gas as fuel and the use of burners in the turbines which are designed and operated to reduce pollutants.