

**Plain Language Summary for New Source Review (NSR) Renewal
Certification Application for Air New Source Review Permit Number 739**

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

RW Miller Power, LLC (CN606151751) has submitted an application for renewal of permit number 739. The RW Miller Plant (RN102033891) is an electric generating facility at 2217 FM 3137, Palo Pinto, Palo Pinto County.

This renewal will authorize the continued operation of the Unit No. 3 Stack at the RW Miller Plant. The RW Miller Power, LLC has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Amount Allowed (tons per year)
VOC	36.42
PM ₁₀	59.5
NO _x	1,395
CO	555
SO ₂	273.75

The facility (Unit 3 Boiler) being renewed does not contain emission control devices.