

# TCEQ CHEMICAL SOURCES HISTORICAL BEST AVAILABLE CONTROL TECHNOLOGY (BACT) REQUIREMENTS

## Cooling Towers

This information is maintained by the CHEMICAL NSR Section and is subject to change. Last update 10/17/2006.

Year	Source Type	Pollutant	Minimum Acceptable Control	Control Efficiency or Details
1996	Cooling Towers	VOC	Non-contact design. Monthly monitoring of VOC in water - assume all VOC stripped out.	Monthly monitored with approved air stripping system.