Texas Commission on Environmental Quality On-Site Sewage Facility Program

Approved Product - Disposal Product

Product Name:EZflowModel Name:1003-T (Triangular Configuration Only)Manufacturer:Infiltrator Systems, Inc.Product Type:Disposal - Multi-pipeCapacity:Contact Manufacturer.

Contact:	Infiltrator Systems, Inc.
Address:	PO Box 768
	Old Saybrook, CT 06475
Phone:	(800) 221-4436 (888) 275-2239
Website:	http://www.infiltratorsystems.com/

Technical Notes: The length of trench in a two-foot wide trench without low-flow water saving devices is determined as follows: L = 0.53 A/(W+2), where: A is the minimum absorptive area calculated with no flow reduction (Q/Ra); W = 2 feet, the width of the trench. The l

Restrictions: System SHALL only be used where a standard absorptive drainfield is allowed under 30 TAC Chapter 285 which is in Class Ib, II, or III soils with no restrictive horizon or groundwater within two feet of the bottom of the excavation. Only a Class Ib, II, o

Certifying Agency: Third party Certification Standard: 30 TAC §285.32(c)(4)(B)

This information was printed from the TCEQ Approved Product page: <u>https://www.tceq.texas.gov/permitting/ossf/ossf-products</u>