

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

March 2, 2022

Michael Martinez
Onsite Sales Representative
Prinsco Water Management Solutions
4517 Eldorado Drive
Plano, Texas 75093

RE: Approval of the Prinsco Pro 4™/36 Leaching Chamber

Dear Mr. Martinez:

The Texas Commission on Environmental Quality (TCEQ) has completed its review of the Prinsco Pro 4™/36 Leaching Chamber. The request letter and the supporting documentation were emailed on December 17, 2021, and included

- A demonstration of compliance with 30 Texas Administrative Code Chapter 285 Section 285.33(c)(2),
- The plans and specifications for the product,
- A PE-stamped letter dated December 13, 2021, an evaluation summary, and an analysis summary from Mr. Tim Toliver, PE, of Advanced Pipe Services that certifies that the product, Prinsco Pro 4™/36 Leaching Chamber, meets or exceeds the dimensional requirements of IAPMO PS 63 and the structural capacity exceeds the load rating requirements of IAPMO PS 63.
- Advanced Pipe Services verification that the product is designed and manufactured to meet the AASHTO H-10 (16,000 pounds per axel) standards with 12 inches of compacted fill.
- A copy of the standard warranty that is provided with the product,

Based on the information presented on December 17, 2021, the Prinsco Pro 4™/36 Leaching Chamber is now approved for use in the state of Texas in conformance with all applicable rules contained in 30TAC §285. This letter serves as proof of approval for the above-listed product until it is listed on the TCEQ website. If you have any questions or require clarification or additional information, please contact Donna Cosper, P.E. by email at donna.cosper@tceq.texas.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "M. Gates".

Marilyn Gates, Section Manager
Program Support Section
TCEQ