

Bryan W. Shaw, Ph.D., *Chairman*  
Carlos Rubinstein, *Commissioner*  
Toby Baker, *Commissioner*  
Zak Covar, *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

August 31, 2012

Mr. Mike Flynn  
AeroGreen LLC  
P.O. Box 30068  
Lumberton, TX 77657

RE: Approval of AeroGreen Models 500AG, 600AG, 800AG, 1200AG and 1500AG

Dear Mr. Flynn,

The staff of the Texas Commission on Environmental Quality has completed our review of the Gulf Coast Testing (NSF/ANSI Standard 40) report on the subject products. Based on the GCT report and certifications, along with review of your training materials and drawings, the units have been approved for use in the State of Texas. Approval of the units was completed August 31, 2012.

The units are rated to treat 500, 600, 800, 1200 and 1500 gallons per day as inferred by the model designation.

Please note that the units do not include integral pretreatment chambers and separate pretreatment tanks will be required for installation in Texas.

This letter will serve as proof of approval until your aerobic treatment unit is listed on our web site. We request that you review the website listings of your products and advise us of any errors in the listings or company contact information.

If you have any questions concerning our review, please contact me by telephone at (512) 239-2150, by E-mail at [mike.price@tceq.texas.gov](mailto:mike.price@tceq.texas.gov) or by facsimile at (512) 239-6390. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

A handwritten signature in blue ink, appearing to read "Michael Price".

Michael Price  
On-site Wastewater Program  
MP/mp