

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 18, 2020

Ms. Sheryl Ervin, PG-TX
Senior Regulatory Specialist
Infiltrator Water Technologies
P.O. Box 768
Old Saybrook, CT 06475

Subject: Delta Treatment Enviro-Aire (EA) Product Line Approvals

Dear Ms. Ervin:

We have completed our review of the Delta Treatment Enviro-Aire products listed in the table below. The listed products are approved for use in Texas. This approval is based on:

- the NSF Standard 40 certifications and scaling certifications of the products,
- TCEQ approval of the training, operation, maintenance, and installation documents for the products.

After reviewing the training, operation, maintenance, and installation documents as well as the certification documents from NSF, TCEQ approves the Enviro-Aire EA Series products listed below:

Model Name	Rated Capacity (gallons/day)	Approved for Use in Tank Type
EA50 (also referenced as EA50-CA)	500	Concrete
EA52.5 (also referenced as EA52.6-IM1060)	525	IM-1060
EA60 (also referenced as EA60-CA)	600	Concrete
EA75 (also referenced as EA75-CA and EA75-IM1530, depending on the tank type)	750	Concrete and IM-1530
EA80-CA	800	Concrete

The suffixes CA, IM1060, and IM1530 indicate the type of tank in which the approved products may be installed.

This letter serves as proof of approval for the above-listed units until they are listed on the TCEQ website. If you have any questions or require clarification or additional information, please contact Donna Cosper, P.E. by email at donna.cosper@tceq.texas.gov.

Sincerely,

A handwritten signature in blue ink that reads "M Gates". The signature is written in a cursive style with a large, stylized "M" and "G".

Marilyn Gates, Section Manager
Program Support Section
TCEQ