

Jon Niemann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

February 14, 2020

Mr. Richard Morales
Acquired Wastewater Technologies, LLC
P.O. Box 96
Denham Springs, LA 70727

RE: Approval of the Acquired Wastewater Technologies, Mo-Dad 2 Model MB600PTX

Dear Mr. Morales,

The staff of the Texas Commission on Environmental Quality has completed our review of the Gulf Coast Testing, LLC (GCT) report on the subject product line. Based on the GCT report, the unit has been approved for use in the State of Texas. Approval of the unit, along with approval of the training materials, was completed February 7, 2020.

The Mo-Dad 2 Model MB600PTX unit is rated at 600 gallons per day treatment. Please note that a separate pretreatment tank is required for installation in Texas. All pump tanks, are subject to the requirements specified in 30 TAC 285.34(b).

This letter will serve as verification of your approval until the Mo-Dad 2 Model MB600PTX treatment unit is listed on the TCEQ website. If you have any questions concerning our review, please contact me by telephone at (512) 239-1937 or by E-mail at tanya.mitchell@tceq.state.tx.us. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

A handwritten signature in blue ink that reads "Tanya Mitchell".

Tanya Mitchell
On-site Sewage Program