Bryan W. Shaw, Ph.D., *Chairman*
Carlos Rubinstein, *Commissioner*
Toby Baker, *Commissioner*
Zak Covar, *Executive Director*

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

July 31, 2012

Mr. Joe Lacey II
Enviro-Flo, Inc.
P.O. Box 321161
151 Custom Drive
Flowood, MS 39232

RE: Approval of NuWater Model B-550

Dear Mr. Lacey,

The staff of the Texas Commission on Environmental Quality has completed our review of the Gulf Coast Testing (NSF/ANSI Standard 40) report on the subject product. Based on the GCT reports, the unit has been approved for use in the State of Texas. Approval of the unit was completed July 30, 2012.

Please note that, since the unit includes an integral pretreatment chamber, no separate pretreatment tank is required for installation in Texas.

All units may be supplied with, or without, a pump chamber. Units supplied with a pump chamber will have the suffix "Combo Tank" included in the model identifier. All integral pump chambers, and separate pump tanks, are subject to the requirements specified in 30 TAC 285.34(b).

This letter will serve as proof of approval until your aerobic treatment unit is listed on our web site. We request that you review the website listings of your products and advise us of any errors in the listings or company contact information.

If you have any questions concerning our review, please contact me by telephone at (512) 239-2150, by E-mail at mike.price@tceq.texas.gov or by facsimile at (512) 239- 6390. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

Michael Price
On-site Wastewater Program
Field Operations Support Division

MP/mp