

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Clancy Utility Holdings, LLC (CN605924489 ) proposes to operate Mirasol Springs Ranch Water Reclamation Facility and disposal facilities (RN111731972). an activated sludge treatment system operated as single stage nitrification with tertiary filtration. The facility will be located 0.8 miles southwest of the intersection of Hamilton Pool Road and Stagecoach Ranch Road , in Bee Cave, Travis/Hays County, Texas 78738.

This application is for a new application to discharge at a daily average flow of 39,000 gallons per day of treated domestic wastewater. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain low levels of Biochemical Oxygen Demand (5-day), Total Suspended Solids (TSS), and Ammonia Nitrogen (NH<sub>3</sub>-N). Domestic wastewater will be treated by an activated sludge treatment system operated as single stage nitrification with tertiary filtration. Treatment units include an influent screen, anoxic basin, aeration basin, clarifier, cloth filter, and chlorine contact chamber and the process produces Type I effluent.

